

## **General Disclaimer**

### **One or more of the Following Statements may affect this Document**

- This document has been reproduced from the best copy furnished by the organizational source. It is being released in the interest of making available as much information as possible.
- This document may contain data, which exceeds the sheet parameters. It was furnished in this condition by the organizational source and is the best copy available.
- This document may contain tone-on-tone or color graphs, charts and/or pictures, which have been reproduced in black and white.
- This document is paginated as submitted by the original source.
- Portions of this document are not fully legible due to the historical nature of some of the material. However, it is the best reproduction available from the original submission.

N76-18676

(NASA-CP-147501) SOLID POLYMER ELECTROLYTE  
WATER ELECTROLYSIS SYSTEM DEVELOPMENT Final  
Technical Report (General Electric Co.)  
Wilmington, Mass.) 169 p HC \$6.75 CSCL 10A G3/44

Unclassified  
18524

NASA CR-

1475-01

# REPORT

## SOLID POLYMER ELECTROLYTE WATER ELECTROLYSIS SYSTEM DEVELOPMENT

Contract NAS 9-13430

### FINAL TECHNICAL REPORT

Prepared for

National Aeronautics and Space Administration  
Lyndon B. Johnson Space Center  
Houston, Texas 77058



### DIRECT ENERGY CONVERSION PROGRAMS

50 FORDHAM ROAD  
WILMINGTON, MASSACHUSETTS 01887

GENERAL  ELECTRIC

CONTENTSSECTIONSUMMARY

	<u>Page</u>
1.0 Introduction	1
2.0 Low Pressure Water Electrolysis Breadboard System (WES)	5
2.1 Specification	5
2.2 System Description	5
2.3 Component Testing	10
2.4 System Evaluation and Test Results	23
3.0 Development of an Advanced Water Electrolysis System with Combination Water Pump, Phase Separator	33
3.1 Specification	33
3.2 System Description	33
3.3 Component Development	47
3.4 System Evaluation and Test Results	92
4.0 High Pressure Oxygen System Analysis and Design	119
5.0 SSP Support Work	126
6.0 Conclusions	127
7.0 Recommendations	128
Appendix	129



**GENERAL  ELECTRIC**

**List of Illustrations**

<u>Figure</u>		<u>Page</u>
1.	4-Man Breadboard WES Facility	2
2.	6-Man Advanced Water Electrolysis System Control Cabinet and Fluid Package	3
3.	4-Man Breadboard Water Electrolysis System Fluid Schematic	7
4.	Layout - 13-Cell Electrolysis Module	11
5.	13-Cell Electrolysis Module	12
6.	Water $\Delta$ P Versus Flow Characteristics - 13 Cell Module	13
7.	Oxygen Regulator (Absolute Type) Performance	17
8.	Hydrogen Regulator (Absolute Type) Performance	18
9.	Water Differential Regulator Performance	19
10.	Differential Water Back-Pressure Regulator Adjustment Characteristics	20
11.	Inverter, Pump and Flow Valve Performance	21
12.	Two-Phase Separator Assembly Water Flow Permeability	24
13.	Module O <sub>2</sub> Side Pressure Decay	25
14.	FDIA Instrumentation Power and Emergency Controller	30
15.	6-Man Advanced Water Electrolysis System Control Cabinet and Fluid Package	36
16.	Schematic - 6-Man Advanced Preprototype Water Electrolysis System (WES)	39
17.	Schematic, Electrical and Fluid Package - 6-Man Advanced Preprototype Water Electrolysis System	40
18.	Water Electrolysis System Control Cabinet, Front View	43
19.	Water Electrolysis System Fluid Package, Front View	45
20.	Water Electrolysis System Fluid Package, Rear View	46
21.	Electrolysis Cell Basic Hardware Components	48
22.	Detail Dwg. - Manifold Cell Gasket	49
23.	13-Cell Advanced Electrolysis Module	52
24.	Layout - 13-Cell, High-Pressure, High-Temperature Electrolysis Module	54
25.	WES Test Run Data - June 13, 1974	55
26.	WES Unattended Endurance Test Evaluation	57
27.	WES Test Run Data - August 20, 1974	58
28.	13-Cell Electrolysis Module Performance Characteristics	61
29.	Electrolysis Module Terminal Voltage During Cyclic (Orbital) Operating Mode	62
30.	75 Amp Power Conditioner	65
31.	Schematic - Power Conditioner	66
32.	Outline Dwg. - Phase Separator - Pump	68
33.	Liquid Flow vs. Pressure Rise - Phase Separator - Pump	70
34.	Layout - Water Accumulator	76
35.	Water Accumulator Bench Test	77



List of Illustrations (Cont.)

<u>Figure</u>		<u>Page</u>
36.	Water Accumulator Change in Piston Position with Change in Electrolysis Module Current	79
37.	Assembly Dwg. - Absolute Pressure Relief Valve	82
38.	Assembly Dwg. - Temperature Regulating Valve	86
39.	Deionizer Bed Pressure Drop vs. Water Flow Rate	88
40.	Gas Mixture Temperature vs. Percent by Volume in O <sub>2</sub> /H <sub>2</sub> Mixture Sensor	91
41.	WES Component Pressure Drop vs. Electrolysis Module Current	93
42.	WES Two-Phase Component Pressure Drop vs. Calculated Gas/ Liquid Volume Ratio.	94
43.	Calculated Hydrogen/Water Volume Ratio vs. Electrolysis Module Current	95
44.	WES/Dynamic Phase Separator - Pump, Calculated Pressure - Flow Characteristic	96
45.	Assembly Dwg. - Differential Pressure Relief Valve P/N P321 - 50	116
46.	Schematic High Pressure Oxygen Generation System	121



**List of Tables**

<u>Table</u>		<u>Page</u>
I	Guideline Specification for Four-Man Rated, Low Pressure Water Electrolysis System (WES)	6
II	FDIA Automatic Shutdown Summary	29
III	Guideline Specification for 6-Man Rated Advanced Water Electrolysis System (WES)	34
IV	Major Components List - 6-Man Advanced Preprototype Water Electrolysis System (WES)	37
V	Significant Design Data - 13-Cell Advanced Water Electrolysis Module	50
VI	Module Performance at Design Point Conditions	59
VII	Vendor Test Data - O <sub>2</sub> Absolute Back-Pressure Regulator	83
VIII	Vendor Test Data - H <sub>2</sub> Absolute Back-Pressure Regulator	84
IX	WES Failure Mode and Effects Analysis - 6-Man Advanced Preprototype System	98
X	FDIA Emergency Shutdown Summary - 6-Man Water Electrolysis System (WES)	110



SECTION 1.0INTRODUCTION

The need for a reliable, long-lived, and efficient water electrolysis unit for closed-cycle life-support systems has prompted a number of development programs encompassing both acid and alkaline technologies. Early acid systems using liquid sulfuric or phosphoric acid electrolytes suffered a significant performance penalty, as compared with alkaline systems, in that they required considerably more power to generate a given amount of oxygen. Both acid and alkaline systems with liquid electrolyte have also encountered problems with leakage, materials compatibility, performance stability, and life.

In March, 1970, NASA Langley Research Center awarded a contract (NAS 1-9750) to General Electric Company, Direct Energy Conversion Programs, Wilmington, Massachusetts (then located in Lynn, Massachusetts) to investigate the use of the solid polymer electrolyte (SPE) technology in a water electrolysis system to generate oxygen and hydrogen for manned space station applications. The long life and stable performance of the SPE electrolysis concept was demonstrated by four separate laboratory cells operating approximately 9000 hours each and a seven cell module (two-man O<sub>2</sub> rate) accumulating 11,000 operating hours all without failure. Under this program, a one-man rated breadboard SPE water electrolysis system (WES) was developed and demonstrated the performance/life characteristics of the SPE electrolysis technology. In addition, the program culminated in the fabrication of the major components for a four-man rated breadboard oxygen generation system. This program was completed in August 1972, with results documented in a final report NASA CR-112183 dated August 1972.

In October 1972, the present program, consisting of two phases, was initiated. Phase I utilized the previously fabricated major components, where appropriate, and fabricated and tested a four-man rated, low pressure breadboard WES with the necessary instrumentation and controls. A photograph of this system is shown in Figure 1. Phase II encompassed the development of a six-man rated, high pressure, high temperature, advanced preprototype WES. This configuration included the design and development of an advanced water electrolysis module, capable of operation at 2758 kN/m<sup>2</sup> (400 psig) and 366.5K (200°F), and a dynamic phase separator/pump in place of a passive phase separator design. Major components and instruments meeting design requirements of this system, were utilized from previous WES contract work. The six-man rated advanced WES was contained in the control cabinet and fluid package shown in Figure 2. Evaluation of this system demonstrated the goal of safe, unattended automatic operation at high pressure and high temperature with an accumulated gas generation time of over 1000 hours. Work under this contract was concluded in June 1975.

During the period of this contract (approximately 2 1/2 years), support was also provided to two other water electrolysis development programs of NASA. System performance mapping tests were performed on the four-man WES, including






Figure 1. Four-Man Breadboard WES Facility




Figure 2. Six-Man Advanced Water Electrolysis System Control Cabinet and Fluid Package

**GENERAL  ELECTRIC**

exploratory, off-design conditions to provide design data in support of the Space Station Prototype (SSP) Oxygen Generation Subsystem design. Also, the six-man WES was tested in different operating modes to provide design information in support of the development of the WES demonstrator unit for the Life Sciences Payload Program, Contract No. NAS 9-14205.



**SECTION 2.0    LOW PRESSURE BREADBOARD, WATER ELECTROLYSIS  
SYSTEM (WES)**

The WES components developed and fabricated under Contract NAS 1-9750 were designed to be capable of continuous oxygen generation equivalent to a nominal four-man rate basis of 4.54 kg/day (10 lb O<sub>2</sub>/day), with a maximum nominal capacity equivalent to a six-man rate. Wherever possible and as directed by the contract, standard commercial materials and components were selected to provide functional demonstration compliance at minimal cost and delivery schedule. It should be noted therefore, that these breadboard components would require modification and redesign in order to provide flight-worthiness to withstand "hard" environment launch vibration, shock and acceleration along with weight and volume reductions, mounting configuration, producibility and maintainability considerations.

**2.1            Specification**

A "guideline" specification for design capability of the four-man rated, low pressure breadboard WES is outlined in Table I.

**2.2            Configuration**

Figure 3 is a fluid schematic of an SPE water electrolysis system showing the basic arrangement of the breadboard components. It should be realized that additional control components and instrumentation would be necessary for automatic control, performance monitoring, fault isolation, shutdown and safety considerations.

Primary fluid and electrical interfaces to the WES are:

- 28 VDC to Control Panel
- 28 VDC to Inverter
- 115 VAC, 60 Hz to Control Panel
- 80 psia nitrogen as necessary for scavenging hydrogen overboard  
(in and out)
- Water Coolant (in and out)
- Make-up (feed water) (in)
- Hydrogen (out)
- Oxygen (out)

As shown in Figure 3, feed water is supplied to the WES at a make-up water rate of approximately 5.13 kg/day (11.3 lb/day) and 69 kN/m<sup>2</sup> (10 psig) for an oxygen generation rate of 4.5 kg/day (10 lb/day). The water enters the WES through a check valve which prevents reverse flow when the system is shutdown at normal



TABLE I

GUIDELINE SPECIFICATION FOR FOUR-MAN RATED, LOW PRESSURE  
WATER ELECTROLYSIS SYSTEM (WES)

WES Capacity

10 lb/day (4.54 kg/day) oxygen (nominal four-man rate - continuous).

Equivalent 75 amp oxygen generation (maximum) - cyclic usage up to 16 hours "on"/  
8 hours "off".

WES Gas PurityOxygen Generation

99.7% min. O<sub>2</sub>

0.1% max. H<sub>2</sub>

Remainder - Not defined.

Hydrogen Generation

99.3% min. H<sub>2</sub>

0.2% max. O<sub>2</sub>

Remainder - Not defined.

NASA-Maintained Downstream Gas Pressures of WES

Oxygen Subsystem: 14.7 psia (101.4 kN/m<sup>2</sup>) or less.

Hydrogen Subsystem: 20 ± 5 psia (137.9 ± 35 kN/m<sup>2</sup>).

Make-up Water (Feed Water) Available to WES

Temperature: +40 to +170°F (277.6 to 350K).

Pressure: 25 ± 5 psia (172 ± 35 kN/m<sup>2</sup>).

Water Purity: < 100 ppm by weight solids (assume ionic species).

< 30 micromhos/cm specific conductance (12,500 ohm-cm max.  
specific resistance).

Bacteria - *Pseudomonas Aeruginosa* 10 counts/cc

*Alcaligenes Faecalis* 10 counts/cc

Fungii - Mucor 1 spore count/cc

Molds - Not defined.

Coolant Available to WES

Fluid: Water with propylene glycol additive to establish a nominal 0°F (273K)  
freezing point.

Temperature: +40 ± 3°F (277.6 ± 1.7K).

Pressure: 30 psig (552 kN/m<sup>2</sup>) max.

Flow: Up to 1 gpm (3.78 l/min.)

Nitrogen Available to WES

Pressure: 30 psia (552 kN/m<sup>2</sup>) nominal.

Electrical Services Available to WES

28 ± 3 VDC.

115 VAC nominal at 60 Hz.






Figure 3. "4-Man" Breadboard Water Electrolysis System Fluid Schematic

working pressures. The feed water is mixed with recycled module cooling water upstream of the particulate filter to the water pump. This process water is circulated throughout the WES by a gear-type pump with quantity regulation maintained by the water flow control valve and needle bypass valve. The pump design includes an internal relief valve which becomes functional if an internal dead-ended condition arises within the pump. Pressurization of the feed water to 69 kN/m<sup>2</sup> (10 psig) reduces the pump pressure rise and subsequent journal bearing load and also prevents the relief valve from continuously relieving. Excess pump capacity is delivered through the needle bypass valve. An orifice could be used in place of the needle valve for a flight designed system. The water pump is powered through a DC to 3-phase AC inverter with a 28 VDC input. Downstream of the pump, the water flows through a deionizer resin bed which reduces the ionic contamination level to acceptable WES purity limits of  $\geq 400,000$  ohm-cm.

The water then passes through a regenerative heat exchanger prior to mixing in a temperature regulating valve which controls the supply temperature to the electrolysis module at approximately 311K (100°F). This temperature control maintains electrolysis module performance essentially independent of coolant and environmental temperature variations. The process water is delivered to the cathode (hydrogen generating) side of the 13-cell electrolysis module. Since the electrolysis occurs at the anode, water required for this reaction diffuses through the solid polymer electrolyte at a rate just equal to that required for oxygen generation. (A cross section showing the SPE electrolysis cell concept and a description of operation are provided in the Appendix.) The generated oxygen will be saturated at the cell temperature and pressure [approximately 322K (120F) and 428 kN/m<sup>2</sup> (62 psia)], but will contain no liquid water when discharged to ambient pressure. The free liquid water required for cell cooling will remain on the cathode side and will exit with the hydrogen as a two-phase mixture. This heated mixture passes through the regenerative heat exchanger to transfer its heat to the incoming colder process water. The two-phase mixture (hydrogen and module cooling water) leaving the regenerative heat exchanger is then cooled to approximately room temperature in the primary heat exchanger which transfers heat to the interface coolant fluid. Waste heat from the power conditioner is removed by the attached heat sink through which the interface coolant is also circulated. A biological resin bed filter is installed immediately upstream of the two-phase separator to remove micro-organisms (i.e., bacteria, molds, fungi, yeast) and particulate matter by three possible mechanisms, namely: electrostatic attraction to the resin beads; particulate matter depth filtration through the resin bed column; and retardation or actual destroying of bacteria and mold growth by any localized acidified water within the resin bed column.

The two-phase mixture, therefore, has been pre-cleaned prior to entry into the two-phase separator. The life of the hydrophilic tubes with a pore size of 2 to 3.5 microns within the separator is therefore increased since pore clogging is minimized. The H<sub>2</sub>/H<sub>2</sub>O phase separator provides a passive means of separating liquid from a gas in a zero gravity environment using both hydrophilic and hydrophobic



separation elements. Primary separation is accomplished by removing water slugs from the two-phase mixture (hydrogen and water) with five hydrophilic porous glass tubes connected in a series fluid flow path. The hydrophilic elements permit the water to pass through the tube wall under a controlled differential pressure to the housing side of the assembly. Gas leaving the last tube, which is normally free of entrained water, passes through three parallel hydrophobic membranes located in the separator cover. The hydrophobic membranes, by their ability to pass only gas, serve as a trap to prevent water carryover to the hydrogen outlet stream in the event of porous tube failure and/or differential water regulator failure. The pressure differential across the hydrophilic elements is controlled by a differential back-pressure regulator which is referenced to the inlet side of the hydrophobic membranes. The water leaving the differential back-pressure regulator (module cooling water) is mixed with the feed water and returned to suction side of the pump through the particulate filter.

The electrolysis module is supplied by a power conditioner which maintains a constant current corresponding to a pre-selected oxygen generation rate. This electronic unit is capable of 75 amps maximum input to the module which is an oxygen generation rate of approximately 15.3 lb/day.

The WES would normally be operated through a single switch at a fixed oxygen generation rate output.

The major components developed and fabricated under Contract No. NAS 1-9750 were:

- 1) 13-Cell Electrolysis Module
- 2) 75 amp Power Conditioner
- 3) Control Panel
- 4) Prototype Two-Phase Separator
- 5) Deionizer Resin Bed
- 6) Biological Filter Resin Bed
- 7) Regenerative Heat Exchanger
- 8) Water Temperature Control Valve
- 9) Process Water Pump
- 10) DC/AC Inverter
- 11) Water Flow Valve
- 12) Absolute Oxygen Back-Pressure Regulator
- 13) Absolute Hydrogen Back-Pressure Regulator
- 14) Differential Back-Pressure Regulator

These breadboard components were individually acceptance tested as part of the aforementioned contract. Installation and operation of these components as part of an integrated four-man rated system was accomplished under Phase I of Contract No. NAS 9-13430.



Figure 1 illustrates the four-man rated breadboard WES which resulted from modification of the NASA/LRC facility (ref. Figure 13 of Report NASA CR-112183). The modification required complete teardown of the one-man rated WES to install the four-man rated breadboard components previously listed.

In addition, the installed system and facility were modified to include start-up pressurization capability, increased make-up water reservoir capacity, primary heat exchanger, city water coolant system and automatic shutdown capability with a fault detection and isolation panel. A 100 amp DC power supply along with facility wiring and temperature, pressure, current and voltage readout was also provided.

## **2.3      Component Testing**

As previously described, the fourteen major components listed on Page 9 had been designed, fabricated and some individually bench tested under Contract NAS 1-9750. Component descriptions, specifications, drawings and check-out test data are included in the Final Report NASA CR-112183 under that contract.

Component checkout tests were completed under the current program, most of which required installation with instrumentation as part of an electrolysis system in order to obtain meaningful operating conditions and test data. The following component checkout activities were undertaken.

### **2.3.1      13-Cell, Low Pressure, Electrolysis Module**

A 13-cell, low pressure ( $434 \text{ kN/m}^2$ , 100 psi, maximum operating pressure), electrolysis module design, as shown in Figure 4 and pictured in Figure 5, was designed to meet requirements of a four-man rated low pressure WES under Phase I of this program. As reported under Phase II, most of the cell parts were salvaged for modification and incorporation into a six-man rated, high pressure ( $2758 \text{ kN/m}^2$ , 400 psi) advanced electrolysis module design. A satisfactory proof-pressure leakage test was performed on the low pressure module design (10/17/72) submerged in water and under  $690 \text{ kN/m}^2$  (100 psig) nitrogen pressure common to oxygen and hydrogen sides. There was no indication of external leakage. Subsequently, a satisfactory cross-membrane leakage test was performed with  $345 \text{ kN/m}^2$  (50 psig) nitrogen to the hydrogen side and atmospheric pressure on the oxygen side. Measured gas leakage was within acceptable SPE permeability limits.

Module flow-pressure drop characteristics of the cathode side were measured with "solid" water flowing respective of a non-operating condition as shown in Figure 6. Two tests were performed, of which the 11/21/72, data is considered more appropriate because some residual gas may have been trapped by screens in the cells for the 11/20/72 evaluation.






Figure 4.





Figure 5. 13-Cell Electrolysis Module

ORIGINAL PAGE IS  
OF POOR QUALITY

Figure 6. Water  $\Delta P$  Versus Flow Characteristics

The module demonstrated satisfactory steady state performance on 11/27/72. This was at four-man rated design point conditions of 49.1 amps, current density of  $230 \text{ mA/cm}^2$  (213 ASF), a process water feed rate of 80 cc/min at 311K (100°F), two-phase mixture (hydrogen plus liquid water) outlet temperature of 331.7K (137.5°F) and nominal operating pressure of  $75.8 \text{ kN/m}^2$  (11 psig). Typical voltage performance at these conditions was as follows:

Voltage, VDC  
at 49.1 Amps,  $230 \text{ mA/cm}^2$

<u>Cell No.</u>													<u>Total Sum.</u>	<u>Total Term.</u>
<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>	<u>6</u>	<u>7</u>	<u>8</u>	<u>9</u>	<u>10</u>	<u>11</u>	<u>12</u>	<u>13</u>		
1.690	1.682	1.678	1.691	1.682	1.661	1.674	1.669	1.668	1.675	1.680	1.670	1.672	21.82	21.85

Immediate gas generation was demonstrated during push-button starts at pre-selected current settings from a nominal 5.6 amps to 49.1 amps. During cyclic operation under typical space-station orbit conditions of a nominal 55 minutes "on" and 39 minutes "off", the oxygen was delivered during the instantaneous start-up transient and thereafter, free of liquid water. Liquid-free oxygen delivery was observed during pushbutton starts following shutdown periods of up to 16 hours. However, with shutdown periods of approximately 24 hours, or longer, some water will be delivered with the oxygen during a subsequent start transient (10 to 30 cc of water). The start transient is that elapsed time from a pushbutton start (at a pre-selected current setting) for the module oxygen-side pressure to reach a steady-state level as set by the absolute oxygen back-pressure regulator. In this four-man rated system, the regulator is set at a nominal  $310 \text{ kN/m}^2$  (45 psig). This water discharge, only at start-up, is caused by the hydraulic permeability of the SPE membrane which allows the gradual transport of water from the flooded hydrogen side to the oxygen side over an extended shutdown period.

### 2. 3. 2 Power Conditioner and Control Panel

The power conditioner and control panel checked-out satisfactorily for all steady state, start and stop transient conditions up to the four-man design point of 49.1 amps ( $230 \text{ mA/cm}^2$ ). In addition, satisfactory operation was demonstrated at above design point conditions up to 75 amps ( $350 \text{ mA/cm}^2$ ).

The automatic current limit shutdown feature of the power conditioner was satisfactorily demonstrated at approximately 80 amps.



## 2.3.3

Temperature Regulating Valve

This valve, Model No. 8A767 - Rev. 002, manufactured by Standard-Thomson Corp., is factory set to control the outlet water temperature of the valve  $313 \pm 2.2\text{K}$  ( $104 \pm 4\text{F}$ ). However, during WES testing in October - December 1972, there was observed occasional upward shifting of the controlled mixture-out temperature (cold water plus hot water) to as high as  $313\text{K}$  ( $140\text{F}$ ). It has been hypothesized that residual gas bubbles in the water at the 80 cc/min. process water rate would tend to collect in the vicinity of the "wax" actuator internally in the valve, causing poor heat transfer characteristics with subsequent "out-of-spec" control of the temperature. During WES operation, when temperature regulation was out-of-spec, it was demonstrated that manually tapping the valve would clear the gas and re-establish proper temperature control at the nominal  $311\text{K}$  ( $100\text{F}$ ) setting.

On 1/3/73, the valve was removed from the WES for a bench evaluation. The results of this investigation demonstrated satisfactory performance of the temperature regulating valve with "solid" water flows of more than 100 cc/min.

In the WES, process water is delivered to the module cathode side for electrolysis and module cooling. A two-phase mixture of water-hydrogen gas sluglets therefore exits from the module at module pressure and temperature. This water also contains dissolved hydrogen gas.

The downstream passive separator removes the water sluglets from this mixture with subsequent return circulation of the water to the pump suction side. In the WES, pressure-drop of components in the return circulating loop (water differential back-pressure regulator, check valve, etc.) have been kept low to minimize the release of dissolved gas in the water "from coming out of solution", due to expansion from a high pressure region to a lower region. It is possible, therefore, that some dissolved gas may come out of the water (effervescent effect) which will be re-circulated by the pump. It was concluded, therefore, that the temperature regulating valve had previously failed to control because of this gas mixture condition.

The evaluation of the problem resulted in the following corrective action:

- 1) For gravity operation, the valve must be mounted at a  $45^\circ$  attitude to provide internal gas clearance from the wax-actuator end of the valve. This facility change was incorporated on 1/24/73. A configuration design change to the valve is possible to remove the attitude sensitivity.
- 2) To enhance gas clearance through the valve, the process water rate was increased by 50% (from 80 to 120 cc/min.).



After introducing these corrective actions, performance of the temperature regulating valve was satisfactory.

#### 2.3.4 Absolute Oxygen Back-Pressure Regulator

Regulator performance of the controlled upstream pressure was evaluated on Ausco Inc. regulator, type P320-51. Figure 7 presents the results of this investigation. Compliance with GE/DECP requirements was satisfactory.

#### 2.3.5 Absolute Hydrogen Back-Pressure Regulator

Regulator performance of the controlled upstream pressure was evaluated on Ausco Inc. regulator, type P320-52. Figure 8 presents the results of this evaluation. Compliance with GE/DECP requirements was somewhat marginal due to the controlled setting being near the lower specification limit. Actually, the results confirm the setting of this component as it was originally received from the vendor. The setting is readily changeable and was adjusted to bring the control point up to approximately 172 kN/m<sup>2</sup> (25 psig) from a nominal 165 kN/m<sup>2</sup> (24 psig).

#### 2.3.6 Differential Back-Pressure Water Regulator

Regulator performance of the controlled upstream water pressure below a nominal hydrogen reference pressure of 165 kN/m<sup>2</sup> (24 psig) was evaluated on Ausco Inc. regulator, type P321-50. Figure 9 presents the results of this investigation. Compliance with GE/DECP requirements was satisfactory.

Figure 10 presents the adjustment characteristics of this regulator as investigated from the original as-received setting.

#### 2.3.7 Inverter, Process Water Pump and Flow Valve

These components were always operated together in bench testing and for the delivery of process water in the WES. A second pump, Micropump Corp. Model No. 02-70-316-986, which included a plastic poppet-type relief valve in place of the ball-type and a 316 SST gear housing in place of a plastic housing, was purchased for this program as a back-up to the original pump (Model No. 02-70-316-731). The performance characteristics of these two pumps are presented in Figure 11. Component evaluation also occurred during systems testing of the WES which identified a number of pump problems that were investigated. A summary of these problems with corrective actions is presented as follows:

- 1) Uncoupling of the magnetic drive between the motor and pump was resolved by drilling pressure balancing holes in the Teflon hub of the driven magnet.



DIGITAL  
QUALITY  
OF POWER  
QUALITY

DIRECT ENERGY CONVERSION PROGRAMS




Figure 7. Oxygen Regulator (Absolute Type) Performance Controlled Upstream Pressure vs. Flow

GENERAL ELECTRIC




Figure 8. Hydrogen Regulator (Absolute Type) Performance - Controlled Upstream Pressure vs. Flow




Figure 9. Water Differential Regulator Performance - Controlled Upstream Water Pressure Below a Nominal 24 psig H<sub>2</sub> Ref. vs. Flow






Figure 10. Steady State WES Operation

ORIGINAL PAGE IS  
OF POOR QUALITY

DIRECT ENERGY CONVERSION PROGRAMS

20




Figure 11. Inverter, Pump and Flow Valve Performance NASA/MSC Water Electrolysis System

- 2) Oscillations in pump discharge pressure had resulted in breakage in the internal relief valve spring. Tried a vendor recommendation of relief valve ball material change from Teflon to rubber, but spring breakage continued. A change from a ball-type to a poppet-type relief valve design configuration did reduce pressure fluctuations and resulted in no spring breakage.
- 3) Pump cavitation was caused by entrained gas in the pump suction resulting from dissolved gas (the water is saturated with hydrogen at the operating pressure of the phase separator) coming out of solution at reduced pressure and increased temperature. An attempt to reduce pump pressure fluctuations with an external bypass to deliver excess flow (approximately 75% of input flow) externally to the pump rather than internally through the relief valve increased the cavitation problem. Cavitation was reduced by raising pump suction pressure, reducing pump suction water temperature and by increasing water pump throughput rate from 80 to 120 cc/min which forced out residual gas.
- 4) The audible noise emitted by the pump was reduced by a material change of the pump-gear housing from plastic to stainless steel.
- 5) External pump leakage was eliminated by a design change to gaskets in place of an O-ring seal.

### 2.3.8 Passive Phase Separator

Operating characteristics of the prototype, five-tube passive phase separator were evaluated during transient and steady-state operation of the four-man rated electrolysis system. A photograph, drawings and a complete description of this assembly is provided in Report NAS CR-112183. This is a passive phase separation device (a dynamic phase separator was developed and tested under Phase II of this program) which utilized five hydrophilic fritted glass tubes for water transport/gas blockage and hydrophobic polypropylene membrane material for gas transport/water blockage.

During system startup, a transient high pressure differential existed momentarily across the hydrophilic tube walls which resulted in some bubble-point breakthrough. This was resolved by replacing two tubes with bubble points of 47 kN/m<sup>2</sup> (6.8 psid) and 59 kN/m<sup>2</sup> (8.5 psid) with tubes of higher bubble points such that all five tubes were greater than 62 kN/m<sup>2</sup> (9.0 psid).

Flooding of the hydrophobic assembly also occurred which was attributed to loss of water permeability of the hydrophilic tubes due to pore contamination and the effects of higher water viscosity and insufficient hydrophilic  $\Delta P$  margin when



operating with a cold (278-283K) (40-50°F) two-phase mixture. Corrective action included (1) discontinuation of the tubes capable of reclamation which resulted in higher water flow permeability of the separator assembly, (2) increasing the hydrophilic  $\Delta P$  by adjusting the water differential regulator from 16.5 kN/m<sup>2</sup> (2.4 psid) to 42.7 kN/m<sup>2</sup> (6.2 psid), (3) thoroughly draining and flushing the system to remove contamination (particulate matter and/or microbiological species), and (4) repacking of the deionizer and biological filter resin beds with new beads after thermoplastically coating (with FEP) the inside of the housings to eliminate a possible corrosion contamination source. Test data showing the water flow permeability of the refurbished separator assembly is provided in Figure 12.

## 2.4 System Evaluation and Test Results

### 2.4.1 System Checkout Tests

WES system checkout was essentially performed during evaluation of components, as described in Section 2.3, such as the electrolysis module, power conditioner, static phase separator, water pump, pressure regulators, etc., under various conditions of module current or gas generation rate, process water rates, process water temperature, city water coolant temperature, etc.

As part of WES testing, electrolysis module operation prior to April 4, 1973, had been exclusively operated in the cathode water feed mode with the oxygen side pressure greater than the hydrogen (cathode) side pressure. This O<sub>2</sub> > H<sub>2</sub> pressure condition was selected to minimize water carryover to the oxygen side by hydrodynamic permeability through the SPE cell from the flooded hydrogen side when the electrolysis module was shutdown. In support of a parallel engineering design effort on the oxygen generation subsystem for the Space Station Prototype (SSP) it was necessary, for overall life support system considerations, to learn the effects of electrolysis module operation and deactivation with a H<sub>2</sub> > O<sub>2</sub> pressure condition. Laboratory experiments have verified that electrolysis cell performance (i.e., cell voltage) is independent of oxygen pressure, but that cell voltage increases about 30 millivolts for each tenfold increase in hydrogen absolute pressure in agreement with the theoretical Nernst equation. Because of protonic pumping (Ref. Appendix) of water from the anode to the cathode in the SPE cell under load, there would be no water transport to the oxygen side even with a H<sub>2</sub> > O<sub>2</sub> pressure differential as was evidenced by test. The effects of a deactivated electrolysis module were studied during the typical orbital "off" period of 39 minutes, and also for extended shutdown periods up to 90 hours. The effects of diffusion and the consumption of gases (H<sub>2</sub> and O<sub>2</sub>) in the "fuel cell" mode were demonstrated after shutdown. Module total voltage decreased from an operating value of about 22 VDC to less than 2 VDC within 2 hours of shutdown for either H<sub>2</sub> > O<sub>2</sub> or O<sub>2</sub> > H<sub>2</sub> pressure condition. Because the trapped gas volume on the oxygen side of the electrolysis module is considerably smaller than that on the hydrogen side, which includes the heat exchangers, biological filter resin bed and phase separator, the oxygen pressure decays more rapidly than the hydrogen pressure after shutdown. The results of measuring oxygen side pressure decay are plotted in Figure 13.



24





Figure 12. Two-Phase Separator Assembly

Figure 13. Module O<sub>2</sub> Side Pressure Decay vs. Shutdown Time

Water accumulation on the oxygen side after shutdown depends upon initial  $H_2 > O_2$  pressure conditions and the time interval for water transport. The water discharged from the oxygen side was measured on the subsequent start-up. In summary, the water discharged at start-up after a 39 minute orbital shutdown amounted to about 2 to 3 cc. After an extended 90 hour shutdown about 90 cc of water was discharged at start-up. This is greater than the total calculated volume of all 13 cells on the oxygen side of the electrolysis module, indicating eventual complete flooding with time.

For module operation with  $O_2 > H_2$  pressure conditions, the discharge of water from the oxygen side on start-up is substantially reduced. No water was ever delivered out the oxygen side for any orbital cycle start-up (39 min. "off" period) and for any extended shutdown period up to 16 hours. The following quantities were measured after the shutdown periods cited: 10 cc in 24 hours, 15 cc in 72 hours, 63 cc in 12 days.

#### 2. 4. 2 SSP Mapping Tests

Exploratory system testing was conducted in support of anticipated SSP operating requirements which represented conditions of overstress outside the design point of the four-man rated WES capability of 4.54 kg/day (10 lb/day) oxygen generation rate. Steady state electrolysis module voltage performance is shown in the following table at the four-man rated WES design point represented by a current of 49.1 amps ( $230 \text{ mA/cm}^2$ ), module controlled water inlet temperature of 311K (100F) and two-phase ( $H_2/H_2O$ ) outlet temperature of 327.7K (130F) obtained from a process water flow of 120 cc/min, 326 kN/m<sup>2</sup>  $O_2$  pressure, and 174 kN/m<sup>2</sup> hydrogen pressure.

Voltage, VDC  
at 49.1 Amps, 230 mA/cm<sup>2</sup>

Date	Cell No.													Total Sum.	Total Term.
	1	2	3	4	5	6	7	8	9	10	11	12	13		
1/29/73	1.715	1.707	1.708	1.713	1.709	1.685	1.705	1.692	1.712	1.697	1.704	1.692	1.695	22.17	22.14

Five simulated orbital cycles were demonstrated, each consisting of a 55 minute "on" power period and a 39 minute "off" period. Design point operating conditions were identical to those cited above except that module  $H_2/H_2O$  outlet temperature of 321.2K (128.5F) was slightly lower reflecting a shorter warm-up period.



**GENERAL  ELECTRIC**

At essentially the same operating pressures, but at a minimum load condition of 5.7 amps ( $27 \text{ mA/cm}^2$ ), module water inlet temperature of  $282.6\text{K}$  ( $85^\circ\text{F}$ ) and  $\text{H}_2/\text{H}_2\text{O}$  outlet temperature of  $303.7\text{K}$ . ( $86.8^\circ\text{F}$ ) the following steady state voltages were measured.

Voltage, VDC  
at 5.7 Amps,  $27 \text{ mA/cm}^2$

<u>Date</u>	<u>Cell No.</u>													<u>Total Sum.</u>	<u>Total Term.</u>
	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>	<u>6</u>	<u>7</u>	<u>8</u>	<u>9</u>	<u>10</u>	<u>11</u>	<u>12</u>	<u>13</u>		
2/2/73	1. 562	1. 563	1. 562	1. 564	1. 562	1. 559	1. 564	1. 559	1. 563	1. 561	1. 565	1. 558	1. 562	20. 31	20. 31

With the  $\text{O}_2$  and  $\text{H}_2$  pressure regulators maintaining design operating pressures as before, and with the temperature regulator controlling water inlet temperature to the module at  $311.5\text{K}$  ( $100.9^\circ\text{F}$ ), off design conditions were established for a load of 75 amps ( $350 \text{ mA/cm}^2$ ). A module two-phase outlet temperature of  $343.2\text{K}$  ( $158^\circ\text{F}$ ) was established at the same process water flow of 120 cc/min. Cell voltage performance was measured as follows.

Voltage, VDC  
at 75 Amps,  $350 \text{ mA/cm}^2$

<u>Date</u>	<u>Cell No.</u>													<u>Total Sum.</u>	<u>Total Term.</u>
	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>	<u>6</u>	<u>7</u>	<u>8</u>	<u>9</u>	<u>10</u>	<u>11</u>	<u>12</u>	<u>13</u>		
2/2/73	1. 788	1. 772	1. 770	1. 780	1. 776	1. 730	1. 763	1. 748	1. 785	1. 760	1. 765	1. 747	1. 750	22. 99	22. 94

Two simulated orbital cycles, each of nominal 55 minutes "on" and 39 minutes "off", at the off design condition of 75 amps were also successfully completed, as was the minimum load condition of 5.7 amps.

An evaluation of electrolysis module operation at higher temperature was made with the water inlet temperature manually controlled at a nominal  $399\text{K}$  ( $150^\circ\text{F}$ ) and at design load of 49.1 amps. Steady state module  $\text{H}_2/\text{H}_2\text{O}$  outlet temperature was measured at  $348\text{K}$  ( $166.8^\circ\text{F}$ ) with the following improved corresponding voltage performance.



Voltage, VDC  
at 49.1 Amps, 230 mA/cm<sup>2</sup>

Date	1	2	3	4	5	6	7	8	9	10	11	12	13	Total Sum.	Total Term.
2/6/73	1.645	1.638	1.637	1.638	1.636	1.619	1.636	1.622	1.638	1.628	1.637	1.626	1.636	21.27	21.23

## 2.4.3 Breadboard System Unattended Test

Following component and system checkout tests, the WES breadboard configuration and operating conditions were sufficiently defined to specify requirements for automatic control, fault monitoring detection with automatic safe shutdown allowing unattended operation. A Failure Mode and Effects Analysis of the WES was made to identify single point failures and determine where redundancy or fault detection of components was required in the system. A Fault Detection and Isolation Analysis (FDIA) identified the monitoring instrumentation and control requirements for automatic WES shutdown capability. Wherever possible, commercial "off-the-shelf" components were purchased to minimize the cost of the FDIA instrumentation.

Table II is a summary of those monitoring devices installed to detect out-of-limit component operating conditions which result in an automatic shutdown. An emergency controller shown in Figure 14 was designed and fabricated which monitored sensor signals and provided conditioning and logic for automatic emergency shutdown of the WES.

After complete installation and checkout of all fault detection and isolation instrumentation, breadboard system operation at design point conditions was initiated on 8/7/73. Typical electrolysis module voltage performance logged on the following at 49.1 amps (230 mA/cm<sup>2</sup>) with temperatures of 310.8K (99.7F) water-in, 328K (130.8F) H<sub>2</sub>/H<sub>2</sub>O out, 121 cc/min process water rate, 165.4 kN/m<sup>2</sup> (24.7 psig) O<sub>2</sub> pressure and 265.5 kN/m<sup>2</sup> (38.5 psig) H<sub>2</sub> pressure was as shown in the following table.



**Table II**

**FDIA Automatic Shutdown Summary**

<u>WES Component Functional Description</u>	<u>Monitoring Device</u>	<u>Fault Isolation Device</u>	<u>WES Result</u>
Low Module Current (Pwr. Cond.)	Meter	Red light on	Automatic Shutdown
High Module Current (Pwr. Cond.)	Meter	Red light on	
High Two-Phase Module Outlet Temperature	Meter	Red light (3) on	
High H <sub>2</sub> Concentration in O <sub>2</sub> Outlet	Meter	Red light on	
Low City Water (Coolant) Flow	Flowrator	Red light on	
Loss 28 VDC Supply Voltage	Meter	Green light out	
Loss 115 VAC Supply Voltage	--	Green light out	
High Power Conditioner Input Current (Circuit Breaker)	SW Pos.	Red light on	
High Pump Outlet Pressure	Meter	Red light on	
High Separator Hydrophilic ΔP	Meter	Red light on	
High Separator Hydrophobic ΔP	Meter	Red light on	
High Module O <sub>2</sub> Outlet Pressure	Meter	Red light on	
High Separator H <sub>2</sub> Outlet Pressure	Meter	Red light on	
High Deionizer Effluent Conductivity	Meter	Red light on	

**Note:**

- a) All circuitry communicates through electronic controller to be designed under Tasks 1.1.9 and 1.1.10.
- b) All automatic shutdowns simultaneously remove power to the module and the pump.
- c) Data recording is manual.






Figure 14. Instrumentation and Controller Unit

ORIGINAL PAGE IS  
OF POOR QUALITY

GENERAL  ELECTRICVoltage, VDCat 49.1 Amps, 230 mA/cm<sup>2</sup>

Date	Cell No.													Total Sum.	Total Term.
	1	2	3	4	5	6	7	8	9	10	11	12	13		
8/8/73	1.724	1.719	1.717	1.714	1.716	1.696	1.717	1.702	1.721	1.705	1.716	1.700	1.705	22.22	22.26

System operation was conducted on an unattended daily basis with minimum data logging and/or operator surveillance. Four hours after morning start-up on 8/9/73 with 18.8 cumulative hours of unattended operation, the system was found automatically shutdown with the "Low Module Current" light illuminated on the FDIA panel. Subsequent investigation revealed that a 10 micron, in-line pump filter (Circle Seal type P/N 43115-2XTN) was severely plugged with anion resin material. A previous failure of the anion resin (degraded into a fine powder) in the biological filter had caused plugging of hydrophilic tubes of the passive phase separator. At that time (5/1/73) the biological filter was removed from the system which was drained and flushed to remove this residual degraded resin. It was hypothesized that the in-line filter was plugged with fine resin material not previously flushed from the system.

After cleaning the in-line filter, a differential pressure transducer was installed in the system to monitor the pressure drop across the filter during WES operation. Also, the water reservoir facility was drained and fresh distilled water added.

While remaining in the breadboard test setup, the 13-cell electrolysis module was checked for possible damage. A cross-membrane, nitrogen permeability test revealed no leakage as evidence damage. A 1000 Hz impedance check did show Cell No. 5 was 0.00142 ohm or 47.6% higher than the average of the other 12 cells. The high cell impedance was attributed to water starvation and subsequent drying prior to emergency shutdown caused by the plugged water filter during WES operation. Attempts to restore the performance of Cell No. 5 with low current density operation ( $\sim 50$  mA/cm<sup>2</sup>) was not fruitful. Retesting of the module at design point conditions previously cited, revealed the following voltage performance at 49.1 amps (230 mA/cm<sup>2</sup>).



GENERAL  ELECTRICVoltage, VDCat 49.1 Amps, 230 mA/cm<sup>2</sup>

<u>Date</u>	<u>Cell No.</u>													<u>Total Sum.</u>	<u>Total Term.</u>
	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>	<u>6</u>	<u>7</u>	<u>8</u>	<u>9</u>	<u>10</u>	<u>11</u>	<u>12</u>	<u>13</u>		
8/14/73	1. 714	1. 709	1. 705	1. 716	1. 978*	1. 695	1. 711	1. 691	1. 710	1. 698	1. 711	1. 698	1. 704	22. 45	22. 50

\* Note that the voltage of Cell No. 5 is 0.273 volt higher at 230 mA/cm<sup>2</sup> than the average of the other twelve cells.

Loss of water supply to one or more cells of the electrolysis module results in drying of the SPE cell membrane and an increase in cell impedance. At a given load this results in a higher cell voltage. The power conditioner voltage/current control established an upper module voltage limit about 1.5 VDC below supply voltage of 28 VDC. Once this voltage limit was reached a further increase in cell or module impedance would reduce input current to the module. An automatic shutdown "low" limit of 5 amps was pre-set for WES operation. It was hypothesized that Cell No. 5 was more sensitive to the condition of low water supply, increased impedance and temperature at the sustained load of 5 amps sufficient to change the SPE water equilibrium such that normal water content impedance and performance could not be restored as in the other cells.

Corrective action was planned to include, for Phase II, the replacement of Cell No. 5 with a new cell when the 13-cell electrolysis module was disassembled, modified and reassembled for high pressure operation. Also, the "low current" shutdown for module protection would be changed to a "high voltage" shutdown condition in the event of water starvation or performance loss. The latter type of shutdown protection had been used successfully on laboratory cells and modules, but had been altered to the former for system incorporation to prevent inadvertent module shutdown at high initial current settings with a "cold" module.



SECTION 3.0 DEVELOPMENT OF AN ADVANCED WATER ELECTROLYSIS SYSTEM (WES) WITH COMBINATION WATER PUMP, PHASE SEPARATOR

3.1

Specification

A guideline specification for the design of a six-man rated, high pressure and temperature WES is outlined in Table III. The primary goals of the advanced WES were the development of an electrolysis system capable of operating at  $2758 \text{ kN/m}^2$  (400 psig) and incorporating a combination water pump/dynamic phase separator, and with an electrolysis module capable of operating up to  $366^\circ\text{K}$  ( $200^\circ\text{F}$ ), and  $350 \text{ ma/cm}^2$  (326 ASF).

3.2

System Description

The complete six-man rated, preprototype water electrolysis system is contained within two packages pictured in Figure 15. The control cabinet (53 x 53 x 66 cm) on the left contains operating controls, meter displays and fault detection and isolation lights. The fluid components and large electrical components of the system are contained in the package (91 x 91 x 61 cm) shown at the right. The electrical and fluid interface connections are located on the left face of this package and an electrical harness interconnects the two packages. A more complete description of these packages with component identification and location will be provided later. A list of the major components installed in the two packages of the system is provided in Table IV. These are identified by item number and shown in the system schematics in Figures 16 and 17. Fluid and electrical service interface connections are shown at the left side of Figure 16 with nominal maintained values in accordance with the guideline specification of Table III. A functional description of the system follows and the basic functional components described are identified by respective item numbers in parenthesis as referred to Table IV and Figures 16 and 17.

Power is delivered to the 13-cell electrolysis module (1) from a 28-VDC supply through a power conditioner (11) which acts as a current regulator for maintaining a selected gas production rate. The power conditioner which operates at about 92 percent efficiency, rejects waste heat to a cold plate through which externally supplied coolant is circulated.

Water is delivered to the hydrogen side of the electrolysis module at a controlled maximum temperature of  $339 \text{ K}$  ( $150^\circ\text{F}$ ) maintained by the temperature regulating valve (10). Some of this process water is dissociated into hydrogen and oxygen by electrolysis, whereas the excess amount is discharged with the hydrogen produced and carries off the module waste heat. Temperature rise of the process water through the module is proportional to the applied load which at 75 A produces a module outlet temperature of  $366 \text{ K}$  ( $200^\circ\text{F}$ ) at a water flow rate of 9 kg/hr (20 lb/hr). The two-phase mixture of hydrogen and water passes through the regenerative heat exchanger (12) to release heat to water delivered to the hot side of the temperature regulating valve. The two-phase mixture is further cooled to about room temperature



Table III

Guideline Specification for Breadboard Six-Man Rated  
Advanced Water Electrolysis System (WES)

(\*Revised 11/30/73)

WES Capacity

15 lb/day (6.8 kg/day) oxygen (nominal six-man rate);  
Equivalent 75 amp maximum oxygen generation;  
Continuous or cyclic orbital duty of 55 minutes "on" power and 39 minutes  
"off" power.

WES Gas PurityOxygen Generation - by volume

99.7% min. O<sub>2</sub>  
0.1% max. H<sub>2</sub>  
Remainder - not defined.

Hydrogen Generation - by volume

99.3% min. H<sub>2</sub>  
0.2% max. O<sub>2</sub>  
Remainder - not defined.

NASA-Maintained Downstream Gas Pressures of WES

Oxygen Subsystem: 14.7 psia (101.4 kN/m<sup>2</sup>) nominal  
Hydrogen Subsystem: 14.7 psia (101.4 kN/m<sup>2</sup>) nominal

Make-Up Water (Feed Water) Available to WES

Fluid: Industrial distilled water

Temperature 75± 5 F. (275 ± 2.8K)

\*Pressure: 2 to 10 psig. (13.8 to 68.9 kN/m<sup>2</sup>)

\*Water Purity

Microorganism species: Not defined.

Total dissolved solids: 5 ppm max.

\*Particulates:

Particulate Size Range	No. of Particles per 500 mi.
0 - 10 microns	Unlimited
10 - 25 microns	1000
25 - 50 microns	200
50 - 100 microns	10



**Table III (Cont'd)**

**Guideline Specification for Breadboard Six-Man Rated**

**Advanced Water Electrolysis System (WES)**

**(\*Revised 11/30/73)**

**Coolant Available to WES**

Fluid: "City" water.

Water Purity (i. e. ionic and microorganism species): Not defined.

Temperature:  $48 \pm 7$  F ( $289 \pm 3.9$  K).

Pressure: 75 psig ( $517$  kN/m<sup>2</sup>) max.

Flow: Up to 10 gpm (37.8 l/min).

**Nitrogen Available to WES**

Pressure: Selectable to 500 psig ( $3448$  k N/m<sup>2</sup>) maximum

**Electrical Services Available to WES**

$28 \pm 5\%$  VDC.

$115 \pm 5\%$  VAC, 60 Hz, single phase.

**Component Design Stress Considerations**

Proof Pressure: 1.5 times maximum operating pressure.

Burst Pressure: 2.5 times maximum operating pressure.






Figure 15. Six-Man Advanced Water Electrolysis System Control Cabinet and Fluid Package

ORIGINAL PAGE IS  
OF POOR QUALITY

Table IV  
Major Components List

6-Man Advanced Preprototype Water Electrolysis System (WES)

Fluid Package

Item No.	Component Title	Installed Quantity
1	Water Electrolysis Module	1
2	Check Valve	6
3	Make-Up Water Filter	1
4	Make-Up Water Pump	1
5	Coolant Water Filter	1
6	Separator/Pump Electronic Controller	1
7	Deionizer Resin Bed	1
8	Two-Phase Dynamic Separator/Pump	1
9	Cooling Water Flowmeter	1
10	Temperature Regulating Valve	1
11	Power Conditioner/Cold Plate Assembly	1
12	Regenerative Heat Exchanger	1
13	Primary Heat Exchanger	1
14	Absolute O <sub>2</sub> Back-Press. Regulator	1
15	Absolute H <sub>2</sub> Back-Press. Regulator	1
16	Water Accumulator	1
17	Pressure Transducer, 0 - 500 psig (0 - 3448 kN/m <sup>2</sup> )	5
18	Differential Press. Trans., ± 100 psid (± 689 kN/m <sup>2</sup> )	1
19	Pressure Switch	1
20	Differential Back Press. Regulator	1
21	Module Outlet Temperature Sensor	1
22	Combustible Gas Detector Sensing Probe	1
23	Dual O <sub>2</sub> and H <sub>2</sub> Flowmeter	1
24	Conductivity Sensor Probe	1
25	Coolant Flow Switch	1
26	In-Line Relief Valve	4
27	Manual N <sub>2</sub> Pressure Regulator	2
28	Manual Shut-Off Valve	7
29 *	Differential Pressure Test Gage, 0 - 30 psid (0 - 207 kN/m <sup>2</sup> )	2
30	Needle Valve	2
31	Flow Orifice	1
32	Catalytic O <sub>2</sub> /H <sub>2</sub> Mixture Sensor	2
33	Circuit Breaker, 80 amp	1
34 *	Differential Pressure Test Gage, 0-200 "WC (0 - 50 kN/m <sup>2</sup> )	1


\* Non-deliverable instrumentation for check out only



Table IV (Cont'd)Major Components List6-Man Advanced Preprototype Water Electrolysis System (WES)Control Cabinet

<u>Item No.</u>	<u>Component Title</u>	<u>Installed Quantity</u>
40	Module Terminal Voltage Meter, 0-50 VDC	1
41	Module Current Meter, 0 - 100 amp	1
42	Module Cell Voltage Meter	1
43	Module Cell Voltage Selector Switch, 13 Pos'n	1
44	Temperature Elec. Display Meter, 0 - 250°F	1
45	Temperature Sensor Selector Sw., 3 Pos'n	1
46	Combustible Gas Detector Controller/Meter	1
47	Conductivity Sensor Controller/Meter	1
48	Press. Trans. Elec. Display Meter, 0 - 500 psig	2
49	Accumulator Δ P Trans. Elec. Disp. Meter, ± 100 psid	1
50	Electric Display Meter, 0 - 5 VDC	2
51	Elec. Meter Selector Switch, 3 Pos'n	2
52	Elapsed Timer	1
53	Module Current Adjust, Potentiometer	1





NASA-JSC, HOUSTON

P - PRESSURE SWITCH REV C 1-27-75  
REV B 1-3-74

REVA 10-1-19

73A-190-86, B

A. C. ERICSSON

12 - 3 - 13

Figure 16.




Figure 17.

in the primary heat exchanger ( 13 ) where heat is rejected to the externally supplied coolant.

The H<sub>2</sub>/H<sub>2</sub>O mixture is delivered to the dynamic phase separator-pump ( 8 ) which provides separation of the gas and water. This device was developed by the Fluid Dynamics Corp., Chester, California, to provide positive separation of hydrogen and water in a zero gravity environment as well as pumping capability for the process water circuit. It is basically a centrifugal pump operating with a gas core of a diameter controlled by the operation of an internal pickup or sensor causing venting of hydrogen through an integral solenoid valve.

An ion exchange column, or deionizer ( 17 ), is located between the phase separator-pump and the electrolysis module to eliminate any system generated contaminants within the circulating process water loop and impurities from the makeup water feed. Hydrogen vented from the phase separator-pump through the differential pressure regulator ( 20 ) is further regulated at an absolute pressure by the hydrogen back pressure regulator ( 15 ) and is discharged from the system. The latter pressure regulator contains a spring adjustment capable of manual settings between 790 and 2860 kN/sq m (115 to 415 psia). The oxygen back pressure regulator ( 14 ) receiving the gas supply directly from the electrolysis module is a similar device which controls oxygen absolute pressure at a level set about 345 kN/sq m (50 psi) higher than hydrogen absolute pressure. This assures a positive pressure differential of oxygen greater than the two-phase mixture of hydrogen and water in the module such that no water is hydraulically transported to the oxygen side and eliminates entrained water in the oxygen discharged from the system.

A feed water makeup pump ( 4 ) and water accumulator ( 16 ) are also provided in the system. The latter contains a spring-loaded piston and rod-actuated position switch. As water is consumed by electrolysis, the piston travels to a position actuating the switch subsequently starting the makeup pump which is energized for two minutes adding water to the system from the supply at ambient or cabin pressure. The water accumulator also accommodates changes in the quantity of water contained in the process water loop due to system startup and load transients associated particularly with cyclic load operation which will be further discussed under "System Development and Test Results."

The nitrogen supply at 3550 kN/m<sup>2</sup> (515 psia) is utilized to pressurize the electrolysis module pressure vessel or domed enclosure subsequently discussed, and to maintain a regulated system base pressure under regulated hydrogen pressure. The oxygen and hydrogen sides of the system are initially pressurized with nitrogen to a base pressure of 234 kN/m<sup>2</sup> (340 psia) with a hand loading pressure regulator (27 - 2) through dual check valves ( 2-1, 2-2, 2-3, and 2-4 ). During automatic start up oxygen and hydrogen are generated and internal pressures built up until the O<sub>2</sub> and H<sub>2</sub> back pressure regulators discharge gas at their pre-set regulated settings. When the system is electrically deactivated at elevated pressure the nitrogen base



pressure serves as a "floor" to which internal pressures gradually decay and maintains a safe condition in the event of an automatic shutdown. The nitrogen also serves as an inert gas for purging the system during depressurization.

In addition to the aforementioned basic functional components, the schematic in Figure 16 also shows relief valves for overpressure protection and manual valves for venting, bypass, sampling, etc. Sensors for measurement of voltage, current, pressure, temperature, water conductivity, etc. provide output to display meters on the control panel as well as to the emergency controller with preset fault detection limits which activates an automatic safe system shutdown.

The packaged system was designed for automatic operation at any preset pressure level from 790 to 2860 kN/m<sup>2</sup> (115 to 415 psia). Operating controls include 0 to 75 amp load adjustment, mode selection switches for continuous, cyclic (simulated near-earth orbital conditions) or standby operation as well as override switches for independent makeup pump, phase separator-pump or power conditioner (including electrolysis module) operation. Control by manual valves permits operation at low pressures close to atmospheric pressure as well as allows "bootstrap" operation by self pressurization of both O<sub>2</sub> and H<sub>2</sub> sides under load to maximum operation pressure.

A frontal view of the control cabinet is shown in Figure 18. The rectangular meters display module current (with potentiometer for load adjustment) and terminal voltage, individual cell voltage with selector switch, module two-phase outlet temperature, O<sub>2</sub> in H<sub>2</sub> and H<sub>2</sub> in O<sub>2</sub>, temperatures sensing gas mixtures, accumulated hours and the following pressures: H<sub>2</sub> and O<sub>2</sub> regulated back pressures, accumulator piston Δp, two-phase (module), N<sub>2</sub> dome, N<sub>2</sub> base, phase separator-pump Δp, and water flow orifice Δp. The nine rectangular push buttons in a vertical line respective from top to bottom provide the following operating functions: Mode selection for (1) Continuous or (2) Cyclic operation, (3) Automatic start up (4) Standby operation (5) Shutdown and the override switches for independently energizing the (6) Contactor (7) Power Conditioner (including electrolysis module) (8) Phase separator-pump and (9) Makeup pump. The 24 small round lights in a vertical line identify which one of 22 fault detection sensor limit conditions was activated during an automatic shutdown. The fault conditions and sensor limits are listed in detail in Table X. To the left center of the control cabinet in Figure 18 is located a controller and meter for a combustible gas detector, Model 180, manufactured by General Monitors, Inc., Costa Mesa, California which detects external hydrogen leakage to ambient from piping and components in the fluid package. At the lower left corner of the control cabinet is the controller and meter, for a water conductivity sensor Model 915M-SC manufactured by Balsbaugh Laboratories, Inc., South Hingham, Massachusetts for monitoring the quality of process water.

Inside the control cabinet are located three circuit boards which contain the logic elements for automatically controlling sequential functions of start up,






Figure 18. Water Electrolysis System Control Cabinet, Front


shutdown, continuous, cyclic and standby system operation as well as the requirements for an automatic safe emergency shutdown. Also contained within the cabinet are eight adjustable potentiometers for each of the FDIA pressure limit conditions which permits pre-setting these limits for any selected system operating pressure between 790 and 2860 kN/m<sup>2</sup> (115 to 415 psia). Also inside is located an emergency shutdown bypass switch which allows low pressure system checkout below the established high pressure regulator and potentiometer limit settings.

A frontal view of the fluid package is provided in Figure 19. Locations of the major components are shown and denoted by item numbers identified in Table IV and Figure 16. The electrolysis module is shown with its thermal insulation removed.

A photograph of the rear view of the fluid package is given in Figure 20. The locations of many of the basic components identified in Table IV and Figure 16 are shown. Thermal insulation applied to those components operating at elevated temperature such as the temperature regulating valve, module outlet temperature sensor and associated lines has been removed. The primary and regenerative heat exchangers shown consist of off-the-shelf concentric tube dual heat transfer coils, P/N 3101-6, 4-8-6X, manufactured by Parker Hannifin, Cleveland, Ohio, which were foamed-in-place into insulating cylinders of polyurethane foam covered with aluminum foil.



**ORIGINAL PAGE IS  
OF POOR QUALITY**



**Figure 19.** Water Electrolysis System Fluid Package, Front View






figure 20. Water Electrolysis System Fluid Package, Rear View

ORIGINAL  
OF POOR QUALITY

## 3.3

Component Development

Available components from the low pressure, breadboard WES developed under Phase I were utilized wherever possible in the high pressure, advanced, preprototype WES. Also, standard commercial materials and components were selected where applicable to avoid unnecessary developmental costs and minimize procurement time. Specifications were prepared for definition and development of those components having operating requirements particular to the needs of the advanced WES system. A discussion of these components including specifications, drawings, and test results from bench checkout and/or system operation follows.


3.3.1 13-Cell, Advanced Electrolysis Module

A primary objective under Phase II of the program was to increase the capacity of the 13-cell, 4-man rated, low pressure module tested under Phase I to a six-man rated, high pressure, high temperature module design. Disassembly of the four-man rated module revealed that all cell parts exhibited no corrosion and were otherwise in a physically good condition. Twelve of the membrane and electrode assemblies were reusable whereas one required replacement because of high electrical impedance, attributed to water starvation during Phase I testing, to make up a 13-cell module. All of the cell screen assemblies and separator sheets were found reusable. A photograph of these cell components is shown in Figure 21. Two screen/gasket assemblies are required for each single cell to form the anode and cathode fluid compartments.

Laboratory compatibility tests were conducted with various gasket materials contacting the SPE membrane for 1400 hours at 361K (190°F) and  $2758 \text{ kN/m}^2$  (400 psi). Fluorosilicone rubber showed excellent resistance to acid attack as did silicone rubber faced with a thin film of teflon (TFE) on the side adjacent to the SPE membrane. Both were considered alternate approaches for the high temperature design with the former incorporated into a molded gasket configuration with dual peripheral beads on each face shown in Drawing 73D205854, Figure 22. Tie bolt holes in all cell components were enlarged from a 10-32 to a 5/16 - 24 screw size to accommodate the higher pressure capability. The basic cell design was otherwise unchanged to increase module operating performance from a Four-man to a Six-man capability (current density from 213 to  $350 \text{ MA/cm}^2$ ) resulting from attaining lower cell voltage and improved performance at higher operating temperature. Basic design parameters of the SPE electrolysis cell are listed in Table V.

The design approach to a high pressure module configuration was to enclose the compressed stack of 13 cells into a pressure vessel. A photograph of the module is shown in Figure 23.





Cell Compartment  
Separator Sheet

Cell Compartment  
Screen/Gasket Assy.

SPE Electrolyte  
with Electrodes

Figure 21. SPE Electrolysis Cell Components




Figure 22.

TABLE V  
13-CELL ADVANCED WATER ELECTROLYSIS MODULE  
SIGNIFICANT DESIGN DATA


<u>Cell Design Parameters</u>	<u>Design Point</u>
Electrode Diameter	16.5 cm (6.5 in.)
Active Area	214 cm <sup>2</sup> (33.2 in. <sup>2</sup> )
Ion Exchange Membrane	G. E. Spec: A50GN342
Anode (O <sub>2</sub> Side) Catalyst	E50, 12.5% Teflon
Cathode (H <sub>2</sub> Side) Catalyst	Pt Black, 12.5% Teflon
Cathode Catalyst Support	Expanded Gold Screen .076 mm (.003 in.) thick, 17.15 cm (6.75 in.) dia.
H <sub>2</sub> and O <sub>2</sub> Gas Gap Screening	5 Layers Expanded Screen 5 Nb 7, 3/0, Platinized and Welded Pressed to .56 mm (.022 in.) Thick
H <sub>2</sub> /O <sub>2</sub> Separator Sheet	.076 mm (.003 in.) Thick Niobium Platinized
Cell Gasket Seal	.69 mm (.025 in.) Thick TFE Faced or Fluorosilicone Rubber Unfilled
H <sub>2</sub> Cell Water Feed Port	.56 mm (.022") Thick Screen Gap x 6.4 mm (.25") Wide
H <sub>2</sub> and O <sub>2</sub> Cell Outlet Gas Ports	.56 mm (.022") Thick Screen Gap x 9.6 mm (.38") Wide
Manifold Gasket Seal	1.19 mm (.047") Thick Silicone or Fluorosilicone Rubber Unfilled
Pressure Pad	1.40 mm (.055") Thick, 16.5 cm (6.5 in.) Diameter Perforated G.E. Silicone Rubber SE-4404
Operating Mode	Cathode Water Feed
Maximum Current	75 amp
Maximum Current Density	350 mA/cm <sup>2</sup>
Maximum Outlet Temperature	367K (200°F)
Cell Voltage (at Maximum Current, Nominal Pressure and Temperature)	1.72 VDC
Nominal Cell Spacing (Including one pressure pad)	2.8 mm (0.110 in.)



TABLE V (Cont'd)  
13-CELL ADVANCED WATER ELECTROLYSIS MODULE  
SIGNIFICANT DESIGN DATA

<u>Module Design Parameters</u>	<u>Design Point</u>
Oxygen Generation Rate	6.8 kg/day (15 lb O <sub>2</sub> /day)
Min. Supply Voltage (Out of Power Conditioner)	23.5 VDC
Number of Modules in System	One
Number of Cells per Module	13
Maximum Cell Pressure	2861 kN/m <sup>2</sup> (415 psia)
Nominal/Maximum Cell or Gasket Pressure Differential	345/690 kN/m <sup>2</sup> (50/100 psid)
Maximum Dome Pressure	3206 kN/m <sup>2</sup> (465 psia)
Proof Pressure	4654 kN/m <sup>2</sup> (675 psig)
Top End Plate	23.2 cm (9.125") Dia x 1.9 cm (.75") thick, 7075-T651 Alum. with .15 mm (.006") thick epoxy coating
Internal Studs	Sixteen, 5/16" - 24 Type 316 S.S.
Belleville Washer Assy.	7 nests of 3 in parallel per Stud, P/N B0750-040-S Assoc. Spring Co.
Bottom Enclosure Plate	33.02 cm (13.00") Dia x 26.8 cm (1.055") Thick Type 316 S.S.
Domed Enclosure Head.	33.02 Cm (13.00") Dia. x 152 cm (6.0") Deep 6061-T651 Alum., Anodized.
Flange Bolts	Sixteen, 3/8" - 24 per MS9559-28
Total Assembled Weight	W/O Insulation 72.5 lbs.





13-Cell Advanced Electrolysis Module  
(With Pressure Dome Removed)

Figure 23.

ORIGINAL PAGE IS  
OF POOR QUALITY

# GENERAL ELECTRIC

The configuration consists of 13 cells with projecting terminal plates compressed with 16 tie bolts, spring-loaded with Belleville washers, between rigid end plates. A flanged elliptical dome is fastened to the larger bottom plate to enclose the stack assembly.

The photograph was taken before internal wiring was connected to the terminal plates and the cell voltage tabs. These tabs of .08 mm (.003") niobium were embossed with a diamond pattern to a thickness of (.16) mm (.006") and inserted between the separator sheet and manifold gasket into the pressure pad cavity of each cell. They provided a dual function of individual cell voltage measurement and gas breathing between the pressure vessel and pressure pad cavity thus preventing possible gasket blowout during rapid module depressurization. A layout of the module assembly is pictured in Figure 24. Module design parameters are listed in Table V.

The module pressure vessel is pressurized with nitrogen to approximately  $345 \text{ kN/m}^2$  (50 psid) greater than cell internal operating pressures to eliminate gasket blowout from high pressures while providing an inert gas blanket in the event of a module gasket failure. Cell gasket thermal expansion at high operating temperatures is accommodated by the stack of Belleville washers on the tie rods which permit axial displacement of the top end plate while maintaining axial load.

The advanced module was assembled initially with FEP film/silicone rubber (GE Compound SE - 4404 unfilled) gaskets since delivery of the molded gaskets was later. With the domed enclosure head removed the 13-cell stack assembly was proof pressure tested at  $690 \text{ kN/m}^2$  (100 psi) internal pressure and cross membrane gas diffusion at  $345 \text{ kN/m}^2$  (50 psid) was measured within acceptable permeability limits.

The aluminum dome was satisfactorily proof pressure tested at  $4827 \text{ kN/m}^2$  (700 psig) using a special stainless steel test plate and filling the dome with water prior to pressurization for safety. The electrolysis module was then completely assembled with the dome and leak checked. With the dome pressurized with nitrogen at  $345 \text{ kN/m}^2$  (50 psig) leakage to the oxygen and hydrogen cell cavities at atmospheric pressure was measured respectively as zero and 13.2 standard cc/hour. Calculated dome-free volume from a pressure decay test was 4320 cc. Electric checkout for shorts and cell impedance measurements were found satisfactory.

Operational checkout of the electrolysis module coincided with initial low pressure checkout of the system on June 4, 1974. All cells performed satisfactorily. Module performance, at a nominal operating pressure of  $690 \text{ kN/m}^2$  (100 psig), exhibited during warmup at varied load settings is shown in Figure 25 on June 13, 1974. Over a 429 hour endurance test period at a nominal system pressure of  $690 \text{ kN/m}^2$  (100 psig) module performance was very stable.






Figure 24.




Figure 25. WES Test Run On June 13, 1974



Tabulated below are the individual cell voltages which were recorded after one and seven days, respectively, of continuous unattended system operation at 75 amps ( $350 \text{ mA/cm}^2$ ),  $827 \text{ kN/m}^2$  (120 psig)  $\text{O}_2$ ,  $655 \text{ kN/m}^2$  (95 psig)  $\text{H}_2/\text{H}_2\text{O}$  pressures,  $339 \text{ k}$  ( $150^\circ\text{F}$ )  $\text{H}_2\text{O}$  inlet and  $361 \text{ k}$  ( $190^\circ\text{F}$ )  $\text{H}_2/\text{H}_2\text{O}$  outlet temperatures at the module.

<u>Date</u>	<u>Voltage, VDC</u>													<u>Total Sum</u>													
	<u>at 75 Amp, <math>350 \text{ mA/cm}^2</math></u>																										
	<u>Cell Number</u>																										
6-20-74	1.734	1	1.730	2	1.711	3	1.717	4	1.716	5	1.710	6	1.694	7	1.714	8	1.710	9	1.694	10	1.712	11	1.698	12	1.795	13	22.34
6-27-74	1.751	1.730	1.730	1.714	1.716	1.699	1.719	1.716	1.697	1.716	1.712	1.692	1.796	1.716	1.710	1.697	1.719	1.716	1.694	1.795	1.795	22.40					

The change in module temperatures and voltage during reductions in load following the endurance test period is plotted in Figure 26.

The end cells, Nos. 1 and 13 exhibit higher voltages because the measurement, as wired, includes IR drop across the terminal plates.

Following system endurance testing at  $690 \text{ kN/m}^2$  (100 psig) and prior to initial testing at  $1724 \text{ kN/m}^2$  (250 psig), a nitrogen dome leakage check disclosed leakage from a Conax gland sealing module cell voltage lead wires through the end plate. This teflon gland seal becomes hot  $\sim 339 \text{ k}$  ( $150^\circ\text{F}$ ) during module operation and evidently some permanent set and contraction allowed leakage at room temperature. Upon commencement of module tests at  $1724 \text{ kN/m}^2$  (250 psig) it was discovered that cell voltage readout on cell numbers 12 and 13 was not possible although module operation and total voltage was otherwise normal. The common voltage tab between cells 12 and 13 was evidently loosened or pulled out when the nut and gland was rotated to effect a seal on the lead wires.

Measurements of module temperature and voltage over a load profile from 20 to 75 amperes at a nominal operating pressure of  $1724 \text{ kN/m}^2$  (250 psig) are plotted in Figure 27.

Coincident with this test run at a module current of 75 amps ( $350 \text{ mA/cm}^2$ ) the following cell voltages were recorded.






Figure 26. WES Unattended Endurance Test Steady State Load/Temperature Evaluation




Figure 27. WES Test Run on August 20, 1974



Voltage, VDC

at 75 Amps,  $350 \text{ mA/cm}^2$ 

Cell No

1	2	3	4	5	6	7	8	9	10	11	12	13	Termi-	nal
1.734	1.710	1.697	1.696	1.688	1.684	1.680	1.691	1.692	1.673	1.679	*	*	22.4	

\* No cell voltage measurement capability on

Cell numbers 12 and 13

Module performance at design point conditions of 75 amp ( $350 \text{ mA/cm}^2$ ) load,  $2860 \text{ kN/m}^2$  (415 psia) nominal pressure and  $367 \text{ K}$  ( $200^\circ\text{F}$ ) outlet temperature was satisfactorily demonstrated by the following operating conditions on 11-7-74.

TABLE VI

<u>Measured Parameter</u>	<u>Operation Value</u>
Module Current, Amp	75
Module Current Density	$350 \text{ mA/cm}^2$ (325 ASF)
Module Terminal Voltage, VDC	22.4
Module Dome N <sub>2</sub> Pressure	$2965 \text{ kN/m}^2$ (430 psig)
Regulated O <sub>2</sub> Pressure	$2772 \text{ kN/m}^2$ (402 psig)
Module H <sub>2</sub> /H <sub>2</sub> O Outlet Pressure	$2578 \text{ kN/m}^2$ (374 psig)
Regulated H <sub>2</sub> Pressure	$2482 \text{ kN/m}^2$ (360 psig)
Regulated N <sub>2</sub> Base Pressure	$2275 \text{ kN/m}^2$ (330 psig)
Phase Separator - Pump $\Delta$ P	$53.8 \text{ kN/m}^2$ (7.8 psig)
Mean Process Water Flow Rate	8.07 kg/hr. (17.8 PPH)
Regulated Module Water Inlet Temp.	$339 \text{ k}$ ( $151^\circ\text{F}$ )
Module H <sub>2</sub> /H <sub>2</sub> O Outlet Temp.	$372 \text{ k}$ ( $210^\circ\text{F}$ )
Module Dome Skin Temp.	$350 \text{ k}$ ( $170^\circ\text{F}$ )
Module End Plate Skin Temp.	$347 \text{ k}$ ( $165^\circ\text{F}$ )



Voltage, VDC  
at 75 amp, 350 mA/cm<sup>2</sup>

## Cell No

1	2	3	4	5	6	7	8	9	10	11	12	13	Termi- nal
1.734	1.717	1.708	1.714	1.695	1.693	1.691	1.714	1.699	1.678	1.691	*	*	22.4

\* No cell voltage measurement capability on

Cell numbers 12 and 13

Because of reduced pumping  $\Delta P$  of the phase separator-pump at high system operating pressure which reduced process water flow rate and increased module outlet temperatures, module operating loads greater than 50 amperes (233 mA/cm<sup>2</sup>) could not be sustained for periods of time exceeding six hours.

After 550 hours of module operation which included high pressure and high temperature operation, the assembly was rechecked for internal leakage with nitrogen. At 345 kN/m<sup>2</sup> (50 psid) pressure differential, N<sub>2</sub> dome to O<sub>2</sub> side and N<sub>2</sub> dome to H<sub>2</sub> side leakage rates were measured 3.13 SCCM and 3.81 SCCM respectively. Cross membrane cell diffusion of nitrogen at 345kN/m<sup>2</sup> (50 psid) O<sub>2</sub> to H<sub>2</sub> side was measured at 8.3 SCC/hr/cell which was under the 10 SCC/hr/cell allowable diffusion for new cells. Nitrogen leakage from the dome to the cell prevented locking in nitrogen pressure during unattended operation and was attributable to difficulty in sealing the manifold port locations which was experienced during assembly. The O<sub>2</sub> to H<sub>2</sub> side sealing capability was effective in the cells so testing was contained without servicing the module.

The performance characteristics of the 13-cell electrolysis module at these pressures (shown by the relationship of cell voltage, current and operating temperature), are shown in Figure 28. These data are taken from mapping and parametric testing of the system over a period of time rather than from a single run evidenced by Table VI. Lines of constant current or cell current density are drawn which show the linear decrease in cell voltage as the module H<sub>2</sub>/H<sub>2</sub>O outlet temperature would increase during a warm-up period at constant load settings.

Satisfactory electrolysis module performance was also demonstrated during the orbital cyclic mode of WES operation. Because of parasitic losses caused by gas diffusion through the SPE cell at high temperature and pressure, a load of 5 amps or greater is required to sustain a net gas production such that the O<sub>2</sub> and H<sub>2</sub> back pressure regulators maintain system pressures. During a period of seven days or 170 hours of continuous unattended system operation in the automatic cyclic mode, the module was cycled between loads of 6 and 20, 30, 40 and 50 amperes. A recorded trace of module terminal voltage over an 11 hour period on 1-28-75 is provided in Figure 29. Maximum voltage occurs immediately after the 40 amp load is







Figure 28. 13-cell Electrolysis Module Performance Characteristics





Test Date: 1/28/75  
0300 to 1400 Hours

Figure 29. Electrolysis Module Terminal Voltage During Cyclic (Orbital)  
Operating Mode: 54.7 Min High Power at 40 Amp  
40.7 Min Standby Power at 6 Amp

instantaneously applied and decays slightly during the warm up period at high load. Minimum voltage occurs immediately after the load change from 40 to 6 amps and increases very slightly as some cooling of the module occurs at the low standby load.

After an accumulated gas generation time of over 1040 hours on the module as part of advanced WES testing, it was removed from the system to be disassembled for inspection and installation of molded fluorosilicone gaskets in place of the FEP film/silicone gaskets as initially assembled. In addition to the new gasket configuration, the electrolysis module will be reassembled with seven, instead of thirteen, cells reflecting the three-man oxygen generation requirement of a WES Test Demonstration Unit for the Life Sciences Payload Program under Contract No. NAS 9-14205. The advanced breadboard system will serve as a test bed to evaluate performance and endurance of the new module configuration as well as other components incorporating modifications for the Test Demonstration Unit.



## 3.3.2

Power Conditioner

The 75 amp power conditioner was developed on previous Contract NAS 1-9750 and adapted for use on this system. The unit is of open construction (Figure 30) with water cooling of the main power handling components. The output is directly coupled to the electrolysis module and the output can be controlled from a remote potentiometer to give from 0 to 75 amps to the module.

The power conditioner circuitry is shown schematically in Figure 31. It is basically a step-down, time-ratio-control current regulator.

The power circuit is a conventional transistor controlled switch using two parallel transformer coupled transistors. Transformer drive is obtained with a two transistor Darlington drive configuration operating directly from TTL logic gates (S/N 7400N). Pulse width control of the fixed repetition rate modulator is obtained by dynamically varying the time constants of the monostable pulse generator S/N 74122N over the range of from < 5 microseconds to the maximum width of one half of the 330 microsecond period. The two modulating circuits acting alternately as controlled by flip flop S/N 7474, will then provide a continuous drive to the power transistors and a resulting continuous conduction characteristic of voltage limited operation.

The control amplifier (741) is basically an integrating amplifier responding to the error signal difference between the shunt signal and the reference set by the current control of the control panel.

The fixed pulse repetition rate is provided by a unijunction pulse generator which is amplified with a transistor and a logic gate.

The unit is normally controlled by biasing the reference circuit to where it calls for less than zero current. This enables the unit to start-up and shut-down very smoothly at any current setting.

One of the drawbacks of adapting this power conditioner from a previous contract was the floating negative module bus. Direct overvoltage shutdown protection divider circuitry was found to be overly sensitive to operating transients causing erratic shutdowns. Replacement with a meter relay which did not require the negative common reformer eliminated this problem. The same result could have been accomplished by using PNP switching transistors and a common negative bus, however, it did not seem practical to redesign and rebuild the power conditioner just to overcome this limitation when a meter relay was available and worked very satisfactorily.







Figure 30. 75 Amp Power Conditioner

ORIGINAL PAGE IS  
OF POOR QUALITY

ORIGINAL PAGE IS  
OF POOR QUALITY



**Figure 31.** Power Conditioner Schematic

3.3.3

Dynamic Phase Separator-Pump

Important to the design of an advanced, high pressure water electrolysis system utilizing a cathode feed SPE module design, was the need for reliable H<sub>2</sub>/H<sub>2</sub>O phase separation and process water circulation essentially insensitive to system operating pressure and its possible variations with operation conditions in a 1 g or zero gravity environment. Experience in low pressure electrolysis systems with passive means of phase separation and available pumps had shown the vulnerability of these devices to system pressure changes resulting in loss of positive separation and/or pump cavitation. A successful centrifugal phase separation device had been developed by the Fluid Dynamics Corporation, Chester, California. An advanced design for the high pressure WES application required increased pumping pressure differential, higher gas volume rates and high line pressure capability. Analyses were made from WES component test data in Phase I to predict H<sub>2</sub>/H<sub>2</sub>O separation and process water flow requirements to define a specification for a combined phase separator-pump. This specification, No. 73A49-828, is included in the appendix.

An outline drawing of the phase separator-pump developed by Fluid Dynamics Corporation under Phase II of this program is provided in Figure 32.

The phase separator-pump assembly consists of a single phase, 115VAC, 60 Hz synchronous motor, permanent magnet drive coupling, pump impeller, speed-sensing pickup impeller, H<sub>2</sub> outlet solenoid valve, overboard relief valve and accompanying electronic control. The permanent magnet on the motor armature engages and spins a concentric magnet sealed inside and attached to the pump impeller thus avoiding a shaft seal. Protruding radial vanes on the pump impeller cause the liquid in the separator spin chamber to form a rotating hollow cylinder which creates a separating force in excess of 200 g's on the incoming fluid. The lighter fluid of a two phase mixture, consisting in this case, hydrogen and water, is separated by moving to the center or core of the spin chamber. The heavier fluid is drawn into the centrifugal pump impeller and is discharged into a chamber connected to the water outlet port.

As a mixture of hydrogen (saturated with water vapor) and water is delivered to the separator, the gas and vapor will be forced to the center core while the liquid will be discharged out of the pump section.

As more gas is separated the center core grows in size and must be vented to allow the separating action to continue. A secondary, or sensor, impeller is mounted in such a way as to face the driving impeller and the rotating mass of liquid causes this impeller to rotate with the fluid. Since the diameter of the sensor impeller is smaller than the spin chamber, the rotating liquid moves out of contact with sensor impeller blades as the gas core grows in size. The sensor impeller, through various components, activates a logic circuit which determines a rotating or non-rotating signal. A non-rotating signal causes the logic circuit to open a solenoid valve allowing the gas in the core to be vented. Since the separator is operated at a pressure higher than the






Figure 32.

discharge point, gas is forced out of the separator. This causes the gas core to shrink, and the spinning liquid engages the sensor impeller causing the logic circuit to close the solenoid valve. More gas enters, is separated, the gas core grows until the sensor impeller slows, the vent valve is opened, the core shrinks, the sensor impeller rotates, and the valve closes. Cycling of the solenoid valve is continuous with a steady input of gas increasing in frequency to about ten cycles per minute at maximum volumetric hydrogen generation rate whereas water flow rate is determined by  $H_2O$  outlet minus  $2 \Phi$  inlet  $\Delta P$  and the flow impedance of the recirculation loop.

The phase separator/pump and its electronic control box was bench tested at low pressure using a seven-cell electrolysis stack as a source of two-phase  $H_2/H_2O$  flow. Operation was found satisfactory except that measured pump pressure rise was  $63.4 \text{ kN/m}^2$  (9.2 psid) instead of  $69 \text{ kN/m}^2$  (10.0 psid) as specified and  $71.7 \text{ kN/m}^2$  (10.4 psid) as obtained by Fluid Dynamics Corporation (see Figure 33) at low system pressure. A subsequent proof pressure test showed excessive leakage at the bolted flange or end plate which attaches the solenoid valve and relief valve to the separator/pump housing. Recommendation by Fluid Dynamics Corporation was made to reduce a  $0.4 \text{ mm}$  (.016" shim) to about  $.30 \text{ mm}$  (.012 inch) thickness to increase the compression on two O-ring face seals. This was accomplished and the separator/pump assembly successfully passed a proof pressure test of  $3840 \text{ kN/m}^2$  (557 psig) without evidence of external leakage. Subsequent bench testing to re-evaluate separator/pump operation showed an increase of pump differential to  $71.7 \text{ kN/m}^2$  (10.4 psid) probably due to reduced internal running clearance. The setting of the built-in relief valve was increased from  $124$  to  $138 \text{ kN/m}^2$  (18-20 psid) to  $290 \text{ kN/m}^2$  (42 psid) cracking pressure,  $207 \text{ kN/m}^2$  (30 psid) reseat pressure.

Performance of the phase separator/pump was satisfactory over a 429 hour test period which included system checkout at low pressure and continuous operation for over 300 hours at a phase separator/pump inlet pressure of  $655 \text{ kN/m}^2$  (95 psig) and an  $H_2O$  out minus  $2 \Phi$  inlet  $\Delta P$  of  $64.8 \text{ kN/m}^2$  (9.4 psid). When system pressures were adjusted for operation at a nominal level of 250 psig, phase separator/pump operation was found to have dropped to under  $41 \text{ kN/m}^2$  (6.0 psid) thereby reducing process water flow rate. With the concurrence of Fluid Dynamics Corporation, the manufacturer, it was decided to obtain system performance data at maximum system pressure of  $2860 \text{ kN/m}^2$  (415 psia) before returning the separator/pump for vendors examination and correction. At this pressure level decoupling of the magnetic drive sometimes occurred as well as leakage of the solenoid valve and integral relief valve. Removal and inspection of the solenoid valve revealed from wear-marks that the open coil of the return spring evidently snagged in the longitudinal groove of the plunger thus preventing its return and proper seating. Correction was accomplished by reversing the coil spring such that the open coil faced the shoulder on the plunger. An improper O-ring seal was found in the relief valve which was corrected by removing the spring and inserting a  $1/4$  inch tube spacer. This, however, left the relief valve non-functional, but was not considered necessary for WES safe operation. It was also learned that normal pumping  $\Delta P$  was restored at low pressures. The unit was removed from the system and sent to Fluid Dynamics Corporation on 9-11-74 for high pressure evaluation and corrective modifications as necessary.






Figure 33. Liquid Flow as Measured Against Pressure Rise Across Vortex Separator

As evaluated by the vendor, loss of pumping pressure differential at high operating pressure was attributed to excessive thrust bearing friction causing loss of motor speed and at times decoupling of the magnet drive to the pump element. The thrust bearing was altered to include improved relative slip between a glass-filled teflon thrust washer and a stainless steel ring inserted in the impeller. Recommendations by Fluid Dynamics Corporation for a more improved redesign, not possible within the configuration of the current unit, would include substitution of graphite for teflon for further reduction of friction and increasing the torque capacity of the magnet drive from 22 to 35-inch-ounces. To prevent magnet uncoupling on the present unit the motor speed was reduced slightly at high torque with the change of a capacitor in its circuit to increase motor slip.

Phase separator/pump operation was satisfactory when re-installed in the system, although it did exhibit some sensitivity to system pressure by a  $\Delta P$  reduction from about 9.5 to 8.0 psid between respective operating pressures of about  $138\text{kN/m}^2$  (20 psig) and  $2480\text{kN/m}^2$  (360 psig). Two occurrences of component malfunction during system evaluation resulted ultimately in a bearing seizure of the separator/pump which required additional repair. During system depressurization and drainage of the process water loop without the separator/pump operating, reversal of water flow through the deionizer caused dislodging of resin beads into the separator/pump water discharge line (which was subsequently flushed) and some inadvertently into the impeller cavity. During unattended system operation a broken solder joint on a water accumulator switch prevented makeup water addition to the process water circuit. This ultimately resulted in fault shutdown of "low" separator/pump  $\Delta P$  equal to  $24\text{kN/m}^2$  (3.5 psid). The low  $\Delta P$  resulted from an enlarged gas core which reduced water lubrication of the impeller thrust bearing, and some deionizer resin particles had settled in the .010 inch clearance between the thrust bearing and impeller, thus interfering with rotation. Normally, the pump could handle this foreign material as a centrifugal pump with adequate water flow. However, with reduced water flow rate the gas core enlarged in diameter and exposed dry regions of the thrust bearing which eventually picked up the resin particles and bound up. New bearings were fabricated and the separator assembly was bench tested at low and high pressure by Fluid Dynamics Corporation.

The repaired phase separator/pump was re-installed in the system on 12-3-74. Subsequent system evaluation revealed at the nominal operating pressure of  $2413\text{kN/m}^2$  (350 psig) that pressure rise across the circulating pump element was  $51.7\text{kN/m}^2$  (7.5 psid) as opposed to  $69\text{kN/m}^2$  (10 psid) measured by a vendor bench test. The difference was later attributed to possible deflection of the pump housing at elevated pressure which increased the impeller clearance and reduced pump performance.

Because a few drops of water had been observed in the glass tube hydrogen flowmeter, a translucent 1/4" diameter nylon line was installed at the hydrogen outlet of the phase separator. During system operating conditions with a full water accumulator, a pressure differential of about  $159\text{kN/m}^2$  (23 psid) can exist across the



closed solenoid valve. Water slugs up to 2.5 cm long were periodically observed discharged with the hydrogen when the solenoid valve was opened. Apparently, the surge of hydrogen from the gas core at high differential allowed some carry-over of water to the outlet. This condition was corrected later in the program by an internal modification which prevented the sensing impeller from picking up water/gas interface during venting at high differential pressure.

On 12-31-74, the system was automatically shutdown caused by a "high" two-phase pressure fault condition resulting from a failed bellows in the hydrogen back pressure regulator. The poppet of this component continuously cycles between an open and almost closed position as the solenoid valve on the phase separator is energized cyclically. The frequency, dependent upon gas generation rate, was about 10 cycles per minute at 30 amperes. It was estimated that 400,000 cycles were accumulated to this failure point with a WES accumulated gas generation time of 629 hours. Subsequently the system was installed with a repaired hydrogen back pressure regulator and an electrical counter which was energized simultaneously with the solenoid valve on the phase separator/pump.

As reported in Para. 3.4.3 a differential H<sub>2</sub> back pressure regulator was added downstream of the separator solenoid valve with a reference to separator/pump H<sub>2</sub>O outlet pressure. This device has reduced the continuous cyclic operation of the solenoid valve and no water discharge was evidenced in the translucent H<sub>2</sub> outlet line. During an extended period of over 200 hours of system operation the pressure rise of phase separator/pump gradually diminished from 7.6 to about 6.0 psid which required readjustment of the differential pressure regulator to "hold" the solenoid valve open.

On February 10, 1975, the phase separator was removed from the system and disassembled. Inspection of the pump revealed that the teflon washer shim between the impeller and housing had been worn and frayed. This was replaced with a .13 mm (.005") thick niobium metallic washer. The separator/pump was then reassembled and bench tested with a pressurized water reservoir up to 2413kN/m<sup>2</sup> (350 psig) and with circulated water flow (without two-phase input capability). A pump ΔP of about 62kN/m<sup>2</sup> (9.0 psid) was measured in this set up. After re-installation of the separator and subsequent operation in the system at design pressure for a few hours its measured ΔP changed to about 51.7kN/m<sup>2</sup> (7.5 psid).

Additional system tests were conducted to determine the variance of phase separator/pump ΔP with low and high pressure operation with solid water or two-phase flow separation, etc. Provision was made with a "tee" inserted in the two-phase line at the separator/pump inlet to inject nitrogen gas. Gas injection at this point took the form of small bubbles swept by the continuous water stream; whereas, electrolysis operation usually results in alternate cylindrical bubbles and water slugs. The "tee" was, therefore, relocated to the two-phase inlet of the primary heat exchanger. In passing through about 6.1 meters (20 feet) of 1/4 inch diameter tubing of the heat



exchanger as well as working against a 25 to 38 cm (10 to 15 inch) water column, a more slug-like flow was established. A differential gage was also installed to measure separator  $\Delta p$ , i. e., ( $H_2O$  OUT minus 2 Q IN). Separator pressure differential was measured under a variety of conditions, i. e., 103 to 2413 kN/m<sup>2</sup> (15 to 350 psig) 0 to high injection rates of N<sub>2</sub> or H<sub>2</sub> gas as well as with electrolysis module generation. At low pressure a differential of 59 to 62kN/m<sup>2</sup> pf (8.5 to 9.0 psid) was usually experienced which fell off to 51.7 to 55kN/m<sup>2</sup> (7.5 to 8.0 psid) at design operating pressure of 2413kN/m<sup>2</sup> (350 psig). This change was sometimes erratic and sudden, however, particularly at high pressure or by stopping and restarting. Although a  $\Delta p$  of 51.7kN/m<sup>2</sup> (7.5 psid) was normally realized at 2413kN/m<sup>2</sup> (6.5 psid). Two phase operation of 12 hours or more resulted in a reduction to about 45kN/m<sup>2</sup> (6.5 psid). The phase separator/pump was not disassembled or removed from the system installation to further ascertain the cause; but, as previously hypothesized these variations were probably due to changes in internal impeller clearance causing variation in internal leakage which affects pump performance.

Operation of the phase separator/pump with the differential pressure regulator, whereby the solenoid valve is maintained continuously open, usually results in generation of a repeating pulse or dip in pump  $\Delta P$  lasting one to two seconds. Periods of steady operation may be up to an hour, but once triggered by a load change, operation of the makeup pump or some flow transient, the pulse is sustained at a frequency of usually two to seven times per minute. During this pulse the pump  $\Delta P$  drops from a normal 48 to 50kN/m<sup>2</sup> (7 to 8 psid) to about 34kN/m<sup>2</sup> (5 psid) and then returns to the higher value. A change in water flow coincides with the change in  $\Delta P$  and motor speed increases sharply as  $\Delta P$  is reduced by a larger core diameter. Because the operation of the phase separator pump, differential pressure regulator and water accumulator are inter-related, the exact cause was not apparent. By isolating the water accumulator and differential pressure regulator with valves and by elimination of water in the H<sub>2</sub> discharge with a trap, the causes of possible instability could be determined. It was found that pulses could occur when the solenoid valve was powered open, even with the differential regulator and water accumulator ineffective in the fluid circuit by valving. It appears that the core diameter may be oscillating slightly (noted by slight  $\Delta P$  oscillations) which becomes unstable probably due to a speed increase as the core diameter grows and the motor becomes unloaded (possibly aggravated by the built-in slip condition). At low pump  $\Delta P$  a churning sound is heard for about one second and then the motor speed is reduced and high  $\Delta P$  is restored as the core collapses. Pulsations have been observed during system operation at low and high pressures and at low and high loads. Observations were also noted during a shutdown condition with the phase separator/pump "on" when the two-phase loop was being drained. That is, pulsations could occur when the solenoid valve was powered open, as caused by a partially drained separator with an enlarged core. Although disconcerting, the pulsations noted are less frequent and no more detrimental to system components than those oscillations caused by a constantly cycling solenoid valve. Further phase separator testing and development should investigate whether pulsations are prevented by a synchronous speed or whether the vortex region or the pump impeller should be modified with baffles to retard free-surface oscillations of the core.



In summary, the technical difficulties experienced with the development of the dynamic phase separator/pump were primarily related to the undersize torque rating of the magnetic coupling which required the reduction in motor speed to prevent decoupling. The modified speed-torque characteristic resulted in a speed and  $\Delta P$  output sensitivity to impeller torque variations with clearance and bearing friction. Positive aspects of the component development were that the unit provided effective H<sub>2</sub>/H<sub>2</sub>O separation over the wide range of system operating pressures and gas production rates and was proven functionally compatible with the automatic start, stop and cyclic operating requirements of the system. Centrifical separation with a hollow core and with gas venting capability completely eliminated pump cavitation problems and no gas was ever entrained in the water discharge. For this reason, the phase separator was operated continuously during system depressurization to effectively separate and handle H<sub>2</sub> outgassing of process water in the two-phase loop as pressures were reduced.



3.3.4

Water Accumulator

The water accumulator provides the dual function of accomodating the changes in the quantity of water in the two-phase region of the process water loop due to sudden changes in load or hydrogen generation rate, and, it also provides the sensing means for adding makeup water periodically as it is consumed by the electrolysis module. Bench tests with a seven-cell electrolysis stack verified the changes in water "held up" in the hydrogen cavity of the cells at various applied loads. Also, the quantity of water contained as cylindrical slugs with two-phase flow in fluid lines depended on rates and the volume ratio of gas and liquid. Anticipated volumes of fluid components handling two-phase flow were calculated with the electrolysis module, primary and regenerative heat exchangers making up the largest portion of total volume for sizing the water accumulator.

Requirements for the design of a water accumulator meeting the volume displacement requirements and the switching logic for makeup water addition are provided in Spec. No. 73A490-862 contained in the appendix. Commercially available accumulators or hydraulic cylinders could not be modified to meet these requirements primarily because materials used were not suitable for water service. Response to quotations were received from four vendors but cost and delivery in all cases were beyond program plans.

The design of the water accumulator specially made for the WES requirements is shown in cross section on Drawing No. 73A490-873 in Figure 34. It consists of a customary hydraulic actuator design with piston, rod, return spring, hollow cylinder and square end plates sealed with O rings and secured with four tie rods. The piston design shown was for incorporating TFE coated "Quad" rings. An alternate split-piston design suitable for chevron-type teflon seal rings was also fabricated. The cylinder bore and piston rod were honed to an 8 RMS finish to minimize friction. All metal parts are made from 300 series stainless steel. The water storage capacity of the unit is 261 cc consistent with a full stroke of 7.62 cm (3 inches). A .635 cm (.25 inch) square by 2.54 cm (1.00 inch) long magnet is contained in the end of the piston rod, which actuates proximity switches, fastened to the surrounding bracket, at zero and full stroke positions. The number of internal washers (one inch diameter bolt size) located on the tubular piston stop can be varied to adjust spring force for various operating pressures.

Bench tests were performed on the accumulator to evaluate both piston seal designs and to set pre-load on the return spring. The teflon seal, of a chevron-type having a captured expansion spring, demonstrated lower friction but allowed a small amount of water leakage ( $H_2O$  to  $H_2$  outlet) which was considered unsatisfactory. The TFE coated "Quad" ring exhibited a 20.6 to 34.5 kN/m<sup>2</sup> (3 to 5 psid) pressure differential due to friction, but maintained a leak-proof seal. The piston was assembled with only one ring to limit friction. Typical accumulator performance during a bench test is shown in Figure 35 with the hydrogen side of the piston at atmospheric pressure. At elevated system  $H_2$  pressure, the piston pressure differential






Figure 34.

WATER ACCUMULATOR LAYOUT

DWG NO 75A490-073

ACERICKSON 2-27-74




Figure 35. Water Accumulator Bench Test

(H<sub>2</sub>O - H<sub>2</sub>) increases because of the imbalance caused by the piston rod area.

Accumulator performance during the extended period of system operation exhibited a minimum of difficulty. On one occasion the WES was automatically shut down due to a broken solder joint on the "empty" position switch. After over 550 hours of WES operation the water accumulator was observed to stick near the "empty" position. The component was disassembled and the teflon coating on the "Quad" ring seals was observed to be worn off and deposited on the cylinder wall near the "empty" position where most of the cyclic stroking occurs (from phase separator solenoid valve cycling). The seals were replaced and Dow Corning silicone grease and "Apiezon" pure hydrocarbon grease were evaluated as lubricants. The latter gave smoother stroking results so was used in the assembly.

The function of the accumulator was evaluated during load and pressure transients as well as during the cyclic mode of WES operation. During system operation at high load the high-volume components of the two-phase loop (primarily the electrolysis module and two heat exchangers) are filled with a mixture of hydrogen and water having a greater portion of hydrogen. At a low gas production rate in the standby mode the mixture changes to mostly water in these components. The difference in the quantity of water in the two-phase loop caused by load change must be accommodated by the water accumulator. Parametric tests of cyclic operation were conducted between a standby current of 6 amperes and selected currents of 20, 30, 50, and 75 amperes which provide the data in Figure 36. As current is changed from low load to high load, water is added to the accumulator from the two-phase loop. At load reductions water is removed from the water accumulator by the return spring in the piston. At maximum load differential, piston displacement approximates 3.8 cm (1.5 inch). To accommodate this displacement it was necessary to relocate the "empty" switch of the water accumulator to the center position of the 7.62 cm (3.00 inch) maximum stroke. This was done with the addition of a button-actuated switch which was actuated by the piston rod for any stroke position between 0 and 3.70 cm (0-1.46 inch); refer Figure 35. From this position, maintained by water addition from the makeup pump, the water accumulator will tend to fill with water for a load increase or almost empty to the zero stroke position for a large load reduction. In the latter case, the makeup pump is on for about eight minutes during the standby period to return the piston to the mid-position. It was therefore necessary to increase the ESD delay time for an "empty" water accumulator from 4.5 to 9.0 minutes.

From all piston positions a continuous feed of sufficient water is always available to the two-phase loop such that pressure decay is minimized and normal phase-separator/pump pressure rise is also maintained during load changes.

It had been concluded after system checkout that the accumulator check valve (Item 2-6, Fig. 16) was not a necessary system component. To verify this by test this component was removed from the WES. One result was that the makeup pump was noisier but otherwise system operation at low pressures and high pressures






Figure 36. Water Accumulator Change in Piston Position With Change in Electrolysis Module Current

was basically the same. Throttling of the accumulator metering valve (Item 30-1, Fig. 16) does diminish the magnitude of the piston stroke during cyclic operation of the solenoid valve on the phase separator/pump.

The same check valve was inserted in the water outlet line of the phase separator/pump to learn if it might reduce the pressure flow excursions caused by cyclic operation of the solenoid valve on the phase separator/pump. It was determined that the check valve was effective in controlling the water flow direction during priming of the system but did not alter system operation or reduce pressure-flow excursions. It appears that rather than the gas core being collapsed by reverse water flow when the solenoid valve is opened, there is a sudden rush of two-phase flow into the phase separator/pump supplied by the reservoir of two-phase fluid in the electrolysis module and heat exchangers. Pressure drop across the check valve in the flow direction was about  $6.9\text{ kN/m}^2$  (1 psid) so that water flow rate was reduced. The conclusion was to leave the check valve out of the system for either function.



## 3.3.5

Oxygen Absolute Back-Pressure Regulator

An oxygen absolute back-pressure regulator P/N 356-01 was designed and fabricated by Ausco, Inc., Port Washington, N.Y. in accordance with the requirements of Specification No. 73A490-831 Rev. B contained in the appendix. A drawing of this unit is provided in Figure 37.

The valve is of the direct acting, bellows loaded poppet type. The evacuated bellows acts to oppose the ambient pressure force to hold the poppet seated until crack pressure is reached, then allows the poppet to lift off its seat for flow. Adjustment of the crack pressure over the range of pressure from 690 to 3448kN/m<sup>2</sup> (100 to 500 psi) is accomplished by turning the gland into the body; then the key type lock is brought into the mating slot in the body by the knurled nut. This gives a positive lock between the body and gland so that vibration, etc. will not alter the pressure setting. This regulator controls oxygen back-pressure on the electrolysis module in the WES. Vendor bench tests with N<sub>2</sub> gas on the unit prior to delivery are included in Table VII.

Performance of the unit during all WES testing was excellent at the adjusted levels of 827, 1793 and 2758kN/m<sup>2</sup> (120, 260, and 400 psig) regulated oxygen pressure used during automatic system operation. No seat leakage was ever observed below set cracking pressure.

## 3.3.5

Hydrogen Absolute Back-Pressure Regulator

A unit identical in design to the oxygen absolute back-pressure regulator was fabricated by Ausco, Inc. as P/N 356-02 to meet requirements for a hydrogen absolute back-pressure regulator per Specification No. 73A490-830 Rev. B contained in the appendix.

Vendor bench tests with helium gas on the unit prior to delivery are included in Table VIII. Adjusted levels of regulated hydrogen pressure were established at 620, 1517, and 2413kN/m<sup>2</sup> (90, 220, 350 psig) during automatic system operation. Pressure regulation and poppet sealing at lock-up conditions was observed to be excellent.

A regulator failure occurred on 12-31-74 at 2413kN/m<sup>2</sup> (350 psig) operating pressure after 619 hours of operation and an estimated 400,000 open/close cycles caused by cyclic operation of the solenoid valve on the phase separator. Disassembly of the valve assembly revealed a cracked bellows. The bellows manufacturer attributed failure to cyclically applied high stress condition on the diaphragm. Recommendations for substantially increased cycling capability would be to increase diaphragm thickness from .152 to .178 cm (.006 to .007 inch).

A spare bellows assembly was installed in the failed regulator which was re-installed in the WES for resumption of testing on 1-3-75. Because this assembly continued the original bellows design, efforts were made to reduce the cyclic nature of phase separator solenoid valve operation as discussed in Para. 3.3.2.



ORIGINAL PAGE IS  
OF POOR QUALITY

DIRECT ENERGY CONVERSION PROGRAMS




Figure 37.



Table VIII

FORM #D5

AUSCO, INC.

VALVE ASS'Y. FUNCTIONAL TEST TRACEABILITY REPORT

ASS'Y # P357-02 ASS'Y. LOT # 1

SERIAL # 1

ASS'T. #1352 P 35%

REV. 8

PAGE 3-25

ASS'Y. DWG # P 356

REV. 5

DATE 3-25-77

DESCRIPTION OF TEST

GE. 73A490-330

\* UNIT TESTED WITH HE

.987 cet 11 of Ho is

~~N<sub>2</sub>PV  
EQUIVALENT TO .22 LB  
H<sub>2</sub>~~

~~PF~~ Hz

**ORIGINAL PAGE IS  
OF POOR QUALITY**

## 3.3.6

Water Temperature Regulating Valve

The water temperature regulating valve controls the process water temperature entering the electrolysis module. This valve mixes the water heated by the regenerative heat exchanger with a portion of the process water which bypasses the regenerative heat exchanger to maintain essentially constant temperature leaving the valves. Electrolysis module performance is improved by the higher operating temperature, remains independent of changes in coolant and ambient temperature at high load and module warm-up time is reduced. The water temperature regulating valve was designed and fabricated by Standard-Thomson Corp., Waltham, Massachusetts in accordance with Specification No. 73A490-829 Rev. B contained in the appendix. A drawing of the unit is shown in Fig. 38. Valve function is performed by an internal spool or actuator which contains a hermetically sealed eutectic wax. Expansion and contraction of the wax due to temperature variations results in valve displacement and subsequent proportioned mixing of "hot" and "cold" entering water.

Performance of the temperature regulating valve installed in the WES was excellent throughout system testing at all water flow conditions. Water discharge temperature was controlled usually within 2K ( $3.6^{\circ}\text{F}$ ). of the regulated setting of 339K ( $150^{\circ}\text{F}$ ). This controlled temperature is maintained for all module loads greater than 50 amps which provide a module heat rejection sufficient to raise the temperature of process water flowing through the regenerative heat exchanger and to the "hot" water inlet part of the temperature regulator to a value above 339K ( $150^{\circ}\text{F}$ ). At module loads below 50 amps the temperature regulating valve is closed to the "cold" water inlet part so no process water by-passes the regenerative heat exchanger and module water inlet temperature sees a lower level of thermal equilibrium (See Figure 26).




## NOTE



1. THIS VALUE DESIGNED TO MEET THE INTENT OF GE SPEC. 73A490-829
2. LOCKWASHER IN ACCORDANCE WITH MS-33540.
- △ 3. INDICATED INFO TO BE ELECTRIC ETCHED.
4. PROOF PRESSURE TEST (HYDROSTATIC) TO 935 PSIG.

COLD IN

.197 - .125



BOSSES PER M.933649-6 - 3 PLACES



PROPERTY OF NASA  
TEMP RGLT VALVE  
STC P/N 8B045-000 SER NO XXXX  
MFD BY  
STANDARD-THOMSON CORP  
WALTHAM, MASS

VALVE SHOWN IN MIX OUT TEMP OF 155°F

SEE STC QUALITY CONTROL  
MANUAL FOR INTERPRETATION  
OF DRAWING CLASSIFICATION  
ALL DRAWING INFORMATION TO  
BE OF MINOR [3] CLASSIFICATION  
UNLESS SPECIFIED

		UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES ON: DECIMALS      ANGLES $XX \pm .000X \pm .020 \pm$ ALL SURFACES 125	
		MATERIAL	CRES CONSTRUCTION
NEXT ASSY	USED ON	HEAT TREAT	FINISH
APPLICATION			

ITEM REQ'D	PART NO.	DESCRIPTION
PARTS LIST		
CONTRACT NO.		
DRAWN OSULLIVAN	DATE 9/1/73	
REDRAWN		
CHECKED		
APPROVED ENG. [Signature]	7/1 73	
APPROVED MFG.		
APPROVED		
SIZE	CODE IDENT. NO.	NUMBER
C	78493	8B045-000
SCALE	1/1	WT. 1.42 EST SHEET 1 OF 1

Figure 38.

3.3.7

Process Water Deionizer

On the basis of makeup water supplied to the WES having total dissolved solids of 5 PPM (Refer Guideline Spec. in Table III), a mixed deionizer bed size of about 80cc was determined for water consumption of 7.7Kg (17 lb.) /day for 60 days at 50 percent bed efficiency. Because of internal generated metal ion contaminants resulting from slight corrosion of stainless steel (primarily type 316) components in the process water loop, the bed size was increased to 500 ML utilizing a commercially available, high pressure gas sampling cylinder as a container. (Model No. 6-645-2520, Matheson Gas Products, Type 304SS, 1800 psig rating). This container was machined with 9/16-18 UNF female threads on each end and internally coated with .15mm (.006") thick gray durathane by American Durifilm Co., Inc., Newton Lower Falls, Massachusetts for corrosion resistance. To the internal face of a commercial outlet fitting was spot welded 100 mesh, type 310 stainless steel screen A 1<sup>1/2</sup> micron in-line filter P/N 20666-4-40, Mectron Industries, Inc., South El Monte, California was installed in the outlet line. The container was filled with Universal I monobed resin, Illinois Water Treatment Co., Rockford, Illinois and with glass wool packed between the resin bed and fitting at each end. The results of these water flow pressure drop tests on 2-5-74 are plotted in Fig. 39.

Because of reduced water flow rate on 11-11-75 the deionizer in-line filter was removed and found plugged with fines from the resin bed. Further inspection revealed many dionizer beads in the water line between the phase separator/pump and inlet to the deionizer. The latter was expected to occur a few days previous during which rapid depressurization from  $2413\text{kN/m}^2$  (350 psig) of the system without the phase separator/pump operating because of a leaky H<sub>2</sub> vent valve (Item 28-1). Rapid venting of hydrogen and water from the two-phase region causes flow surges, and in this case, high flow reversal through the deionizer thus dislodging the beads into the inlet line. Inspection of the resin bed indicated considerable anion resin material had degraded to a fine powder.

The inlet fitting of the deionizer was also provided with 100 mesh screen filter to retain resin beads in the event of flow reversal. The container was re-filled with Mixed Bed Resin AG501-X8 from BIO-RAD Laboratories, Richmond, California having a 20-50 mesh bead size which was used with good results in other laboratory work. The degraded resin from Illinois Water Treatment Co., was evidently the result of a quality control problem. The result of a water flow pressure drop test on this configuration is also plotted in Fig. 39.

Following a WES test demonstration on 2-11-75 the system was depressurized without the phase separator/pump operating and with water flow control valve (Item 30-2) inadvertently closed. This condition resulted from trapping rather than expelling from the process water the hydrogen outgassed during depressurization. Subsequent system start up revealed a reduced water flow rate. A bench flow test with water indicated no problem with the deionizer as the data






Figure 39. Detonizer Bed Pressure Drop Versus Water Flow Rate

shown in Fig. 39. Checks on other components of the process water circuit also revealed no problem. Further evaluation of the deionizer showed that a gas bound deionizer bed can initially block water flow (top to bottom at 1g) up to  $12.5\text{kN/m}^2$  ( $50'' \text{H}_2\text{O}$ ) but that gradual water seepage and recirculation will remove the entrained gas. This condition was never experienced again during repeated WES depressurizations with the phase separator/pump operating and circulating the process water to remove entrained hydrogen evolved at low pressure.



3.3.8

O<sub>2</sub>/H<sub>2</sub> Mixture Sensor


Although a General Monitors Corp. combustible gas detector (Item 22, Table I) was used in the WES to sense external hydrogen leakage to ambient, there remained a need for a sensor for detecting potential mixtures of O<sub>2</sub> and H<sub>2</sub> existing in internal lines resulting from possible internal electrolysis module leakage. Operation at high system pressure compounded the problem.

A catalytic sensor was devised by attaching a platinum electrode (as used in SPE fuel and electrolysis cells) to a stainless steel sheathed platinum resistance temperature probe which could be exposed to an O<sub>2</sub>/H<sub>2</sub> mixture in a high-pressure fluid line. A successfully tested configuration consisted of a pressed electrode made with platinum black and expanded tantalum screen which was wrapped around and tack welded to a .64 cm (1/4 inch) dia. sheath x 14 cm (5-1/2 inch) long resistance temperature detector P/N GP70-A1-P200-B manufactured by RDF Co., Hudson, N. H. This catalytic sensor probe was inserted in the horizontal leg of a 3/8 inch Swagelok Tee and fastened and sealed with a 3/8 to 1/4 reducer.

The O<sub>2</sub>/H<sub>2</sub> mixer sensor was bench tested with various mixtures of oxygen and hydrogen injected in the vertical leg of the Tee. The flow of gas mixture impinged on the sensing probe, which was heated by combination of O<sub>2</sub> and H<sub>2</sub> on the platinum black surface and ejected out one horizontal leg of the Tee. Measured sensor temperatures versus the percentage of O<sub>2</sub> in H<sub>2</sub> or H<sub>2</sub> in O<sub>2</sub> are plotted in Fig. 40. Two sensors were installed in the system. The O<sub>2</sub> in H<sub>2</sub> mixture sensor (Item 32-1) was installed in the hydrogen upstream of the hydrogen back pressure regulator to prevent exposure to air during shutdown. The H<sub>2</sub> in O<sub>2</sub> mixture sensor (Item 32-2) was installed in the oxygen output line between the oxygen back pressure regulator and O<sub>2</sub> flowmeter. Automatic emergency shutdown was set for 333K (140°F) for the O<sub>2</sub> in H<sub>2</sub> sensor and 359K (187°F) for the H<sub>2</sub> in O<sub>2</sub> sensor. The latter setting was higher because oxygen leaving the insulated oxygen regulator can reach about 327K (130°F).

Inspection of these sensors after about 1000 hours operation showed that the platinum black had spalled off particularly the O<sub>2</sub> in H<sub>2</sub> sensor. This erosion was caused by water impingement at rather high velocity when present in the discharge lines. Recommended modifications would be to improve the adhesion of the catalyst with more binder and a smaller screen grid. Also, erosion would be reduced with a baffle or shield in the impact zone and probe installation in a 1/2 inch Tee size to reduce local gas velocities.



Figure 40. Gas Mixture Temperature vs. Percent by Volume in  $O_2/H_2$  Mixture Sensor.

3.4

System Development and Test Results

3.4.1

System Design Analysis

Advance system development under Phase II of the subject contract included the design, fabrication and procurement, assembly and test of a six-man rated pre-prototype WES. Various proposed systems were studied which would include an advanced electrolysis module capable of six-man oxygen generation rate and a dynamic phase separator. With the concurrence of Mr. R. B. Martin, NASA/JSC, Contract Technical Monitor, the system selected included an advanced electrolysis module, a dynamic phase separator/pump and other ancillary components to provide pure oxygen and hydrogen generation at high pressure (nominal  $2860\text{kN/m}^2$ , 415 psia) and (nominal 355K, 180° F) module average temperature. This system would include, where possible for cost effectiveness, former NAS1-9750 contract components with necessary modifications and off-the-shelf commercial components meeting functional requirements. The existing 13-cell electrolysis module would be modified for operation at high pressure, high temperature and accompanying high current density to increase capacity from a four-man to a six-man rating. This pre-prototype water electrolysis system would be packaged and contain suitable controls and display for safe, unattended operation.

Tests on the four-man breadboard WES were conducted to provide data for predicting pressure drop in the water and two-phase circuit at high pressure conditions. Figure 41 shows measurements of pressure drop versus electrolysis module current for process water flow rates of 4.53, 6.79 and  $9.16\text{kg/hr.}$  (10, 15 and 20 lb/hr.). Differential pressure was measured across a series of components in combination: (1) deionizer, water temperature regulator and electrolysis module in one group; and (2) check valve, regenerative heat exchanger and primary heat exchanger in another group. Pressure drop of Group (1) was essentially independent of hydrogen generation rate or module current exhibited by flow through screens in the cells. Pressure drop in Group (2) was dependent upon both water and hydrogen flow caused by two-phase slug flow in the tubing of the heat exchangers. Nominal line pressure was  $310\text{kN/m}^2$  (45 psia).

From the test data, hydrogen and water volumetric flow rates were calculated to generate Figure 42, which shows pressure drop in the two-phase region (Group (2) components in series) as a function of hydrogen/water volume ratio. The significance of this volume ratio is illustrated by Figure 43 at design water flow rate, mean fluid temperature at various system operating pressures. As indicated by the dashed line, at constant water flow the hydrogen volumetric rate at 23 amps,  $690\text{kN/m}^2$  (100 psia), is equivalent to 75 amps at  $691\text{kN/m}^2$  (350 psia). A map of predicted system pressure-flow characteristics are given in Figure 44 with estimated performance of the phase separator/pump.

Analysis of the water electrolysis module was made to predict performance at  $2760\text{kN/m}^2$  (400 psia) oxygen pressure,  $2413\text{kN/m}^2$  (350 psia) hydrogen






Figure 41. WES Components Pressure Drop Vs. Electrolysis Module Current at Constant Water Flow






Figure 42. WES Two-Phase Components Pressure Drop Versus Calculated Gas/Liquid Volume Ratio at Constant Water Flow






Figure 43. Calculated Hydrogen/Water Volume Ratio Versus Electrolysis Module Current at Different H<sub>2</sub> Side Pressures




Figure 44. Dynamic Phase Separator-Pump Calculated Pressure - Flow Characteristics

pressure, and a mean cell temperature of 355k (180°F). At high pressure, and temperature parasitic losses are increased. This is particularly due to diffusion of gases across the solid polymer electrolyte (SPE) membrane. A parasitic current of about 5 amps was expected at the cited conditions, requiring process water flow of about 20 lb/hr. to limit the cell temperature gradient to 22k (40°F). A higher process water flow could reduce module temperature gradients, but increase system pressure drop and pump requirements.

A volume study of the proposed system was also performed to predict water content retention on the two-phase side especially during oxygen generation rate changes of cyclic operation, startup and shutdown. Since the volume ratio of water to gas varies as a function of O<sub>2</sub> generation rate (process water rate is essentially constant), it becomes necessary to provide a water accumulator of adequate storage capacity within the process water loop of the system.

Definition of the advanced system configuration resulted in the requirement of those major components listed in Table IV on Page 37 installed as shown in the functional schematic in Figure 16 which was described earlier. Some small but no basic revisions were made in the course of development. A safety study and a failure mode and effect analysis (FMEA) were performed to establish single point failures. A fault detection and isolation analysis (FDIA) was also made to establish fault sensors and monitoring equipment requirements of the WES installation. The FMEA is included in Table IX accompanied by the guideline criteria used in conducting the analysis. A summary of the fault conditions, derived from the FDIA, which result in an automatic safe emergency shutdown (ESD) of the system is provided in Table X. The limit values and hold periods shown are those set for high pressure operation at the WES design point. Most of the limit values and hold periods were established in advance from design criteria which defined emergency controller logic and shutdown requirements. Potentiometer adjustments for setting all pressure limits provide for system operation and automatic ESD at any selected pressure level and allowed for component and system variations experienced during development.



Table IX  
Failure Mode and Effects Analysis  
Guideline Criteria

- a) For the purpose of the Failure Mode and Effect Analysis, the term "failure" is defined as a structural break, a change in dimension or a change in functional characteristics to the extent that the part or component no longer performs within specification limits.
- b) In the interest of cost effectiveness, monitoring and recording is performed manually by an operator.
- c) In the interest of cost effectiveness, isolation is indicated by lights. When two or more lights are indicating, further investigation will be necessary to isolate the failure and cause.
- d) In the interest of cost effectiveness, redundancy of instrumentation to provide a voting validation of a fault at the same location is not included in this pre-prototype WES.
- e) Only the major components of the WES (Table IV, Figure 1.6) will be considered in the FMEA.
- f) Although the NASA/JSC WES components are considered "non-flyable" breadboard hardware, the FMEA will be evaluated for severity of consequences, with failures categorized in accordance with space station classes as:

<u>Class</u>	<u>Description</u>
I	A single failure which could cause loss of personnel.
IIA	A single failure whereby the next associated failure could cause loss of personnel.
IIB	A single failure that could cause return of one or more personnel to earth, or loss of subsystem function(s) essential to continuation of space operations and scientific investigation.
III	A single failure which could not result in loss of primary or secondary mission objectives or adversely affect crew safety.



Table IX

## WES FAILURE MODE AND EFFECT ANALYSIS

## 6-MAN ADVANCED BREADBOARD WATER ELECTROLYSIS SYSTEM (WES)

GENERAL  ELECTRIC

Refer Drawing 73A490-868 Rev. A

Item No.	Component Title	Component Function	Failure Mode	Hypothetical Failure Mechanism	Effect of Failure	Failure Class	Fault Detection	Fault Isolation	Comments
1.	Water Electrolysis Module	To generate oxygen and hydrogen by electrolysis of water proportional to input current.	a) Mixture (O <sub>2</sub> to H <sub>2</sub> /H <sub>2</sub> O side), internal cross leakage.	Cell assembly gasket displacement, deterioration or rupture; solid polymer electrolyte (SPE) membrane perforation or rupture.	WES will automatically shutdown by oxygen sensing in H <sub>2</sub> outlet or by hydrogen sensing in O <sub>2</sub> outlet.	III	Temperature rise of catalytic O <sub>2</sub> /H <sub>2</sub> mixture sensor. Temperature rise of H <sub>2</sub> /H <sub>2</sub> O fluid at module outlet (Items 32-1, 32-2, 21).	Red "O <sub>2</sub> in H <sub>2</sub> " or "H <sub>2</sub> in O <sub>2</sub> " or "Mod Temp High" light on.	
			b) Internal cross leakage, N <sub>2</sub> in dome to O <sub>2</sub> or H <sub>2</sub> /H <sub>2</sub> O sides.	Cell assembly gasket displacement, deterioration or rupture.	Pressure decay of trapped N <sub>2</sub> in module dome, dilute output gases with N <sub>2</sub> . WES will ESD (i.e., automatic emergency shutdown).	III	Dome pressure on Press Trans (Item 17-4) drops below low limit.	Red "N <sub>2</sub> Dome Low" light on.	
			c) External leakage of N <sub>2</sub> .	Loss of gland or O-ring seals by permanent set or deterioration. Fracture of dome.	Pressure decay of trapped N <sub>2</sub> in module dome. N <sub>2</sub> to cabin. WES will ESD.	III	Same as (b).	Same as (b).	
			d) External leakage of O <sub>2</sub> .	Loss of O-ring seal at module end plate tube connections.	Gross leak will drop O <sub>2</sub> pressure below O <sub>2</sub> regulated pressure. WES will ESD. Small leak has no effect.	III	O <sub>2</sub> pressure on Press Trans (Item 17-2) falls below low limit.	Red "O <sub>2</sub> Low" light on.	
			e) External leakage of H <sub>2</sub> or H <sub>2</sub> O.	Same as (d).	a) Gross leak will drop H <sub>2</sub> /H <sub>2</sub> O pressure below H <sub>2</sub> regulated pressure. WES will ESD. H <sub>2</sub> and/or H <sub>2</sub> O will vent to cabin. WES will ESD. b) H <sub>2</sub> small leak to cabin. WES will ESD. c) H <sub>2</sub> O small leak to cabin. No ESD.	III	a) Two-phase pressure on Press Trans (Item 17-3) falls below low limit. b) Combustible Gas Detector (Item 22) exceeds high limit. c) Visual inspection by crew.	Red "2Ø Low" light on. b) Red light on CGD, Item 22. c) Location of H <sub>2</sub> O drop formation.	
			f) Performance decay (i.e., higher input voltage required at current setting to generate desired O <sub>2</sub> and H <sub>2</sub> rate).	Increased cell(s) impedance due to (1) water starvation, (2) SPE ion contamination, (3) low contact pressure (4) corrosion of current collector.	Module terminal voltage will increase until WES will ESD.	III	Output voltage sensing on Power Conditioner (Item 11) exceeds high limit.	Red "Mod Volt High" light on.	
			g) H <sub>2</sub> /H <sub>2</sub> O side restriction.	Contamination clogging cell(s) H <sub>2</sub> /H <sub>2</sub> O side flow passages.	Water starvation of one or more cells. WES will ESD on module high voltage.	III	Same as (f).	Same as (f).	
2-1 2-2	Redundant N <sub>2</sub> Input Check Valves to H <sub>2</sub> Side	To prevent H <sub>2</sub> feed back to N <sub>2</sub> supply line.	Valve(s) stuck closed.	Contamination.	a) Unable to pressurize H <sub>2</sub> side with N <sub>2</sub> during system pressurization prior to start-up.  b) H <sub>2</sub> pressure falls below N <sub>2</sub> base pressure during normal, cyclic (WES will ESD) or emergency shutdown.	III	a) Pressure Trans. (Items 17-1, 17-3) show no increase on display meters when P <sub>N<sub>2</sub></sub> > P <sub>H<sub>2</sub></sub> . Visual readout.  b) Items 17-1 and 17-3 fall below low limit setting for cyclic operation.	a) Remove both check valves and separately bench test.  b) Red "2Ø Low" light on, perform (a).	
			One valve stuck open.	a) Contamination and/or spring rupture.	No effect with redundant units.	III	None.	Remove both check valves and separately bench test.	

ORIGINAL PAGE IS  
OF POOR QUALITY

Table IX

## WES FAILURE MODE AND EFFECT ANALYSIS

## 6-MAN ADVANCED BREADBOARD WATER ELECTROLYSIS SYSTEM (WES)

GENERAL  ELECTRICSheet 2 of 11  
Date: 9-20-74

Refer Drawing 73A490-868 Rev. A

Item No.	Component Title	Component Function	Failure Mode	Hypothetical Failure Mechanism	Effect of Failure	Failure Class	Fault Detection	Fault Isolation	Comments	
2-1 2-2	Continued		Two valves stuck open.  External leakage	Same as (a), both valves.  Seal material set or loose connection.	H <sub>2</sub> admission into N <sub>2</sub> supply line, gradual mixture admission to O <sub>2</sub> side after normal, cyclic or emergency shutdown. WES will ESD on restart.  a) N <sub>2</sub> side, eventual exhaustion of N <sub>2</sub> supply to cabin. WES will ESD.  b) H <sub>2</sub> side, H <sub>2</sub> leakage to cabin. WES will ESD.	III	Temperature rise of catalytic O <sub>2</sub> /H <sub>2</sub> mixture sensor (Item 32-2).	Red "H <sub>2</sub> in O <sub>2</sub> " light on.		
2-3 2-4	Redundant N <sub>2</sub> Input Check Valves to O <sub>2</sub> Side	To prevent O <sub>2</sub> feed back to N <sub>2</sub> supply line.	Valve(s) stuck closed.  One valve stuck open.	Contamination.	a) Unable to pressurize O <sub>2</sub> side with N <sub>2</sub> during system pressurization prior to start-up.  b) O <sub>2</sub> pressure falls below N <sub>2</sub> base pressure during normal, cyclic (WES) or emergency shutdown.	III	a) Press Trans (Item 17-2) shows no increase on display meter when P <sub>N<sub>2</sub></sub> > P <sub>O<sub>2</sub></sub> . Visual readout.  b) Item 17-2 falls below limit setting for cyclic operation.	a) Remove both check valves and separately bench test.  b) Red "O <sub>2</sub> Low" light on. Perform (a).		
2-5	Makeup Water Check Valve	To prevent drain back of high pressure process water (and H <sub>2</sub> ) to low pressure makeup water supply.	Valve stuck closed.  Valve stuck open.  External leakage.	Contamination.  Contamination and/or spring rupture.  Seal material set or loose connection.	No effect with redundant units.  O <sub>2</sub> admission into N <sub>2</sub> supply line. Mixture admission into H <sub>2</sub> /H <sub>2</sub> O side after normal, cyclic or emergency shutdown. WES will ESD on restart.  a) N <sub>2</sub> side, eventual exhaustion of N <sub>2</sub> supply to cabin. WES will ESD.  b) O <sub>2</sub> side, O <sub>2</sub> leakage to cabin. No effect unless gross leakage (see Item 1, Failure Mode d).  Unable to resupply process water loop with makeup water. WES will ESD.  a) No effect if outlet check valve on makeup pump (Item 4) checks properly.  b) If outlet check valve on makeup pump fails open, WES will ESD.  a) Gross leak on high pressure side will drop H <sub>2</sub> /H <sub>2</sub> O pressure to cause ESD.  b) H <sub>2</sub> O small leak to cabin. No ESD.	III III III III III III	None  Temperature rise of catalytic O <sub>2</sub> /H <sub>2</sub> mixture sensor (Item 32-1).  a) N <sub>2</sub> pressure on Press Trans (Item 17-5) falls below low limit.  b) None.	Red "O <sub>2</sub> in H <sub>2</sub> " light on.  a) Red "N <sub>2</sub> Base Low" light on.  b) None.	Remove both check valves and separately bench test.  Red "Accum Empty" light on.  a) Remove and bench test.  b) Red "2Ø Low" light on.  a) Red "2Ø Low" light on.  b) Visual inspection by crew.	Makeup Pump Ass'y. (Item 4) has outlet check valve, so Item 2-5 is redundant.

Table IX

GENERAL ELECTRIC

Sheet 3 of 11  
Date: 9-20-74WES FAILURE MODE AND EFFECT ANALYSIS  
6-MAN ADVANCED BREADBOARD WATER ELECTROLYSIS SYSTEM (WES)

Refer Drawing 73A490-868 Rev. A

Item No.	Component Title	Component Function	Failure Mode	Hypothetical Failure Mechanism	Effect of Failure	Failure Class	Fault Detection	Fault Isolation	Comments
2-6	Water Accumulator Check Valve	Allows quick fill of water accumulator from 2Ø loop during start-up or load change transients. Prevents reverse surge during this transient and when makeup water pump (Item 4) is operating.	Valve stuck closed.  Valve stuck open.  External leakage.	Contamination.  Contamination and/or spring rupture.  Seal material set or loose connection.	H <sub>2</sub> /H <sub>2</sub> O pressure will suddenly increase during start-up or increase in load. WES will ESD.  Reverse surge of water from accumulator to 2Ø loop could cause ΔP cycling in loop and splitting of separator/pump to H <sub>2</sub> outlet. Probable ESD.  a) Gross leak will drop H <sub>2</sub> /H <sub>2</sub> O pressure to cause ESD.  b) H <sub>2</sub> O small leak to cabin. No ESD.	III  III  III	H <sub>2</sub> /H <sub>2</sub> O pressure on P. T. (Item 17-3) will exceed high limit.  H <sub>2</sub> /H <sub>2</sub> O pressure on P. T. (Item 17-3) will exceed high limit during pressure surge.  a) H <sub>2</sub> /H <sub>2</sub> O pressure on P. T. (Item 17-3) falls below low limit.  b) Visual inspection by crew.	Red "2Ø High" light on.  Red "2Ø High" light on.  a) Red "2Ø Low" light on.  b) Location of H <sub>2</sub> O drop formation.	Pressure measurements and transient behavior of 2Ø loop to be investigated with Item 2-6 removed during WES development tests.
3	Makeup Water Filter	To remove particulate material from water supplied to makeup pump (H <sub>2</sub> O A).	High filter ΔP or no water flow.  External leakage.	Partial or complete clogging by contamination. Loss of makeup water supply pressure.  Seal material set or loose connection.	Makeup pump suction pressure is low when operating. WES will ESD.  H <sub>2</sub> O leakage to cabin. No ESD.	III  III	Pressure at pressure switch (Item 19) fails to actuation point.  Visual inspection by crew.	Red "Makeup H <sub>2</sub> O Low" light on.  Location of H <sub>2</sub> O drop formation.	101
4	Makeup Water Pump	To supply makeup water to high pressure process water loop.	No water delivery to water accumulator.  External leakage.	Failure of motor, drive mechanism, plunger seal leak, or stuck inlet or outlet check valves.  Seal material set or loose connection.	a) Unable to supply process water loop with makeup water. WES will ESD.  H <sub>2</sub> O leakage to cabin. No ESD unless leak exceeds output as in (a).	III  III	Water accumulator (Item 16) "Empty" position switch remains actuated beyond 20 sec. limit.  Visual inspection by crew.	Red "Accum Empty" light on.  Location of H <sub>2</sub> O drop formation.	
5	Coolant Water Filter	To remove particulate material from cooling water supplied to WES.	Low or no water flow.  External leakage.	Partial or complete clogging by contamination.  Seal material set or loose connection.	WES will ESD at coolant flow under 0.2 gpm.  H <sub>2</sub> O leakage to cabin. No ESD.	III  III	Coolant flow under 0.2 gpm will actuate flow switch, (Item 25).  Visual inspection by crew.	Red "Cool Flow Low" light on.  Location of H <sub>2</sub> O drop formation.	
6	Electronic Controller for Phase Separator/Pump (Item 8)	Provides manual switches and electronic control for energizing separator/pump motor and solenoid valve.	Loss of power input to pump motor.  Loss of power to energize N.C. solenoid valve open.	Open circuit from poor solder connections, or component failure.  Open circuit from poor solder connections, or component failure.	Loss of separator/pump ΔP and process water flow. WES will ESD.  Two-phase loop pressure will increase until solenoid valve relieves and/or relief valve (Item 26-3) opens. WES will ESD.	III  III	ΔP press. trans. (Item 18-1) will fall below low limit setting.  2Ø pressure will exceed high limit setting of P. T. (Item 17-3).	Red "Sep. ΔP Low" light on.  Red "2Ø High" light on.	
7	Deionizer Resin Bed	To remove ionic impurities from process water.	High conductivity effluent water from deionizer.	Resin monobed channeling, high conductivity makeup H <sub>2</sub> O, ionic contamination of process water by WES components.	WES will ESD by high conductivity H <sub>2</sub> O. Ion exchange of impurities with hydrogen proton in SPE of module cell will cause some permanent degradation of electrolysis module (Item 1) performance.	III	Process water conductivity will exceed high limit setting of conductivity sensor (Item 24).	Red "Cond. High" light on.	

ORIGINAL PAGE IS  
OF POOR QUALITY

Table IX

## WES FAILURE MODE AND EFFECT ANALYSIS

## 6-MAN ADVANCED BREADBOARD WATER ELECTROLYSIS SYSTEM (WES)

GENERAL  ELECTRIC

Refer Drawing 73A490-868 Rev. A

Item No.	Component Title	Component Function	Failure Mode	Hypothetical Failure Mechanism	Effect of Failure	Failure Class	Fault Detection	Fault Isolation	Comments
7	Continued		Low process water flow rate.	Resin bed has become partially clogged with particulate contamination.	Reduced process water flow rate will increase electrolysis module H <sub>2</sub> /H <sub>2</sub> O outlet temperature. WES will ESD.	III	Module outlet temperature sensor will exceed high limit.	Red "Mod Temp High" light on.	
	Two-Phase Dynamic Separator/Pump	To separate process water and H <sub>2</sub> from 2Ø mixture and provide ΔP for process water circulation.	No process water flow.	Resin bed has become completely clogged with particulate contamination.	Water starvation of one or more electrolysis module cells increases module terminal voltage. WES will ESD.	III	Output voltage sensing on power conditioner (item 11) exceeds high limit.	Red "Mod Volt High" light on.	
			External leakage.	Seal material set or loose connection.	H <sub>2</sub> O leak to cabin.	III	Visual inspection by crew.	Location of H <sub>2</sub> O drop formation.	
			Loss of pumping ΔP and water circulation.	Motor failure, decoupling of magnet drive, excessive torque due to bearing or component failure, lack of adequate H <sub>2</sub> O in 2Ø mixture.	Inadequate or loss of process water flow would overheat and/or starve electrolysis module (item 1). WES will ESD.	III	ΔP on press. trans. (item 18-1) will fall below low limit.	Red "Sep ΔP Low" light on.	
			Normally closed solenoid fails to open.	Open circuit due to poor solder joint or broken wire, jammed plunger, contamination.	2Ø mixture will increase in pressure at module gas generation rate until vented by relief valve (item 26-3). WES will ESD.	III	2Ø pressure on P. T. (item 17-3) will exceed high limit.	Red "2Ø High" light on.	
			N. C. solenoid stuck open or leaks internally.	Spring fracture, seal material set, jammed plunger, contamination.	Water discharge to downstream hydrogen.	III	Visual inspection of H <sub>2</sub> flowmeter by crew.	H <sub>2</sub> O droplets in glass H <sub>2</sub> flowmeter, downstream H <sub>2</sub> O discharge in H <sub>2</sub> stream.	
			External leakage.	Seal material set or loose connection.	a) H <sub>2</sub> leakage to cabin detected by comb. gas detector. WES will ESD. b) H <sub>2</sub> O leakage to cabin.	III	Comb. gas detector (item 22) exceeds high limit.	Red light on CGD, item 22.	
9	Cooling Water Flow-meter	To provide visual display of coolant flow.	High float reading.	Contamination of gas in flowmeter.	None.	III	Visual inspection by crew		
			Low float reading.	Same.	None.	III	Same as above.	If no ESD on 25 at low flow, check 29 calibration.	
			External leakage.	Seal material set, loose connection, glass fracture.	H <sub>2</sub> O leakage to cabin. No ESD.	III	Same as above.	Location of H <sub>2</sub> O drop formation.	
10	Temperature Regulating Valve	To control the inlet water temperature to the electrolysis module (item 1).	High outlet H <sub>2</sub> O temperature.	Wax actuating valve binding due to contamination or corrosion limiting cold-water in flow or poor heat transfer to wax actuator due to excessive gas in H <sub>2</sub> O.	Electrolysis module inlet and outlet temperatures increase improving module performance. WES will ESD.	III	Temperature of 2Ø mixture at module outlet rises above high limit.	Red "Mod Temp High" light on.	
			Low outlet H <sub>2</sub> O temperature.	Wax actuating valve binding due to contamination or corrosion limiting hot-water in flow.	Electrolysis module inlet and outlet temperatures decrease reducing performance. Terminal voltage may exceed high limit at high loads resulting in ESD of WES.	III	Output voltage sensing on power conditioner (item 11) will exceed high limit.	Red "Mod Volt High" light on.	

ORIGINAL PAGE IS  
OF POOR QUALITY

102

Sheet 4 of 11  
Date: 9-20-74

Refer Drawing 73A490-868 Rev. A

Item No.	Component Title	Component Function	Failure Mode	Hypothetical Failure Mechanism	Effect of Failure	Failure Class	Fault Detection	Fault Isolation	Comments
10	Continued		External leakage.	Seal material set or loose connection.	H <sub>2</sub> O leak to cabin.	III	Visual inspection by crew.	Location of H <sub>2</sub> O drop formation.	
11	Power Conditioner/Cold Plate Assembly	To provide manually preset regulated current to electrolysis module below a maximum voltage limit.	Zero or low current output to module below setting.	Loss of amplifier gain, broken wire, overheated or shorted electronic elements, poor solder joints.	Possible burned out electronic elements or insulation in P. C. Zero or reduced WES gas output.	III	Visual inspection of module current meter and O <sub>2</sub> and H <sub>2</sub> gas flowmeters by crew.	Low meter readings.	
			High current output to module, above manual setting.	Same as above.	Possible burned out electronic elements. Excessive current drawn by P. C. may activate circuit breaker (item 33) or increase module voltage resulting in ESD of WES.	III	a) Input P. C. current may exceed circuit breaker limit.  b) Output voltage may exceed high limit.	a) Red "Current High" light on.  b) Red "Mod Volt High" light on.	
			Overheating.	Contamination in coolant tubes of cold plate.	Zero or reduced coolant flow. WES will ESD.	III	Coolant flow will fall below actuation point of flow switch.	Red "Cool Flow Low" light on.	
			External coolant leakage from cold plate.	Corroded tubing, loose connection.	H <sub>2</sub> O coolant leak to cabin.	III	Visual inspection by crew.	Location of H <sub>2</sub> O drop formation.	
12	Regenerative Heat Exchanger	Recovery of waste heat from electrolysis to preheat process water to module for elevated temperature operation.	Inadequate heat transfer from hot side to cold side.	Partial or complete clogging of tubes with contamination.	a) Module operating temperature will reduce which may cause excessive terminal voltage at high loads. WES will ESD.  b) WES will ESD if low process water flow causes water starvation of one or more cells, increasing terminal voltage.	III	Output voltage sensing on power conditioner (item 11) would exceed high limit.	Red "Mod Volt High" light on.	
			External leakage.	Seal material set or loose connection.	H <sub>2</sub> leakage to cabin detected by GCD.	II	Combust. gas detector (item 22) exceeds high limit.	Red light on CGD is on.	
					H <sub>2</sub> O leakage to cabin.	III	Visual inspection by crew.	Location of H <sub>2</sub> O drop formation.	
13	Primary Heat Exchanger	To transfer WES waste heat (elec. module and power cond.) to coolant water.	Inadequate heat transfer from hot (process water) to cold (coolant water) side.	Partial or complete clogging of tubes with contamination.	a) Reduced process water flow or surface fouling will cause module temp. to increase.  b) Blocked process water flow same as item 12 b.  c) Reduced or blocked coolant flow.  All will cause ESD of WES.	III	a) Module outlet temp. sensor will exceed high limit.  b) Output voltage on power cond. would exceed high limit.  c) Coolant flow will fall below actuation point of flow switch.	Red "Mod Temp High" light on.  Red "Mod Volt High" light on.  Red "Cool Flow Low" light on.	
14	Absolute O <sub>2</sub> Back Pressure Regulator	Regulates pressure level on O <sub>2</sub> side of electrolysis module.	Valve elements stuck closed.	a) Contamination binding movable parts in closed position.	O <sub>2</sub> side pressure increases until vented by O <sub>2</sub> relief valve (item 26-2). WES will ESD.	III	O <sub>2</sub> pressure on P. T. (item 17-2) exceeds high limit.	Red "O <sub>2</sub> High" light on.	
			Valve elements stuck open.	b) Spring fracture, soft seat rupture, contamination binding movable parts in an open position.	O <sub>2</sub> side pressure falls to N <sub>2</sub> base pressure where N <sub>2</sub> is admitted. WES will ESD.	III	O <sub>2</sub> pressure on P. T. (item 17-2) falls below low limit.	Red "O <sub>2</sub> Low" light on.	

Table IX

## WES FAILURE MODE AND EFFECT ANALYSIS

GENERAL  ELECTRICSheet 6 of 11  
Date: 9-20-71

## 6-MAN ADVANCED BREADBOARD WATER ELECTROLYSIS SYSTEM (WES)

Refer Drawing 73A490-868 Rev. A

Item No.	Component Title	Component Function	Failure Mode	Hypothetical Failure Mechanism	Effect of Failure	Failure Class	Fault Detection	Fault Isolation	Comments
14	Continued		External leakage.	c) Seal material set or rupture.	O <sub>2</sub> leakage to cabin. No ESD unless O <sub>2</sub> pressure falls to low limit.	III	None unless audible hiss heard by crew.	Location of leakage point by bubble check.	
15	Absolute H <sub>2</sub> Back Pressure Regulator	Regulates pressure level at H <sub>2</sub> discharge of phase separator/pump (Item 8) and H <sub>2</sub> side of H <sub>2</sub> O accumulator (Item 16).	Valve elements stuck closed.	Same as Item 14 a.	H <sub>2</sub> regulator inlet pressure increases until vented by H <sub>2</sub> relief valve (Item 26-1). WES will ESD.	III	H <sub>2</sub> pressure on P. T. (Item 17-1) exceeds high limit.	Red "H <sub>2</sub> High" light on.	
			Valve elements stuck open.	Same as Item 14 b.	H <sub>2</sub> regulator inlet pressure falls to N <sub>2</sub> base pressure where N <sub>2</sub> is admitted. WES will ESD.	III	H <sub>2</sub> pressure on P. T. (Item 17-1) falls below low limit.	Red "H <sub>2</sub> Low" light on.	
16	Water Accumulator	Provides high pressure reservoir for makeup water and absorbs changes in H <sub>2</sub> O quantity in 2Ø loop during startup and load changes.	External leakage.	Same as Item 14 c.	H <sub>2</sub> leakage to cabin. WES will ESD.	III	Combust. gas detector (Item 22) exceeds high limit.	Red light on CGD is on.	
			Piston stuck in "Empty" position.	Contamination, corrosion or seal wear binding piston or Rod. "Empty" position switch fails closed.	WES will ESD after 4 minute delay if "Empty" position signal held continuously.	III	"Empty" position switch actuated by piston Rod, electronic timer.	Red "Accum Empty" light on.	
			Piston stuck in intermediate position.	Contamination binding as above.	Lack of H <sub>2</sub> O in 2Ø loop will reduce separator/pump ΔP and WES will ESD.	III	ΔP on P. T. (Item 18-1) will fall below low limit.	Red "Sep ΔP Low" light on.	
			Piston stuck in "Overfill" position.	Contamination binding as above. "Overfill" switch fails closed.	WES will ESD after 4 minute delay if "Overfill" position signal held continuously.	III	"Overfill" position switch actuated by piston Rod, electronic timer.	Red "Accum Overfill" light on.	
			Internal leakage.	Piston seal wear, set, scored cylinder from contamination.	H <sub>2</sub> O will leak across piston to H <sub>2</sub> chamber and H <sub>2</sub> discharge line. Excessive makeup water "consumption".	III	Visual inspection of H <sub>2</sub> flowmeter by crew.	H <sub>2</sub> O droplets visible in glass H <sub>2</sub> flowmeter.	
			External leakage.	Seal material set, loose connection.	H <sub>2</sub> leakage to cabin. WES will ESD.	III	Combust. gas detector (Item 22) exceeds high limit.	Red light on CGD is on.	
			"Empty" position switch fails open.	Fatigue, lever fracture.	Makeup pump will not come on. Lack of H <sub>2</sub> O quantity in 2Ø loop will reduce separator/pump ΔP and WES will ESD.	III	ΔP on P. T. (Item 18-1) will fall below low limit.	Red "Sep ΔP Low" light on.	
			"Overfill" position switch fails open.	Fatigue.	"Overfill" accumulator condition can only occur at start-up, load change or secondary failure. Excessive 2Ø pressure buildup as a result would vent 2Ø relief valve (Item 26-3). WES will ESD.	III	2Ø pressure on P. T. (Item 17-3) will exceed high limit.	Red "2Ø High" light on.	
17-1	Pressure Transducer, 0-500 psig, H <sub>2</sub> Press.	To monitor regulator H <sub>2</sub> pressure and provide high and low ESD signals.	High signal output.	Failure of internal electronic component.	a) False "High" pressure signal can cause ESD.	III	"H <sub>2</sub> " meter display, red "H <sub>2</sub> High" light on.	Compare P. T. 17-1 readout with P. T. 17-3 and 17-5.	
			Low signal output.	Same as above.	b) False "Low" pressure signal can cause ESD.	III	"H <sub>2</sub> " meter display, red "H <sub>2</sub> Low" light on.	Same as above.	
			Zero signal output.	Same as above.	c) WES will ESD.	III	Same as above.	Same as above.	

ORIGINAL PAGE IS  
OF POOR QUALITY

**WES FAILURE MODE AND EFFECT ANALYSIS**  
**6-MAN ADVANCED BREADBOARD WATER ELECTROLYSIS SYSTEM (WES)**  
Refer Drawing 73A490-868 Rev. A

**GENERAL ELECTRIC**

Item No.	Component Title	Component Function	Failure Mode	Hypothetical Failure Mechanism	Effect of Failure	Failure Class	Fault Detection	Fault Isolation	Comments
17-2	Pressure Transducer, 0-500 psig, O <sub>2</sub> Press.	To monitor regulator O <sub>2</sub> pressure and provide high and low ESD signals	High signal output.  Low signal output.  Zero signal output.	Same as 17-1.  Same as 17-1.  Same as 17-1.	Same as 17-1 a).  Same as 17-1 b).  WES will ESD.	III	"O <sub>2</sub> " meter display, red "O <sub>2</sub> High" light on.	Compare P. T. 17-2 readout with 17-5.	
17-3	Pressure Transducer, 0-500 psig, H <sub>2</sub> /H <sub>2</sub> O Press.	To monitor H <sub>2</sub> /H <sub>2</sub> O pressure at module outlet and provide high and low ESD signals.	High signal output.  Low signal output.  Zero signal output.	Same as 17-1.  Same as 17-1.  Same as 17-1.	Same as 17-1 a).  Same as 17-1 b).	III	"O <sub>2</sub> " meter display, red "O <sub>2</sub> Low" light on.  "2 phase" meter display, "2G Low" light on.	Compare P. T. 17-3 readout with P. T.'s 17-1 and 17-5.	
17-4	Pressure Transducer, 0-500 psig, N <sub>2</sub> Dome Press.	To monitor N <sub>2</sub> pressure in module dome and provide low ESD signal.	High signal output.  Low signal output.  Zero signal output.	Same as 17-1.  Same as 17-1.  Same as 17-1.	None.  Same as 17-1 b).  WES will ESD.	III	"N <sub>2</sub> Dome" meter display.	Compare P. T. 17-4 readout with 17-5 with 27-1, 27-2 and 28-7 full open at low N <sub>2</sub> pressure.	
17-5	Pressure Transducer, 0-500 psig, N <sub>2</sub> Base Press.	To monitor N <sub>2</sub> base pressure and provide low ESD signal.	High signal output.  Low signal output.  Zero signal output.	Same as 17-1.  Same as 17-1.  Same as 17-1.	None.  Same as 17-1 b).  WES will ESD.	III	"N <sub>2</sub> Base" meter display, red "N <sub>2</sub> Base Low" light on.	Compare P. T. 17-5 readout with 17-1 and 17-3.	
18-1	Differential Pressure Transducer, ± 15 psid Separator/Pump ΔP	To monitor separator/pump ΔP and provide a low ESD signal.	High signal output.  Low signal output.  Zero signal output.	Failure of internal Electronic component.	None.  False "Low" signal can cause ESD.  WES will ESD.	III	"Separator" meter display.	Check P. T. 18-1 readout when separator 8 is switched on and off. Compare P. T. 18-1 with P. T. 20.	
18-2	Differential Pressure Transducer, ± 15 psid H <sub>2</sub> O Flow Orifice ΔP	To monitor process water flow rate.	High signal output.  Low signal output.  Zero signal output.	Same as 18-1.  Same as 18-1.  Same as 18-1.	None.  None.  None.	III	"Orifice" meter display.	Check P. T. 18-2 readout when separator (8) is switched on and off.	

Table IX

GENERAL  ELECTRICSheet 5 of 11  
Date: 9-20-74

WES FAILURE MODE AND EFFECT ANALYSIS  
6-MAN ADVANCED BREADBOARD WATER ELECTROLYSIS SYSTEM (WES)  
Refer Drawing 73A490-868 Rev. A

Item No.	Component Title	Component Function	Failure Mode	Hypothetical Failure Mechanism	Effect of Failure	Failure Class	Fault Detection	Fault Isolation	Comments
19	Pressure Switch (N.O.)	To monitor makeup pump suction pressure and provide low (switch closes) ESD signal.	Switch fails closed.	Failure of internal component or contamination.	False "low" pressure signal will cause ESD.	III	Red "Makeup H <sub>2</sub> O Low" light is on.	Verify makeup H <sub>2</sub> O supply pressure and check with makeup water pump (4) switched on and off.	No ESD will result with shut-off makeup H <sub>2</sub> O supply line and makeup water pump (Item 4) on.
			Switch fails open.	Same as above.	Low makeup H <sub>2</sub> O supply pressure or clogged makeup H <sub>2</sub> O filter (Item 3) will not be detected.	III	None.		
			External leak.	Seal material set or rupture, loose connection.	No ESD. H <sub>2</sub> O leak to cabin.	III	Visual inspection by crew.		Location of H <sub>2</sub> O drop formation.
20	Differential Pressure Transducer ± 100 psid H <sub>2</sub> O Accumulator ΔP	To monitor water accumulator (P <sub>H<sub>2</sub>O</sub> - P <sub>H<sub>2</sub></sub> ).	High signal output	Same as 18-1.	None.	III	"Accumulator" meter display.	Check P. T. 20 readout when separator (8) is off and P. T. 's 17-1, 17-3 and 17-5 are at same pressure.	Compare P. T. 20 readout with 18-1 with separator (8) on.
			Low signal output.	Same as 18-1.	None.	III	Same as above.		
			Zero signal output.	Same as 18-1.	None.	III	Same as above.		
21	Module Outlet Temp. Sensor	To monitor module H <sub>2</sub> /H <sub>2</sub> O outlet temp. and provide high ESD signal.	High signal output.		False "high" temperature signal can cause ESD.	III	"Mod. Out" meter display.	Check item 20 readout at low module current.	Check item 20 readout at high module current.
			Low or zero signal output.	Broken or burned out resistance element.	High module outlet temperature will not be detected.	III	Same as above.		
22	Combustible Gas Detector	To monitor H <sub>2</sub> leakage from WES to cabin and provide high ESD signal.	High signal output.	Electrical component failure as breakage, overheating, shorts, poor connections.	False "high" H <sub>2</sub> level signal can cause ESD.	III	Red light on CGD meter display is on.	Check other cabin CGD monitors. Recalibrate CGD.	"Malfunction" light on CGD display.
			Low or zero signal output.	Same as above.	H <sub>2</sub> leakage if present would not be detected.	III	CGD meter display.		
			High float reading.	Contamination or H <sub>2</sub> O in flowmeter.	None.	III	Visual inspection by crew.		
23	Dual O <sub>2</sub> and H <sub>2</sub> Flowmeter Assembly	To provide visual display of O <sub>2</sub> and H <sub>2</sub> output flow rate.	Low float reading.	Same as above.	Possible gas leak upstream of flowmeter.	III	Same as above.	Check module current and WES pressures. Tap flowmeter.	Same as above. Check for gas leakage.
			External leakage.	Seal material set, loose connection, glass fracture.	Same as above.	II	Same as above.		
			External leakage.	Seal material set, loose connection, glass fracture.	Same as above.	II	Same as above.		
24	Conductivity Sensor	To monitor the ionic impurity level of process water effluent from deionizer (Item 7) and provide high ESD signal.	High output signal.	Same as 22. Contamination or rupture of sensor cell.	False "high" H <sub>2</sub> O conductivity signal can cause ESD.	III	Conductivity sensor (24) meter display.	Take H <sub>2</sub> O sample thru valve 26-6 and check conductivity. Check module (1) voltage.	Same as above.
			Zero or low output signal.	Same as above.	Possible damage to module (1) cells if makeup H <sub>2</sub> O has high ionic content or if deionizer not serviced regularly.	III	Same as above.		

ORIGINAL PAGE IS OF POOR QUALITY

106

Table IX

## WES FAILURE MODE AND EFFECT ANALYSIS

## 6-MAN ADVANCED BREADBOARD WATER ELECTROLYSIS SYSTEM (WES)

GENERAL ELECTRIC

Sheet 9 of 11  
Date: 9-20-74

Refer Drawing 73A490-86B Rev. A

Item No.	Component Title	Component Function	Failure Mode	Hypothetical Failure Mechanism	Effect of Failure	Failure Class	Fault Detection	Fault Isolation	Comments
25	Coolant H <sub>2</sub> O Flow Switch (N. O.)	To monitor cooling H <sub>2</sub> O flow rate and provide low (switch closes) ESD signal.	Switch fails closed. Switch fails open.	Switch actuator stuck by contamination, failure of internal component. Same as above.	False "Low Flow" signal will cause ESD. Low coolant flow would not be detected by Item 25, but overheating of module would cause ESD by Item 21.	III	Red "Cool Flow Low" light on. Coolant flowmeter (24) display.	Verify coolant H <sub>2</sub> O supply pressure and check with supply on and off.	
26-1	In-Line Relief Valve, H <sub>2</sub> Relief	To provide over-press. relief in the event of a failed-closed H <sub>2</sub> regulator (Item 15).	a) Valve elements stuck closed. b) Valve elements stuck open or internal leakage.	a) Contamination binding elements. b) Same as above. Seat material set or damage.	Dual failure of Items 15 and 26-1 will increase H <sub>2</sub> pressure. WES will ESD. None if H <sub>2</sub> leakage is less than H <sub>2</sub> generation rate. WES will ESD at higher leakage as H <sub>2</sub> pressure falls to N <sub>2</sub> base pressure.	III	H <sub>2</sub> pressure on P. T. 17-1 exceeds high limit.	Red "H <sub>2</sub> High" light on. Bench test 15 and 26-1.	
26-2	In-Line Relief Valve, O <sub>2</sub> Relief	To provide over-press. relief in the event of a failed-closed O <sub>2</sub> regulator (Item 14).	Same as 26-1 a). Same as 26-1 b).	Same as 26-1 a). Same as 26-1 b).	Dual failure of Items 14 and 26-2 will increase O <sub>2</sub> pressure. WES will ESD. None if O <sub>2</sub> leakage is less than O <sub>2</sub> generation rate. WES will ESD at higher leakage as O <sub>2</sub> pressure falls to N <sub>2</sub> base pressure.	III	O <sub>2</sub> pressure on P. T. 17-2 exceeds high limit.	Red "O <sub>2</sub> High" light on. Bench test 14 and 26-2.	
26-3	In-Line Relief Valve, Two-Phase Relief	To provide over-press. relief in the event of a failed-closed and stuck solenoid valve on phase separator/pump (Item 8).	Same as 26-1 a). Same as 26-1 b).	Same as 26-1 a). Same as 26-1 b).	Dual failure of Items 8 and 26-3 will increase H <sub>2</sub> /H <sub>2</sub> O pressure. WES will ESD. H <sub>2</sub> /H <sub>2</sub> O discharge thru dump if leakage less than H <sub>2</sub> generation rate. Excess makeup H <sub>2</sub> O "consumption" and low H <sub>2</sub> output. WES will ESD at higher leakage as 2G pressure falls to H <sub>2</sub> regulator pressure.	III	2G pressure on P. T. 17-3 exceeds high limit.	Red "2G High" light on. Check for H <sub>2</sub> /H <sub>2</sub> O dump.	
26-4	In-Line Relief Valve, N <sub>2</sub> Input to 2G	To provide check when (P <sub>2G</sub> > P <sub>H2</sub> ) and input $\Delta P$ (P <sub>N<sub>2</sub></sub> > P <sub>2G</sub> ) during pressurization and shutdown.	Same as 26-1 a). Same as 26-1 b).	Same as 26-1 a). Same as 26-1 b).	Unable to pressurize 2G loop with N <sub>2</sub> for start-up. 2G pressure will decay below N <sub>2</sub> base pressure during WES shutdown. No effect during WES continuous operation.	III	2G pressure on P. T. 17-3 below pressure on P. T. 17-1 by greater difference than 26-9 $\Delta P$ relief setting.	Red "2G Low" light on. Compare 17-3 and 17-1 difference during N <sub>2</sub> pressurization.	
27-1	Manual N <sub>2</sub> Pressure Regulator, N <sub>2</sub> Dome Input.	Manual setting provides N <sub>2</sub> come pressure on module (1).	a) Regul. valve elements fail open. b) Regul. valve elements failed closed.	a) Contamination, valve elements stuck open, spring rupture. b) Contamination, valve elements stuck closed.	No effect during WES operation with valve 28-7 normally closed. Same as above.	III	"N <sub>2</sub> Dome" meter display.	Pressure on P. T. 17-1 will increase with 27-1 backed off and valve 28-7 open.	
						III	Same as above.	Unable to pressurize dome with 28-7 open.	

Table IX

Sheet 10 of 11  
Date: 9-20-74

**WES FAILURE MODE AND EFFECT ANALYSIS**  
**6-MAN ADVANCED BREADBOARD WATER ELECTROLYSIS SYSTEM (WES)**  
**Refer Drawing 73A190-868 Rev. A**

**GENERAL  ELECTRIC**

ORIGINAL PAGE IS

108

Item No.	Component Title	Component Function	Failure Mode	Hypothetical Failure Mechanism	Effect of Failure	Failure Class	Fault Detection	Fault Isolation	Comments
27-2	Manual N <sub>2</sub> Pressure Regulator, N <sub>2</sub> Base Input	Manual setting provides N <sub>2</sub> base pressure to O <sub>2</sub> and H <sub>2</sub> lines.	Same as 27-1 a).  Same as 27-1 b).	Same as 27-1 a).  Same as 27-1 b).	Slow down of N <sub>2</sub> supply pressure to H <sub>2</sub> regulator pressure setting. High "O <sub>2</sub> " and "H <sub>2</sub> " flow readings on item 23. H <sub>2</sub> and O <sub>2</sub> pressure will increase and may cause high pressure ESD.	III	"N <sub>2</sub> Base" meter and O <sub>2</sub> and H <sub>2</sub> flowmeter display. Possible red "H <sub>2</sub> High" light on.	Pressure on P. T. 17-5 will increase with 27-2 backed off. Low N <sub>2</sub> supply pressure.	
28-1	Manual Shut-Off Valve H <sub>2</sub> Regulator Bypass (N. C.)	To provide means for bypassing H <sub>2</sub> regulator to vent H <sub>2</sub> and depressurize WES.	a) Internal leak.  b) External leak.	a) Seat material set or damage.  b) Gland material set or damage. Loose connection.	WES will ESD during normal or cyclic shutdown as N <sub>2</sub> base pressure decays.	III	Pressure on P. T. 17-5 will fall below low limit.	Red "N <sub>2</sub> Base Low" light on. Unable to re-pressurize.	
28-2	Manual Shut-Off Valve O <sub>2</sub> Regulator Bypass (N. C.)	To provide means for bypassing O <sub>2</sub> regulator to vent O <sub>2</sub> and depressurize WES.	Same as 28-1 a).  Same as 28-1 b).	Same as 28-1 a).  Same as 28-1 b).	WES will ESD if O <sub>2</sub> leak exceeds O <sub>2</sub> generation rate or during normal or cyclic shutdown.	III	O <sub>2</sub> pressure on P. T. 17-1 falls below low limit.	Red "O <sub>2</sub> Low" light on. Bench test to verify failure of 28-1, 15, or 26-1.	
28-3	Manual Shut-Off Valve 2Ø Relief Valve By-pass (N. C.)	To provide means for bypassing 2Ø relief to vent H <sub>2</sub> /H <sub>2</sub> O and depressurize WES.	Same as 28-1 a).  Same as 28-1 b).	Same as 28-1 a).  Same as 28-1 b).	WES will ESD if H <sub>2</sub> leak exceeds H <sub>2</sub> generation rate. High makeup H <sub>2</sub> O "consumption".	III	2Ø pressure on P. T. 17-1 falls below low limit.	Red "2Ø Low" light on. Bench test to verify failure of 28-3 or 26-3.	
28-4	Manual Shut-Off Valve, N <sub>2</sub> Input to 2Ø Shut-Off (N. O.)	To provide means of separately pressurizing O <sub>2</sub> side during maintenance only.	External leak.	Gland material set or damage, loose connection.	H <sub>2</sub> leakage to cabin. WES will ESD.	III	Same as 28-1 b).	Red light on CGD (22) is on.	
28-5	Manual Shut-Off Valve, H <sub>2</sub> O Orifice Shut-Off (N. O.)	To provide means of adjusting H <sub>2</sub> O flow on metering valve (30-2).	Same as above.	Same as above.	H <sub>2</sub> O leakage to cabin. No ESD.	III	Visual inspection by crew	Location of H <sub>2</sub> O drop formation.	
28-6	Manual Shut-Off Valve, H <sub>2</sub> O Sample Point (N. C.)	To provide means of extracting process H <sub>2</sub> O sample.	Same as above.	Same as above, or seat material set or damage.	Same as above.	III	Same as above.	Same as above.	
28-7	Manual Shut-Off Valve, Module Dome Shut-Off (N. C.)	To provide means for locking H <sub>2</sub> in dome.	Same as 28-1 a).  Same as 28-1 b).	Same as 28-1 a).  Same as 28-1 b).	N <sub>2</sub> pressure decay on module dome. WES will ESD.	III	Pressure on P. T. 17-4 will fall below low limit.	Red "N <sub>2</sub> Dome Low" light on.	
28-8	Manual Shut-Off Valve, Module Dome Drain Valve (N. C.)	To provide means for venting or draining module dome.	Same as 28-6.	Same as 28-6.	Same as above. N <sub>2</sub> leakage to cabin.	III	Same as above.	Same as above.	
30-1	Needle Valve, Accumulator H <sub>2</sub> O Metering (N. O.)	To provide means of restricting H <sub>2</sub> O flow from accumulator.	Same as 28-5.  Clogged valve.	Same as 28-5.  Contamination.	Same as 28-5.  No makeup H <sub>2</sub> O to process H <sub>2</sub> O loop. WES will ESD.	III	Same as 28-5.	Same as 28-5.	
						III	Separator ΔP on P. T. 18-1 will fall below low limit.	Red "Sep ΔP Low" light on.	

Table IX

Sheet 11 of 11  
Date: 9-20-74

**WES FAILURE MODE AND EFFECT ANALYSIS**  
**6-MAN ADVANCED BREADBOARD WATER ELECTROLYSIS SYSTEM (WES)**  
Refer Drawing 73A490-868 Rev. A

**GENERAL ELECTRIC**


Item No.	Component Title	Component Function	Failure Mode	Hypothetical Failure Mechanism	Effect of Failure	Failure Class	Fault Detection	Fault Isolation	Comments
39-2	Needle Valve, Process H <sub>2</sub> O Metering (N. C.)	To provide means of adjusting H <sub>2</sub> O flow.	Same as 28-1 a).	Same as 28-1 a).	None. Module (1) ΔT may be lower.	III	Orifice meter display for ΔP on P. T. 18-2 may be lower.	Bench check.	
31	Process Water Flow Orifice	To provide means of monitoring process water flow rate.	Partially clogged orifice or screen.	Contamination.	Inadequate process water flow rate will increase module (1) outlet temperature. WES will ESD.	III	Module outlet temperature sensor will exceed high limit.	Red "Mod Temp High" light on.	
32-1	Catalytic O <sub>2</sub> /H <sub>2</sub> Mixture Sensor (O <sub>2</sub> in H <sub>2</sub> )	To monitor presence of O <sub>2</sub> in H <sub>2</sub> output gas.	a) High output signal.  b) Zero or low output signal.  c) External leakage.	Internal electrical failure.  Same as above. Shorted resistive element.  Seal damage. Loose connection.	False O <sub>2</sub> signal would cause ESD of WES.  O <sub>2</sub> in H <sub>2</sub> output possibly caused by module (1) internal leak would go undetected.  H <sub>2</sub> leakage to cabin. WES will ESD.	III	Separator ΔP on P. T. 18-1 will fall below low limit.  "O <sub>2</sub> in H <sub>2</sub> " meter display.  Same as above. Visual inspection by crew.	Red "Sep ΔP Low" light on.  Red "O <sub>2</sub> in H <sub>2</sub> " light on. Check output signal with N <sub>2</sub> gas in H <sub>2</sub> output line.  Meter readout is constant H <sub>2</sub> output temp., unless 22-1 has failed.	
32-2	Catalytic O <sub>2</sub> /H <sub>2</sub> Mixture Sensor (H <sub>2</sub> in O <sub>2</sub> )	To monitor presence of H <sub>2</sub> in O <sub>2</sub> output gas.	Same as 32-1 a).  Same as 32-1 b).  Same as 32-1 c).	Same as 32-1 a).  Same as 32-1 b).  Same as 32-1 c).	False H <sub>2</sub> signal would cause ESD of WES.  H <sub>2</sub> , if present in O <sub>2</sub> discharged to cabin, would result in ESD of WES.  None.	III	"H <sub>2</sub> in O <sub>2</sub> " meter display.  "H <sub>2</sub> in O <sub>2</sub> " meter display. Combustible gas detector (22) would exceed high limit if H <sub>2</sub> in cabin.	Red "H <sub>2</sub> in O <sub>2</sub> " light on. Check output signal with N <sub>2</sub> gas in O <sub>2</sub> output line.  Meter readout is O <sub>2</sub> output temperature unless 32-2 has failed. Red light on CGD is on.	
33	Circuit Breaker (N. C.) 50 amp DC	To prevent excess input current to power conditioner (11).	Contacts stuck closed.  Contacts stuck open.	Welded contacts or spring rupture.  Contamination. Open relay coil.	Unable to manually open 28 VDC input switch. Secondary failure in power conditioner, if causing high current, would probably result in burned out transistor in P. C., and loss of input power to module (11). WES would ESD during O <sub>2</sub> pressure decay at open circuit.  Unable to apply 28 VDC to WES.	III	Green "28 VDC" light remains on. Red "O <sub>2</sub> Low" light on.  Green "28 VDC" light remains off.	Unable to remove 28 VDC input to WES by manual switching of (33).  Unable to apply 28 VDC input to WES by manual switching of (33).	

 ORIGINAL PAGE IS  
OF POOR QUALITY

For Sensor and Display Device  
Item No. Identification and Location  
Refer Table I and Figure 1

TABLE X  
6-MAN WATER ELECTROLYSIS SYSTEM (WES)  
FDIA EMERGENCY SHUTDOWN SUMMARY

Fault Condition	Fault Sensor	Sensor Item No.	Limit Setting*	Limit Hold Period	Inhibit Required	Display Device	Disp. Devel. Item No.	Fault Visual Signal
1. High Module Voltage	Voltage Meter Relay	None	> 24 VDC	Instant	None	0-59 VDC Meter	40	Red Light "On"
2. High Module (P.C. Out) Curr.	Current Shunt	None	> 80 amp	Instant	None	0-100 A Meter	41	Red Light "On"
3. High Power Cond. Input Curr.	100 A Circuit Breaker	33	> 80 Amp	Instant	None	None	-	Red Light "On"
4. Loss 28 VDC Supply Voltage	Voltage Divider	None	< 26 VDC	Instant	Reset	None	-	Green Light "Off"
5. Loss 115 VAC Supply Voltage	Voltage Divider	None	< 100 VAC	Instant	Reset	None	-	Green Light "Off"
6. High Module Outlet Temp.	Temperature Sensor	21	> 220°F	10 Sec.	None	0-250°F Elec. Meter	44	Red Light "On"
7. Low Sep./Pump Press. Rise	ΔP Press. Trans.	18	< 3.5 psid	1 Sec.	Start-up	0-5 VDC Elec. Meter/Sel. Sw.	50	Red Light "On"
8. High Module 2 O Outlet Press.	Press. Trans. 0-500 psig	17-3	*>390 psig	1/4 Sec.	None	0-500 psig Elec. Meter	50	Red Light "On"
9. Low Module 2 O Outlet Press.	Press. Trans. 0-500 psig	17-3	*<350 psig	1 Sec.	Start-up + 5 min timer	0-500 psig Elec. Meter	50	Red Light "On"
10. High O <sub>2</sub> Outlet Press.	Press. Trans. 0-500 psig	17-2	*>412 psig	1/4 Sec.	None	0-500 psig Elec. Meter	48-2	Red Light "On"
11. Low O <sub>2</sub> Outlet Press.	Press. Trans., 0-500 psig	17-2	*<380 psig	1 Sec.	Start-up + 5 min timer	0-500 psig Elec. Meter	48-2	Red Light "On"
12. High H <sub>2</sub> Outlet Press.	Press. Trans. 0-500 psig	17-1	*>380 psig	1/4 Sec.	None	0-500 psig Elec. Meter	48-1	Red Light "On"
13. Low H <sub>2</sub> Outlet Press.	Press. Trans. 0-500 psig	17-1	*<330 psig	1 Sec.	Start-up + 5 min timer	0-500 psig Elec. Meter	48-1	Red Light "On"
14. Empty Water Accumulator	"Empty" Position Switch On	16	Closed Sw.	9 Min.	Start-up	None	-	Red Light "On"
15. Overfilled Water Accum.	"Max Stroke" Posn. Sw. On	16	Closed Sw.	20 Sec.	None	None	-	Red Light "On"
16. Low Coolant Water Flow	Flow Switch	25	<.1 GPM	1 Sec.	None	None	-	Red Light "On"
17. High H <sub>2</sub> Conc. In O <sub>2</sub> Line	Catalytic Temp. Sensor	32-2	>187°F	1 Sec.	None	0-250°F Elec. Meter	44	Red Light "On"
18. Low Makeup H <sub>2</sub> O Inlet Press.	Pressure Switch	19	<.5 psig	30 Sec.	None	None	-	Red Light "On"
19. High Process H <sub>2</sub> O Conductivity	Conductivity Sensor	24	> 5/4 MHO	1 Min.	Start-up	Meter	On (47)	Red Light "On"
20. High H <sub>2</sub> Concentration	Combustible Gas Detector	22	>.5%	Inst.	None	Meter	On (46)	Red Light "On"
21. High O <sub>2</sub> Conc. In H <sub>2</sub> Line	Catalytic Temp. Sensor	32-1	>140°F	1 Sec.	None	0-250°F Elec. Meter	44	Red Light "On"
22. Low Module Dome N <sub>2</sub> Press.	Press. Trans., 0-500 psig	17-4 Pot. Adj.	<400 psig	1 Sec.	None	0-5 VDC Elec. Meter/Sel. Sw.	50	Red Light "On"
23. Low N <sub>2</sub> Base Press.	Press. Trans., 0-500 psig	17-5	<320 psig	15 Sec.	None	0-5 VDC Elec. Meter/Sel. Sw.	50	Red Light "On"

\* Limit Setting With Potentiometer Adjustment

ORIGINAL PAGE IS  
GE POOR QUALITY

## 3.4.2

System Assembly and Check Out

The pre-prototype assembly for the system consisted of a fluid package and control package or cabinet (photographed in Figure 15). The fluid package was made of "Unistrut" aluminum frame with a vertical aluminum panel for mounting the larger fluid components. A commercially available cabinet was selected of a size for mounting all the display components on the front face resulting in a generous interior for mounting electrical control components and circuit boards.

Prior to installation in the fluid package, fluid components were bench tested for proof pressure, leakage, regulated settings, etc. and instruments were checked out as calibrated by vendors or by in-house verification. Some of this component testing is described in Section 3.3. Sections of fluid lines with components were also proof pressure and leak checked as sub-assemblies prior to installation wherever possible.

Initial system testing was conducted at pressures under  $345\text{kN/m}^2$  (50 psig) to check out major functional components such as the power-conditioner/electrolysis module, phase separator/pump, water accumulator and make-up pump. These conditions were also used to verify sensor outputs, automatic startup and shutdown sequence functions and automatic emergency shutdowns.

All major components performed satisfactorily so that most of check out period was occupied with troubleshooting of automatic controls.



## 3.4.3

System Evaluation

The following discussion summarizes in chronological order the conditions experienced and observations made during extensive testing of the advanced WES which commenced in June, 1974. Operating results and test data relating to a specific component have been presented in Section 3.3 and a functional description of components as part of overall system operation is provided in Section 3.2.

Operation of the system at regulated system pressure and temperature was initially performed on June 13, 1974. A load profile versus time showing the temperature transients during warmup is provided in Figure 25. Operation of all pressure regulators, nominally set for a  $690\text{kN/m}^2$  (100 psig) level, and the water temperature regulator was very satisfactory.

Electrical checkout of automatic startup and emergency shutdown functions was sufficiently complete to allow unattended system operation around the clock. Erratic automatic shutdowns in the module overvoltage channel and later in the separator  $\Delta P$  channel, however, interrupted sustained operation. The first was corrected by utilizing isolated voltage sensing with a meter relay in place of the previous electronic-comparator circuit approach. The cause of the latter erratic behavior was found to be sensitivity to 115 VAC noise and load switching on the power line which was subsequently corrected with a commercial noise filter on the input 115 VAC line.

The first week of endurance testing was hampered by false shutdowns as described. However, two weeks of continuous unattended operation was subsequently demonstrated at the nominal  $690\text{kN/m}^2$  (100 psig) system pressure level. Maximum gas generation rate at an electrolysis module load of 75 amperes was sustained for most of the 429 accumulated hours of endurance testing at this pressure.

As shown by Figure 25, a regulated process water temperature of  $339\text{K}$  ( $150^\circ\text{F}$ ) was achieved after warmup resulting in a  $\text{H}_2/\text{H}_2\text{O}$  module outlet temperature of  $431\text{K}$  ( $190^\circ\text{F}$ ). At 75 amp load, module surface temperatures reach about  $344\text{K}$  ( $160^\circ\text{F}$ ). The pressure of trapped nitrogen in the module dome is seen to increase and eventually stabilize with temperature.

Measurement of steady state temperatures at different loads was obtained subsequent to a sustained period at maximum load. This load/temperature profile is shown in Figure 26. Recorded temperatures were not continuous but readings were taken at least six hours after load changes to obtain essentially steady state values. Process water regulated temperature is maintained at about  $339\text{K}$  ( $150^\circ\text{F}$ ) at 50 amps or higher and with electrolysis module  $\Delta T$ , i. e., module  $\text{H}_2/\text{H}_2\text{O}$  out minus module  $\text{H}_2\text{O}$  in, proportional to load. Heat generation rate below 50 amps was not sufficient to maintain a  $339\text{K}$  ( $150^\circ\text{F}$ ) process water temperature; the "hot" port of the temperature regulator is fully open, and system temperatures fall as shown.



The initial 429 hour endurance test period was established at system pressures tabulated in Figures 25 and 26, nominally  $690\text{kN/m}^2$  (100 psig). Subsequently the system was shutdown to adjust pressure regulators, relief valves and a the accumulator return spring for operation at nominally  $1724\text{kN/m}^2$  (250 psig). The load/temperature profile and tabulated pressures are shown in Figure 27. Because phase separator/pump pressure rise had dropped to under  $41\text{kN/m}^2$  (6.0 psid) and reduced process water flow rate, maximum load of 75 amp could not be sustained without module outlet temperature exceeding  $441\text{K}$  ( $200^\circ\text{F}$ ). In addition, a water discharge was observed in the  $\text{H}_2$  outlet flowmeter. Differential pressure gages were added to monitor separator/pump  $\Delta P$  and water flow rate. Also, 1/4 inch diameter translucent nylon tubing was inserted at the separator/pump  $\text{H}_2$  outlet to observe any water discharge.

The phase separator/pump was found to have a loss in  $\Delta P$  with increasing system pressure and a leaky solenoid valve. With the concurrence of Fluid Dynamics Corporation, the manufacturer, it was decided to obtain system performance data at maximum system pressure of 2413 to  $2760\text{kN/m}^2$  (350 to 400 psig) before returning the separator/pump for vendors examination and correction. This would identify any other component difficulty at design pressure level before suffering the extended downtime expected for separator/pump repair.

The pressure regulators, relief valves and water accumulator spring load were adjusted for nominal  $2760\text{kN/m}^2$  (400 psig) system operation. Evaluation of system operation at gradually increasing pressure levels was accomplished by self-pressurization at a 10 amp load (with automatic ESD deactivated) and gradually "bootstrapping" the system with manual control of valves to the following operating pressures  $\text{kN/m}^2$  (psig) at regulated conditions:  $\text{N}_2$  dome, 2896 (420);  $\text{O}_2$  regulator, 2723 (395), module two-phase 2586 (375);  $\text{H}_2$  regulator, 2427 (352) and  $\text{N}_2$  base 2289 (332). Phase separator-pump  $\Delta P$  was found to fall off briskly from 66 to  $31\text{kN/m}^2$  (9.6 to 4.5 psid) with increased line pressure indicating possible deflection of internal components proportional to pressure. Sustained operation of the WES at high pressure was not possible because of sudden loss of pump output due to uncoupling of the magnetic drive. The unit was removed from the system on 9-11-74 and sent to the manufacturer, Fluid Dynamics Corporation, Chester, California for high pressure evaluation and corrective modifications. Further discussion of phase separator/pump performance is included in Para. 3.3.3.

Subsequent to installation of the repaired phase separator/pump on 10-30-74 high pressure system evaluation was resumed. Adjustment of the switch position on the water accumulator and a change in the timing cycle of the make-up pump was required to avoid false "empty" signals. After satisfactory component performance was verified and system automatic startup and shutdown sequences were tested, ESD pressure limits were readjusted for high pressure operation. The ESD limit settings are listed in the FDIA Table X. These limits were verified under actual test conditions where possible with the automatic ESD controls reactivated. "High" limit pressure values could not be demonstrated under actual system operation



because the O<sub>2</sub> and H<sub>2</sub> pressure regulators relieved gas under the fault ESD valve.

System depressurization with ESD controls activated did not allow components such as the phase separator/pump to operate at system pressures below ESD limits. Therefore, expulsion of hydrogen gas (plus water) from the two-phase region was accomplished by venting the fluids through manual valve (Items 28-3, Figure 16) to atmosphere. Subsequent to rapid system depressurization on 11-9-74 because of a leaky seat on the H<sub>2</sub> vent valve (Item 28-1) the water line connecting the outlet of the phase separator/pump and inlet of the deionizer was found to contain resin beads dislodged from the deionizer by pulsating, reverse two-phase flow during depressurization. The deionizer was modified as discussed in Para. 3.3.7 and additional phase separator/pump repair was required because of damage by the resin particles. Also as a corrective measure, an enabling switch was added inside the control cabinet which could correct or interrupt all ESD signals to the controller. The switch enabled component and system operation outside of ESD limits. In particular, it allowed phase separator/pump operation during systems depressurization to vent essentially all entrapped and dissolved hydrogen gas from the two phase region to the hydrogen outlet and simultaneously prevented flow reversal in the process water loop. This switch also permitted low pressure system operation and self-pressurization as previously described up to regulated operating pressures although manual valve adjustments were required for pressure control. Normal system pressurization is accomplished by gradual pressurization with the N<sub>2</sub> manual regulators until all pressures are within design limits with all FDIA lights out. The system can then be activated electrically using the desired push button panel controls.

System operation was resumed on 12-4-74 with development testing concentrated on performing cyclic (orbital) operation at high pressure conditions. System checkout and testing during the normal work day was concentrated on the setting and evaluation of automatic functions for cyclic operation. Overnight, the system was placed on unattended continuous operation to accumulate hours of endurance testing. Electrical trouble shooting during the cyclic evaluation tests revealed that a faulty transistor had caused erratic time functions for cyclic operation and was corrected. The electronic timer was subsequently set to provide a 54.7 minute system powered period and a 40.7 minute standby period. It is not possible at high pressure to hold a period of unpowered electrolysis module without the cyclic consumption of nitrogen to maintain a minimum allowable base pressure on both the oxygen and hydrogen sides. Also, it was learned that the phase separator could not be operated with the module unpowered since the separator would lose pressure differential and the impeller would become noisy (caused by enlargement of the gas core). For these reasons a minimum module load was to be determined by additional testing in the standby mode.

On December 31, 1974 the system was automatically shutdown due to high two-phase pressure which was caused by a faulty hydrogen regulator. Bench check and disassembly of the component revealed a leaky gas bellows apparently cracked from cyclic fatigue. The poppet of the component continuously cycles between an open and closed position as the solenoid valve on the phase separator is energized



cyclically. The frequency, dependent upon gas generation rate, was about 10 cycles per minute at 30 amperes. It was estimated that 400,000 cycles were accumulated to this failure point. A spare bellows assembly and gland for the H<sub>2</sub> regulator was received from Ausco, Incorporated, bench checked, and installed on January 3, 1975. An electrical counter was also installed to measure the number of cycles of solenoid valve operation. Subsequent system operation was satisfactory and evaluation of the cyclic operating mode was resumed.

When the failed hydrogen regulator was disassembled some particles of catalyst material were found inside. Inspection of the upstream catalytic sensor revealed the catalyst material had been eroded away apparently from the impingement of water slugs on the catalyst in the line. A future modification would include a protective screen to reduce erosion and an enlarged fitting to reduce fluid velocity.

During the period of system evaluation from January 3 to January 9, 1975, accumulating 119 hours of module operation under load, 62,703 solenoid valve (on the phase separator) operating cycles were counted for an average rate of 525 cycles/hour. In order to prevent the potential cyclic fatigue of related components it was decided to add a hydrogen differential pressure regulating valve downstream of the solenoid valve. (Refer Figure 16, Item 20). The purpose of this regulating valve is to hold a pressure differential across the phase separator (water outlet pressure minus hydrogen outlet pressure) slightly less than its normal pressure rise when the gas core diameter is controlled by the magnetic pickup and solenoid valve. With this pressure regulator the gas core is slightly larger, such that the magnetic pickup impeller is not rotated by the water vortex and the solenoid valve is energized continuously open to let hydrogen out. An Ausco, Incorporated differential pressure regulator, P/N P321-50, previously used on this program as a water differential pressure regulator (refer to Figure 45 and to Para. 2.3.6) was tried for this purpose. It was necessary to add a small spring on the poppet side of the bellows to increase operating pressure differential to an initial adjusted value of 52.4 kN/m<sup>2</sup> (7.6 psid).

The addition of the differential hydrogen regulator was very successful in almost eliminating solenoid valve cycling except during momentary transient periods of startup, load change, and at times during system pressurization and water priming. It was also found that the previously observed cyclic emission of water slugs out a cycling solenoid valve was essentially eliminated by the use of the differential regulator.

System evaluation continued on parametric testing in the cyclic mode consisting of a 54.7 minute high power period and a 40.7 low power or standby period. A minimum standby electrolysis module current of 6 amperes was established to maintain a small net gas output rate of about 330 SCCM H<sub>2</sub> and 165 SCCM O<sub>2</sub> such that the hydrogen and oxygen pressure regulators would hold minimum pressures above emergency shutdown limits. Pressure regulator settings and ESD limits were accordingly adjusted. A minimum current is required to overcome the relatively higher rate of



5	4	3	2	1																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																									
D				D																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																									
		<b>REVISIONS</b> REV NO. ZONE STA. DESCRIPTION DATE APPROVED 1 10-15-73 11-2-73 J.P.L.																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																											
C	B	A	C	B																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																									
<p><b>NOTES:</b></p> <ol style="list-style-type: none"> <li>1. GATE ITEM NO. 4 - IN RELIEF PRESS., H<sub>2</sub>O RELIEF.</li> <li>2. TEMPERATURE - AMBIENT 40°C TO 100°F., FLUID 30°C TO 80°F.</li> <li>3. PRESSURE - PRESS. 24 PSIG, EUST. 160 PSIS.</li> <li>4. PERFORMANCE (1.6 AT 4.1 TO 10-12 PSIA): TEAR - 220 LB/IN.</li> </ol> <p>CHART - DIFFERENTIAL PRESS. 1.5 TO 2.5 PSI BELOW H<sub>2</sub> PRESS. FULL FLOW - 25 TO 45 MM/H AT 1.5 TO 2.5 PSI BELOW H<sub>2</sub> PRESS, LOWING LINEAR PRESS. VARIATION - 0 TO .47 PSIA.</p> <p>5. MACHINING - LASCO, PBFED, SN---; PORTS. 6. WEIGHT - 1.5 LBS MAX.</p>																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
<table border="1"> <tr> <td>ITEM</td> <td>1</td> <td>2</td> <td>3</td> <td>4</td> <td>5</td> <td>6</td> <td>7</td> <td>8</td> <td>9</td> <td>10</td> <td>11</td> <td>12</td> <td>13</td> <td>14</td> <td>15</td> <td>16</td> <td>17</td> <td>18</td> <td>19</td> <td>20</td> <td>21</td> <td>22</td> <td>23</td> <td>24</td> <td>25</td> <td>26</td> <td>27</td> <td>28</td> <td>29</td> <td>30</td> <td>31</td> <td>32</td> <td>33</td> <td>34</td> <td>35</td> <td>36</td> <td>37</td> <td>38</td> <td>39</td> <td>40</td> <td>41</td> <td>42</td> <td>43</td> <td>44</td> <td>45</td> <td>46</td> <td>47</td> <td>48</td> <td>49</td> <td>50</td> <td>51</td> <td>52</td> <td>53</td> <td>54</td> <td>55</td> <td>56</td> <td>57</td> <td>58</td> <td>59</td> <td>60</td> <td>61</td> <td>62</td> <td>63</td> <td>64</td> <td>65</td> <td>66</td> <td>67</td> <td>68</td> <td>69</td> <td>70</td> <td>71</td> <td>72</td> <td>73</td> <td>74</td> <td>75</td> <td>76</td> <td>77</td> <td>78</td> <td>79</td> <td>80</td> <td>81</td> <td>82</td> <td>83</td> <td>84</td> <td>85</td> <td>86</td> <td>87</td> <td>88</td> <td>89</td> <td>90</td> <td>91</td> <td>92</td> <td>93</td> <td>94</td> <td>95</td> <td>96</td> <td>97</td> <td>98</td> <td>99</td> <td>100</td> <td>101</td> <td>102</td> <td>103</td> <td>104</td> <td>105</td> <td>106</td> <td>107</td> <td>108</td> <td>109</td> <td>110</td> <td>111</td> <td>112</td> <td>113</td> <td>114</td> <td>115</td> <td>116</td> <td>117</td> <td>118</td> <td>119</td> <td>120</td> <td>121</td> <td>122</td> <td>123</td> <td>124</td> <td>125</td> <td>126</td> <td>127</td> <td>128</td> <td>129</td> <td>130</td> <td>131</td> <td>132</td> <td>133</td> <td>134</td> <td>135</td> <td>136</td> <td>137</td> <td>138</td> <td>139</td> <td>140</td> <td>141</td> <td>142</td> <td>143</td> <td>144</td> <td>145</td> <td>146</td> <td>147</td> <td>148</td> <td>149</td> <td>150</td> <td>151</td> <td>152</td> <td>153</td> <td>154</td> <td>155</td> <td>156</td> <td>157</td> <td>158</td> <td>159</td> <td>160</td> <td>161</td> <td>162</td> <td>163</td> <td>164</td> <td>165</td> <td>166</td> <td>167</td> <td>168</td> <td>169</td> <td>170</td> <td>171</td> <td>172</td> <td>173</td> <td>174</td> <td>175</td> <td>176</td> <td>177</td> <td>178</td> <td>179</td> <td>180</td> <td>181</td> <td>182</td> <td>183</td> <td>184</td> <td>185</td> <td>186</td> <td>187</td> <td>188</td> <td>189</td> <td>190</td> <td>191</td> <td>192</td> <td>193</td> <td>194</td> <td>195</td> <td>196</td> <td>197</td> <td>198</td> <td>199</td> <td>200</td> <td>201</td> <td>202</td> <td>203</td> <td>204</td> <td>205</td> <td>206</td> <td>207</td> <td>208</td> <td>209</td> <td>210</td> <td>211</td> <td>212</td> <td>213</td> <td>214</td> <td>215</td> <td>216</td> <td>217</td> <td>218</td> <td>219</td> <td>220</td> <td>221</td> <td>222</td> <td>223</td> <td>224</td> <td>225</td> <td>226</td> <td>227</td> <td>228</td> <td>229</td> <td>230</td> <td>231</td> <td>232</td> <td>233</td> <td>234</td> <td>235</td> <td>236</td> <td>237</td> <td>238</td> <td>239</td> <td>240</td> <td>241</td> <td>242</td> <td>243</td> <td>244</td> <td>245</td> <td>246</td> <td>247</td> <td>248</td> <td>249</td> <td>250</td> <td>251</td> <td>252</td> <td>253</td> <td>254</td> <td>255</td> <td>256</td> <td>257</td> <td>258</td> <td>259</td> <td>260</td> <td>261</td> <td>262</td> <td>263</td> <td>264</td> <td>265</td> <td>266</td> <td>267</td> <td>268</td> <td>269</td> <td>270</td> <td>271</td> <td>272</td> <td>273</td> <td>274</td> <td>275</td> <td>276</td> <td>277</td> <td>278</td> <td>279</td> <td>280</td> <td>281</td> <td>282</td> <td>283</td> <td>284</td> <td>285</td> <td>286</td> <td>287</td> <td>288</td> <td>289</td> <td>290</td> <td>291</td> <td>292</td> <td>293</td> <td>294</td> <td>295</td> <td>296</td> <td>297</td> <td>298</td> <td>299</td> <td>300</td> <td>301</td> <td>302</td> <td>303</td> <td>304</td> <td>305</td> <td>306</td> <td>307</td> <td>308</td> <td>309</td> <td>310</td> <td>311</td> <td>312</td> <td>313</td> <td>314</td> <td>315</td> <td>316</td> <td>317</td> <td>318</td> <td>319</td> <td>320</td> <td>321</td> <td>322</td> <td>323</td> <td>324</td> <td>325</td> <td>326</td> <td>327</td> <td>328</td> <td>329</td> <td>330</td> <td>331</td> <td>332</td> <td>333</td> <td>334</td> <td>335</td> <td>336</td> <td>337</td> <td>338</td> <td>339</td> <td>340</td> <td>341</td> <td>342</td> <td>343</td> <td>344</td> <td>345</td> <td>346</td> <td>347</td> <td>348</td> <td>349</td> <td>350</td> <td>351</td> <td>352</td> <td>353</td> <td>354</td> <td>355</td> <td>356</td> <td>357</td> <td>358</td> <td>359</td> <td>360</td> <td>361</td> <td>362</td> <td>363</td> <td>364</td> <td>365</td> <td>366</td> <td>367</td> <td>368</td> <td>369</td> <td>370</td> <td>371</td> <td>372</td> <td>373</td> <td>374</td> <td>375</td> <td>376</td> <td>377</td> <td>378</td> <td>379</td> <td>380</td> <td>381</td> <td>382</td> <td>383</td> <td>384</td> <td>385</td> <td>386</td> <td>387</td> <td>388</td> <td>389</td> <td>390</td> <td>391</td> <td>392</td> <td>393</td> <td>394</td> <td>395</td> <td>396</td> <td>397</td> <td>398</td> <td>399</td> <td>400</td> <td>401</td> <td>402</td> <td>403</td> <td>404</td> <td>405</td> <td>406</td> <td>407</td> <td>408</td> <td>409</td> <td>410</td> <td>411</td> <td>412</td> <td>413</td> <td>414</td> <td>415</td> <td>416</td> <td>417</td> <td>418</td> <td>419</td> <td>420</td> <td>421</td> <td>422</td> <td>423</td> <td>424</td> <td>425</td> <td>426</td> <td>427</td> <td>428</td> <td>429</td> <td>430</td> <td>431</td> <td>432</td> <td>433</td> <td>434</td> <td>435</td> <td>436</td> <td>437</td> <td>438</td> <td>439</td> <td>440</td> <td>441</td> <td>442</td> <td>443</td> <td>444</td> <td>445</td> <td>446</td> <td>447</td> <td>448</td> <td>449</td> <td>450</td> <td>451</td> <td>452</td> <td>453</td> <td>454</td> <td>455</td> <td>456</td> <td>457</td> <td>458</td> <td>459</td> <td>460</td> <td>461</td> <td>462</td> <td>463</td> <td>464</td> <td>465</td> <td>466</td> <td>467</td> <td>468</td> <td>469</td> <td>470</td> <td>471</td> <td>472</td> <td>473</td> <td>474</td> <td>475</td> <td>476</td> <td>477</td> <td>478</td> <td>479</td> <td>480</td> <td>481</td> <td>482</td> <td>483</td> <td>484</td> <td>485</td> <td>486</td> <td>487</td> <td>488</td> <td>489</td> <td>490</td> <td>491</td> <td>492</td> <td>493</td> <td>494</td> <td>495</td> <td>496</td> <td>497</td> <td>498</td> <td>499</td> <td>500</td> <td>501</td> <td>502</td> <td>503</td> <td>504</td> <td>505</td> <td>506</td> <td>507</td> <td>508</td> <td>509</td> <td>510</td> <td>511</td> <td>512</td> <td>513</td> <td>514</td> <td>515</td> <td>516</td> <td>517</td> <td>518</td> <td>519</td> <td>520</td> <td>521</td> <td>522</td> <td>523</td> <td>524</td> <td>525</td> <td>526</td> <td>527</td> <td>528</td> <td>529</td> <td>530</td> <td>531</td> <td>532</td> <td>533</td> <td>534</td> <td>535</td> <td>536</td> <td>537</td> <td>538</td> <td>539</td> <td>540</td> <td>541</td> <td>542</td> <td>543</td> <td>544</td> <td>545</td> <td>546</td> <td>547</td> <td>548</td> <td>549</td> <td>550</td> <td>551</td> <td>552</td> <td>553</td> <td>554</td> <td>555</td> <td>556</td> <td>557</td> <td>558</td> <td>559</td> <td>560</td> <td>561</td> <td>562</td> <td>563</td> <td>564</td> <td>565</td> <td>566</td> <td>567</td> <td>568</td> <td>569</td> <td>570</td> <td>571</td> <td>572</td> <td>573</td> <td>574</td> <td>575</td> <td>576</td> <td>577</td> <td>578</td> <td>579</td> <td>580</td> <td>581</td> <td>582</td> <td>583</td> <td>584</td> <td>585</td> <td>586</td> <td>587</td> <td>588</td> <td>589</td> <td>590</td> <td>591</td> <td>592</td> <td>593</td> <td>594</td> <td>595</td> <td>596</td> <td>597</td> <td>598</td> <td>599</td> <td>600</td> <td>601</td> <td>602</td> <td>603</td> <td>604</td> <td>605</td> <td>606</td> <td>607</td> <td>608</td> <td>609</td> <td>610</td> <td>611</td> <td>612</td> <td>613</td> <td>614</td> <td>615</td> <td>616</td> <td>617</td> <td>618</td> <td>619</td> <td>620</td> <td>621</td> <td>622</td> <td>623</td> <td>624</td> <td>625</td> <td>626</td> <td>627</td> <td>628</td> <td>629</td> <td>630</td> <td>631</td> <td>632</td> <td>633</td> <td>634</td> <td>635</td> <td>636</td> <td>637</td> <td>638</td> <td>639</td> <td>640</td> <td>641</td> <td>642</td> <td>643</td> <td>644</td> <td>645</td> <td>646</td> <td>647</td> <td>648</td> <td>649</td> <td>650</td> <td>651</td> <td>652</td> <td>653</td> <td>654</td> <td>655</td> <td>656</td> <td>657</td> <td>658</td> <td>659</td> <td>660</td> <td>661</td> <td>662</td> <td>663</td> <td>664</td> <td>665</td> <td>666</td> <td>667</td> <td>668</td> <td>669</td> <td>670</td> <td>671</td> <td>672</td> <td>673</td> <td>674</td> <td>675</td> <td>676</td> <td>677</td> <td>678</td> <td>679</td> <td>680</td> <td>681</td> <td>682</td> <td>683</td> <td>684</td> <td>685</td> <td>686</td> <td>687</td> <td>688</td> <td>689</td> <td>690</td> <td>691</td> <td>692</td> <td>693</td> <td>694</td> <td>695</td> <td>696</td> <td>697</td> <td>698</td> <td>699</td> <td>700</td> <td>701</td> <td>702</td> <td>703</td> <td>704</td> <td>705</td> <td>706</td> <td>707</td> <td>708</td> <td>709</td> <td>710</td> <td>711</td> <td>712</td> <td>713</td> <td>714</td> <td>715</td> <td>716</td> <td>717</td> <td>718</td> <td>719</td> <td>720</td> <td>721</td> <td>722</td> <td>723</td> <td>724</td> <td>725</td> <td>726</td> <td>727</td> <td>728</td> <td>729</td> <td>730</td> <td>731</td> <td>732</td> <td>733</td> <td>734</td> <td>735</td> <td>736</td> <td>737</td> <td>738</td> <td>739</td> <td>740</td> <td>741</td> <td>742</td> <td>743</td> <td>744</td> <td>745</td> <td>746</td> <td>747</td> <td>748</td> <td>749</td> <td>750</td> <td>751</td> <td>752</td> <td>753</td> <td>754</td> <td>755</td> <td>756</td> <td>757</td> <td>758</td> <td>759</td> <td>760</td> <td>761</td> <td>762</td> <td>763</td> <td>764</td> <td>765</td> <td>766</td> <td>767</td> <td>768</td> <td>769</td> <td>770</td> <td>771</td> <td>772</td> <td>773</td> <td>774</td> <td>775</td> <td>776</td> <td>777</td> <td>778</td> <td>779</td> <td>780</td> <td>781</td> <td>782</td> <td>783</td> <td>784</td> <td>785</td> <td>786</td> <td>787</td> <td>788</td> <td>789</td> <td>790</td> <td>791</td> <td>792</td> <td>793</td> <td>794</td> <td>795</td> <td>796</td> <td>797</td> <td>798</td> <td>799</td> <td>800</td> <td>801</td> <td>802</td> <td>803</td> <td>804</td> <td>805</td> <td>806</td> <td>807</td> <td>808</td> <td>809</td> <td>810</td> <td>811</td> <td>812</td> <td>813</td> <td>814</td> <td>815</td> <td>816</td> <td>817</td> <td>818</td> <td>819</td> <td>820</td> <td>821</td> <td>822</td> <td>823</td> <td>824</td> <td>825</td> <td>826</td> <td>827</td> <td>828</td> <td>829</td> <td>830</td> <td>831</td> <td>832</td> <td>833</td> <td>834</td> <td>835</td> <td>836</td> <td>837</td> <td>838</td> <td>839</td> <td>840</td> <td>841</td> <td>842</td> <td>843</td> <td>844</td> <td>845</td> <td>846</td> <td>847</td> <td>848</td> <td>849</td> <td>850</td> <td>851</td> <td>852</td> <td>853</td> <td>854</td> <td>855</td> <td>856</td> <td>857</td> <td>858</td> <td>859</td> <td>860</td> <td>861</td> <td>862</td> <td>863</td> <td>864</td> <td>865</td> <td>866</td> <td>867</td> <td>868</td> <td>869</td> <td>870</td> <td>871</td> <td>872</td> <td>873</td> <td>874</td> <td>875</td> <td>876</td> <td>877</td> <td>878</td> <td>879</td> <td>880</td> <td>881</td> <td>882</td> <td>883</td> <td>884</td> <td>885</td> <td>886</td> <td>887</td> <td>888</td> <td>889</td> <td>890</td> <td>891</td> <td>892</td> <td>893</td> <td>894</td> <td>895</td> <td>896</td> <td>897</td> <td>898</td> <td>899</td> <td>900</td> <td>901</td> <td>902</td> <td>903</td> <td>904</td> <td>905</td> <td>906</td> <td>907</td> <td>908</td> <td>909</td> <td>910</td> <td>911</td> <td>912</td> <td>913</td> <td>914</td> <td>915</td> <td>916</td> <td>917</td> <td>918</td> <td>919</td> <td>920</td> <td>921</td> <td>922</td> <td>923</td> <td>924</td> <td>925</td> <td>926</td> <td>927</td> <td>928</td> <td>929</td> <td>930</td> <td>931</td> <td>932</td> <td>933</td> <td>934</td> <td>935</td> <td>936</td> <td>937</td> <td>938</td> <td>939</td> <td>940</td> <td>941</td> <td>942</td> <td>943</td> <td>944</td> <td>945</td> <td>946</td> <td>947</td> <td>948</td> <td>949</td> <td>950</td> <td>951</td> <td>952</td> <td>953</td> <td>954</td> <td>955</td> <td>956</td> <td>957</td> <td>958</td> <td>959</td> <td>960</td> <td>961</td> <td>962</td> <td>963</td> <td>964</td> <td>965</td> <td>966</td> <td>967</td> <td>968</td> <td>969</td> <td>970</td> <td>971</td> <td>972</td> <td>973</td> <td>974</td> <td>975</td> <td>976</td> <td>977</td> <td>978</td> <td>979</td> <td>980</td> <td>981</td> <td>982</td> <td>983</td> <td>984</td> <td>985</td> <td>986</td> <td>987</td> <td>988</td> <td>989</td> <td>990</td> <td>991</td> <td>992</td> <td>993</td> <td>994</td> <td>995</td> <td>996</td> <td>997</td> <td>998</td> <td>999</td> <td>1000</td> </tr> </table> <p><b>SECTION A-A</b></p> <p>CK SIZE</p> <p>UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES ON FRACTIONS DECIMALS ANGLES ± .003 ± .010 ± 1°</p> <p>NEXT ASSY USED ON APPLICATION</p> <p>CONTRACT NO.</p> <p>DRAWN BY E. MARSH CHECKED DATE 11-2-73</p> <p>ENG'D APPROVED</p> <p>SIZE CODE IDENT NO. 3 06239 P321-50 REV A</p> <p>SCALE FULL SHEET 1 OF 1</p> <p>AUSCO, INC. 820 PINE WASHINGTON BLVD. POINT WASHINGTON N.Y. 10803</p> <p>VALVE, RELIEF, DIFFERENTIAL PRESSURE</p>					ITEM	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100	101	102	103	104	105	106	107	108	109	110	111	112	113	114	115	116	117	118	119	120	121	122	123	124	125	126	127	128	129	130	131	132	133	134	135	136	137	138	139	140	141	142	143	144	145	146	147	148	149	150	151	152	153	154	155	156	157	158	159	160	161	162	163	164	165	166	167	168	169	170	171	172	173	174	175	176	177	178	179	180	181	182	183	184	185	186	187	188	189	190	191	192	193	194	195	196	197	198	199	200	201	202	203	204	205	206	207	208	209	210	211	212	213	214	215	216	217	218	219	220	221	222	223	224	225	226	227	228	229	230	231	232	233	234	235	236	237	238	239	240	241	242	243	244	245	246	247	248	249	250	251	252	253	254	255	256	257	258	259	260	261	262	263	264	265	266	267	268	269	270	271	272	273	274	275	276	277	278	279	280	281	282	283	284	285	286	287	288	289	290	291	292	293	294	295	296	297	298	299	300	301	302	303	304	305	306	307	308	309	310	311	312	313	314	315	316	317	318	319	320	321	322	323	324	325	326	327	328	329	330	331	332	333	334	335	336	337	338	339	340	341	342	343	344	345	346	347	348	349	350	351	352	353	354	355	356	357	358	359	360	361	362	363	364	365	366	367	368	369	370	371	372	373	374	375	376	377	378	379	380	381	382	383	384	385	386	387	388	389	390	391	392	393	394	395	396	397	398	399	400	401	402	403	404	405	406	407	408	409	410	411	412	413	414	415	416	417	418	419	420	421	422	423	424	425	426	427	428	429	430	431	432	433	434	435	436	437	438	439	440	441	442	443	444	445	446	447	448	449	450	451	452	453	454	455	456	457	458	459	460	461	462	463	464	465	466	467	468	469	470	471	472	473	474	475	476	477	478	479	480	481	482	483	484	485	486	487	488	489	490	491	492	493	494	495	496	497	498	499	500	501	502	503	504	505	506	507	508	509	510	511	512	513	514	515	516	517	518	519	520	521	522	523	524	525	526	527	528	529	530	531	532	533	534	535	536	537	538	539	540	541	542	543	544	545	546	547	548	549	550	551	552	553	554	555	556	557	558	559	560	561	562	563	564	565	566	567	568	569	570	571	572	573	574	575	576	577	578	579	580	581	582	583	584	585	586	587	588	589	590	591	592	593	594	595	596	597	598	599	600	601	602	603	604	605	606	607	608	609	610	611	612	613	614	615	616	617	618	619	620	621	622	623	624	625	626	627	628	629	630	631	632	633	634	635	636	637	638	639	640	641	642	643	644	645	646	647	648	649	650	651	652	653	654	655	656	657	658	659	660	661	662	663	664	665	666	667	668	669	670	671	672	673	674	675	676	677	678	679	680	681	682	683	684	685	686	687	688	689	690	691	692	693	694	695	696	697	698	699	700	701	702	703	704	705	706	707	708	709	710	711	712	713	714	715	716	717	718	719	720	721	722	723	724	725	726	727	728	729	730	731	732	733	734	735	736	737	738	739	740	741	742	743	744	745	746	747	748	749	750	751	752	753	754	755	756	757	758	759	760	761	762	763	764	765	766	767	768	769	770	771	772	773	774	775	776	777	778	779	780	781	782	783	784	785	786	787	788	789	790	791	792	793	794	795	796	797	798	799	800	801	802	803	804	805	806	807	808	809	810	811	812	813	814	815	816	817	818	819	820	821	822	823	824	825	826	827	828	829	830	831	832	833	834	835	836	837	838	839	840	841	842	843	844	845	846	847	848	849	850	851	852	853	854	855	856	857	858	859	860	861	862	863	864	865	866	867	868	869	870	871	872	873	874	875	876	877	878	879	880	881	882	883	884	885	886	887	888	889	890	891	892	893	894	895	896	897	898	899	900	901	902	903	904	905	906	907	908	909	910	911	912	913	914	915	916	917	918	919	920	921	922	923	924	925	926	927	928	929	930	931	932	933	934	935	936	937	938	939	940	941	942	943	944	945	946	947	948	949	950	951	952	953	954	955	956	957	958	959	960	961	962	963	964	965	966	967	968	969	970	971	972	973	974	975	976	977	978	979	980	981	982	983	984	985	986	987	988	989	990	991	992	993	994	995	996	997	998	999	1000
ITEM	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100	101	102	103	104	105	106	107	108	109	110	111	112	113	114	115	116	117	118	119	120	121	122	123	124	125	126	127	128	129	130	131	132	133	134	135	136	137	138	139	140	141	142	143	144	145	146	147	148	149	150	151	152	153	154	155	156	157	158	159	160	161	162	163	164	165	166	167	168	169	170	171	172	173	174	175	176	177	178	179	180	181	182	183	184	185	186	187	188	189	190	191	192	193	194	195	196	197	198	199	200	201	202	203	204	205	206	207	208	209	210	211	212	213	214	215	216	217	218	219	220	221	222	223	224	225	226	227	228	229	230	231	232	233	234	235	236	237	238	239	240	241	242	243	244	245	246	247	248	249	250	251	252	253	254	255	256	257	258	259	260	261	262	263	264	265	266	267	268	269	270	271	272	273	274	275	276	277	278	279	280	281	282	283	284	285	286	287	288	289	290	291	292	293	294	295	296	297	298	299	300	301	302	303	304	305	306	307	308	309	310	311	312	313	314	315	316	317	318	319	320	321	322	323	324	325	326	327	328	329	330	331	332	333	334	335	336	337	338	339	340	341	342	343	344	345	346	347	348	349	350	351	352	353	354	355	356	357	358	359	360	361	362	363	364	365	366	367	368	369	370	371	372	373	374	375	376	377	378	379	380	381	382	383	384	385	386	387	388	389	390	391	392	393	394	395	396	397	398	399	400	401	402	403	404	405	406	407	408	409	410	411	412	413	414	415	416	417	418	419	420	421	422	423	424	425	426	427	428	429	430	431	432	433	434	435	436	437	438	439	440	441	442	443	444	445	446	447	448	449	450	451	452	453	454	455	456	457	458	459	460	461	462	463	464	465	466	467	468	469	470	471	472	473	474	475	476	477	478	479	480	481	482	483	484	485	486	487	488	489	490	491	492	493	494	495	496	497	498	499	500	501	502	503	504	505	506	507	508	509	510	511	512	513	514	515	516	517	518	519	520	521	522	523	524	525	526	527	528	529	530	531	532	533	534	535	536	537	538	539	540	541	542	543	544	545	546	547	548	549	550	551	552	553	554	555	556	557	558	559	560	561	562	563	564	565	566	567	568	569	570	571	572	573	574	575	576	577	578	579	580	581	582	583	584	585	586	587	588	589	590	591	592	593	594	595	596	597	598	599	600	601	602	603	604	605	606	607	608	609	610	611	612	613	614	615	616	617	618	619	620	621	622	623	624	625	626	627	628	629	630	631	632	633	634	635	636	637	638	639	640	641	642	643	644	645	646	647	648	649	650	651	652	653	654	655	656	657	658	659	660	661	662	663	664	665	666	667	668	669	670	671	672	673	674	675	676	677	678	679	680	681	682	683	684	685	686	687	688	689	690	691	692	693	694	695	696	697	698	699	700	701	702	703	704	705	706	707	708	709	710	711	712	713	714	715	716	717	718	719	720	721	722	723	724	725	726	727	728	729	730	731	732	733	734	735	736	737	738	739	740	741	742	743	744	745	746	747	748	749	750	751	752	753	754	755	756	757	758	759	760	761	762	763	764	765	766	767	768	769	770	771	772	773	774	775	776	777	778	779	780	781	782	783	784	785	786	787	788	789	790	791	792	793	794	795	796	797	798	799	800	801	802	803	804	805	806	807	808	809	810	811	812	813	814	815	816	817	818	819	820	821	822	823	824	825	826	827	828	829	830	831	832	833	834	835	836	837	838	839	840	841	842	843	844	845	846	847	848	849	850	851	852	853	854	855	856	857	858	859	860	861	862	863	864	865	866	867	868	869	870	871	872	873	874	875	876	877	878	879	880	881	882	883	884	885	886	887	888	889	890	891	892	893	894	895	896	897	898	899	900	901	902	903	904	905	906	907	908	909	910	911	912	913	914	915	916	917	918	919	920	921	922	923	924	925	926	927	928	929	930	931	932	933	934	935	936	937	938	939	940	941	942	943	944	945	946	947	948	949	950	951	952	953	954	955	956	957	958	959	960	961	962	963	964	965	966	967	968	969	970	971	972	973	974	975	976	977	978	979	980	981	982	983	984	985	986	987	988	989	990	991	992	993	994	995	996	997	998	999	1000					

Figure 45.

gas diffusion across the cell SPE membrane at 361 to 367K (190-200°F) as load is abruptly changed from a high power of 50 amperes or greater to the standby value. As the cells of the electrolysis module cool during the low power period a somewhat lower current would be sufficient for a net gas output to prevent pressure decay (when H<sub>2</sub> and O<sub>2</sub> back pressure regulators are closed). During an extended period of system operation of over 200 hours the pressure rise of phase separator/pump gradually diminished from 52.4 to 41.4kN/m<sup>2</sup> (7.6 to about 6.0 psid) which required readjustment of the differential pressure regulator to "hold" the solenoid valve open.

System accumulated gas generation time had now reached 995 hours. Sustained unattended operation at high pressure except for load changes and five differential regulator adjustments described above, was demonstrated for 190 hours from January 22 to January 30, 1975. After 20 hours of continuous operation the system was changed to the cyclic mode demonstrating cyclic load changes between 6 amperes standby current to high power values of 10, 20, 30, 40 and 50 amperes each for extended periods totalling 170 hours without shutdown. Because of the loss phase separator/pump speed and pumping differential it was decided to deactivate the system on January 30, 1975 until the phase separator problem could be investigated and resolved.

On February 10, 1975, functional aspects of the system were demonstrated at various loads and operating modes for a short period prior to system depressurization to remove and disassemble the phase separator/pump. Inspection of the pump revealed that a teflon washer shim between the impeller and housing had been worn and frayed. This was replaced by a 13 mm (.005 inch) thick niobium metallic washer. The separator/pump was then reassembled and bench tested with a pressurized water reservoir up to 2413kN/m<sup>2</sup> (350 psid) and circulated water flow (without two-phase input capability). A pump ΔP of about 62kN/m<sup>2</sup> (9.0 psid) was measured in this set-up. On February 11 the phase separator/pump was reinstalled in the system. Initial system operation at low pressure of approximately 172kN/m<sup>2</sup> (25 psig), revealed a low water flow rate at normal pump ΔP. After removal and bench flow testing of the deionizer the problem was corrected. The added flow impedance was attributed to gas blockage of the deionizer caused by the previous day's depressurization with a closed water metering valve. This dead-ended the inlet line to the deionizer and trapped the gas coming out of solution. Subsequent normal system operation at design pressure and at module load from 10 to 75 amperes was demonstrated at phase separator/pump ΔP of 52kN/m<sup>2</sup> (7.6 psid) and water flow of 90.2kg/hr. (22.5 PPH).

Additional system tests were conducted to determine the variation in phase separator/pump performance which is discussed in Para. 3.3.3.. Phase separator/pump ΔP output remained at 44.8 to 51.7kN/m<sup>2</sup> (6.5 to 7.5 psid) at high line pressure attributable to internal clearance changes. Except for maintaining module current under 50 amp during sustained operating periods to keep outlet temperature under 367K (200F), high pressure system operation was otherwise satisfactory.



In support of preliminary design work on a parallel program for a Life Science WES Demonstrator Unit, continued system testing was used to provide data for electrolysis module and system performance analysis. Also, design approaches for simplifying pressure control, priming and depressurizing techniques were also investigated. From this work a recommendation for the Demonstrator Unit included the use of O<sub>2</sub> and H<sub>2</sub> differential back pressure regulators which would be referenced to the base pressure nitrogen regulator. This modification would allow manual adjustment of a single regulating valve to establish control of both H<sub>2</sub> and O<sub>2</sub> pressures at any desired operating level rather than by pre-adjustment of absolute gas regulators in the current system. Additional tests also verified that the accumulator check valve (Item 2-6) was not a necessary system component and its removal was proposed for the Demonstrator Unit.

Because of a planned change in facility location, the six-man packaged WES was satisfactorily disconnected and transported to the new location. With the availability of services in the new facility on 6-2-75 the packaged system was reconnected and satisfactorily operated at design conditions within two-days time. Subsequently the electrolysis module was removed from the system, as planned, for disassembly, refurbishment, and installation of fluorosilicone cell gaskets to be evaluated. Total accumulated operating time under load was 1077 hours.



SECTION 4.0 HIGH PRESSURE OXYGEN GENERATION4.1 System Analysis

As part of the subject program, design analyses were made for the electrolytic generation of oxygen at up to  $17.24 \text{ MN/m}^2$  (2500 psia) with the basic SPE cell and module configuration for the purpose of providing oxygen for a waste process reaction.

Requirements for the oxygen generator would be that it provide oxygen at a temperature between 283 and 343K ( $50\text{--}140^\circ\text{F}$ ) and at a constant rate of 2.95 kg/day (6.5 lb/day) into a reactor in which pressure normally varies between 14.5 and 15.9  $\text{MN/m}^2$  (2100-2300 psia). The water utilized by the oxygen generator would be supplied at ambient pressure. The high pressure oxygen output control valve would be part of the waste process system. Two separate electrical signal pulses of 5 VDC from the waste process system would be utilized to start and stop the oxygen generator.

Electrolysis cell operating performance at high pressure was derived from development testing of SPE electrolysis cells for oxygen generation at  $20.79 \text{ MN/m}^2$  (3015 psia) and conforming to requirements for a Navy oxygen generating plant under Contract N00024-72-C-5557, Project Serial No. SF0433-104, Task 16670 under Naval Ship Systems Command, Department of the Navy. At a mean cell operating condition of 393K ( $120^\circ\text{F}$ ),  $17.24 \text{ MN/m}^2$  (2500 psia) and at a current density of  $242 \text{ mA/cm}^2$ , it was determined that 12 cells of  $214.2 \text{ cm}^2$  area (same as in 13-cell module of advanced WES) would provide the required oxygen rate of 2.957 kg/day (6.52 lb/day). Process water circulation rate would be 26.1 kg/hr (57.5 lb/hr) for an electrolysis module water inlet temperature of 311K ( $100^\circ\text{F}$ ) and a  $\text{H}_2/\text{H}_2\text{O}$  outlet temperature of 333K ( $140^\circ\text{F}$ ).

This was the operating temperature and the current density demonstrated during most of the life tests on submarine cells operating in the cathode water feed mode. Higher operating temperatures were not found advantageous since higher parasitic losses due to gas diffusion through SPE cells at high pressures offset the reduction in cell operating voltage. Predicted input power to the power conditioner (90% efficiency) and electrolysis module would be 1425 watts whereas, heat rejection from both components would be 672 watts. Consistent input current would be 50.9 amps at a supply voltage of 28 VDC.

The electrolysis module design for  $17.24 \text{ MN/m}^2$  (2500 psia) would be similar in concept to the  $2.86 \text{ MN/m}^2$  (415 psia) design of the advanced WES. That is, the stack of 12 cells would be contained within a dome pressurized with nitrogen to reduce cell gasket differential pressures to about  $690 \text{ kN/m}^2$  (100 psid).



The basic high pressure oxygen generation system schematic is shown in Figure 46. Redundant components for improved reliability and necessary instrumentation for performance monitoring and fault detection are not included for simplification. Functional components are similar to those of the six-man advanced WES (refer to Figure 16) except that differential rather than absolute back pressure regulators are employed for high pressure control and means of system pressurization and depressurization. The process water loop operating conditions of lower temperature and higher pressure have allowed for elimination of the regenerative heat exchanger. This requires operation of the phase separator/pump at about 333K (140°F) and the deionizer at about 311K (100°F) which is considered feasible for both components.

As shown in Figure 46, a hand-loading base pressure regulator is used for manually raising and lowering system operating pressure. O<sub>2</sub> and H<sub>2</sub> differential back pressure regulators and the module dome pressure regulator are referenced to regulated base pressure. It is proposed that the O<sub>2</sub> generator system would be started at low pressure and be self-pressurized by electrolysis at increasing pressure levels as base pressure is adjusted upward to design operating conditions at the following regulated values:

$$\text{N}_2 \text{ Base Regulated Pressure: } P_{\text{N}_2 \text{ BASE}} = 0-16.5 \text{ MN/m}^2 \text{ (0-2400 psia)} \\ (\text{Manually adjusted})$$

$$\text{Hydrogen Regulated Back Pressure: } P_{\text{H}_2} = P_{\text{N}_2 \text{ BASE}} + 345 \text{ kN/m}^2 \\ (50 \text{ psid})$$

$$\text{Oxygen Regulated Back Pressure: } P_{\text{O}_2} = P_{\text{N}_2 \text{ BASE}} + 690 \text{ kN/m}^2 \\ (100 \text{ psid})$$

$$\text{N}_2 \text{ Dome Regulated Pressure: } P_{\text{N}_2 \text{ DOME}} = P_{\text{N}_2 \text{ BASE}} + 1135 \text{ kN/m}^2 \\ (150 \text{ psid})$$

Relief valves are provided for overpressure protection and would back-up FDIA instrumentation with ESD controls. Several manual valves are shown for shut-off and venting capability to completely depressurize the system.

A water temperature regulator controls process water delivered to the deionizer and to the H<sub>2</sub> side of the module at a temperature of 311K (100°F). Two-phase H<sub>2</sub>/H<sub>2</sub>O flow leaves the module at a temperature of 333K (140°F) and is delivered to the phase separator. Because of the high pressure, only a small amount of water vapor is discharged with the hydrogen at this temperature. Water discharged from the phase separator is cooled by the heat exchanger with some by-pass directly to the temperature regulator. A water accumulator, as in the advanced six-man WES, has the dual function of providing logic for make-up water addition and a water storage capacity for load changes. A piston-type make-up pump delivers feed water from ambient supply pressure to the accumulator at a pressure of about 16.9 MN/m<sup>2</sup> (2450 psia). Coolant supplied to the system removes waste heat from the heat exchanger and power conditioner.






Figure 46.—High Pressure Oxygen Generation System



A trade-off study would be required to determine the most feasible means of meeting power, weight, start/stop requirements of a waste process system. Because of a high rate of O<sub>2</sub> and H<sub>2</sub> gas diffusion at high pressure or so-called "fuel celling", gas pressures would drop suddenly if load was removed from the electrolysis module. Either a standby current must be maintained such that a small net O<sub>2</sub> and H<sub>2</sub> gas production is discharged through the back pressure regulators, or as the pressures fall in the electrolysis module, nitrogen would be admitted through the check valves shown in Figure 46, to hold system pressure at regulated N<sub>2</sub> base pressure. For short, frequent down times of the waste process reaction, maintaining a standby load on the O<sub>2</sub> generator sounds feasible whereas for long, infrequent down times, the nitrogen back fill would conserve power with little addition weight for N<sub>2</sub> usage.

It was determined that a standby current of 16 amps would be required to overcome estimated diffusion losses at a module temperature and pressure of 316K (110°F) and 17.2 MN/m<sup>2</sup> (2500 psia). An input power of 386 watts and system heat rejection of 375 watts would be required to maintain this condition. Some O<sub>2</sub> output valve control would be necessary to dump or by-pass the small amount of oxygen discharged from the O<sub>2</sub> generator.

Complete removal of current from the electrolysis module would result in nitrogen at 16.5 MN/m<sup>2</sup> (2400 psia) replacing essentially all oxygen and the equivalent stoichiometric amount of hydrogen which are gradually combined to form water by diffusion at the electrodes in the SPE cells. It was calculated that a total quantity of 4.54 kg (10 lb) of nitrogen would be used for 100 system shutdowns. This nitrogen would necessarily be purged overboard with the generated O<sub>2</sub> and H<sub>2</sub> for a sufficient period of time after restarting to eliminate this diluent from oxygen delivered to the waste process reactor. Assuming three complete system changes which include N<sub>2</sub> pressurization of the module dome, the total nitrogen requirement would be 7.5 kg (16.5 lb). The gas bottle volume requirement for initial storage at 41.3 MN/m<sup>2</sup> (6000 psia) and use at 16.5 MN/m<sup>2</sup> (2400 psia) would be 26.4 liters (0.932 ft<sup>3</sup>) equivalent to a sphere having an inside diameter of 36.9 cm (14.5 inch).

#### 4.2

#### Component Design

Because cell design would be identical to and the stack assembly of 12 cells would closely approximate the 13-cell advanced module configuration, only the enclosure plate and domed enclosure would require redesign for higher pressure. Conditions of maximum operating pressure of 17.9 MN/m<sup>2</sup> (2600 psia), a proof pressure (1.5 X) of 26.9 MN/m<sup>2</sup> (3900 psia), and a burst pressure (2.5 X) 44.8 MN/m<sup>2</sup> (6500 psia) were applied for module design stress analysis. The following modifications would apply to the module design shown in Figure 22. The bottom enclosure plate would consist of 7075S-T6 aluminum, 5.08 cm (2.00 inch) thick utilizing type 316 stainless steel inserts for fluid porting and corrosion resistance. The lower module operating temperature permits the use of this design approach and use of this high



strength aluminum to reduce weight. The elliptical dome of the module is made of 2024-T6 aluminum with a wall thickness of 1.42 cm (0.56 inch) and having a flange thickness of 3.8 cm (1.50 inch). The diameter of the flange and enclosure plate have been increased from 33 to 37.4 cm to accomodate these larger dimensions and larger flange bolts. Twenty-four flange bolts 9/16-18 thread are specified by MS9738 (17-4 Ph), precipitation hardened stainless steel. The estimated weight of this 12-cell  $17.24 \text{ MN/m}^2$  (2500 psia) module design, is 41 kg (90.5 lb).

The water accumulator design shown in Figure 34, which incorporates an external actuating rod was found not feasible for much higher pressures because of imbalance forces. A modified design concept would include an internal stainless steel piston with encapsulated magnets and without a piston rod. Reed-type position switches would be contained in sealed tubes inserted in the end plates of the accumulator. Water capacity was reduced to 164 cc (10 in.<sup>3</sup>) because of elimination of the regenerative heat exchanger in the water process loop and the high operating pressure. Cylinder size would be 7.62 cm (3.00 inch) O.D. x 20.6 cm (8.12 inch) long. Net additional weight over the six-man WES accumulator is 1.4 kg (3.1 lb) to a total new weight of 7.13 kg (15.74 lb).

The phase separator/pump would not change in concept, but would increase in size and weight to provide for a heavier housing to accomodate the higher internal pressure. Estimated weight would be 9.1 kg (20 lb).

Design of a nitrogen bottle for minimum weight considered an ARDEFORM sphere made from cryogenically formed 301 stainless steel shell with external glass filament reinforcing. As fabricated, the steel inner shell is under compression and approaches a zero stress condition at the design operating pressure of  $41.3 \text{ MN/m}^2$  (6000 psia). Design burst pressure (2.5 X) would be  $103 \text{ MN/m}^2$  (15,000 psia). The external fiber structure is of glass filament wound construction with resin cured at 422K (300F). Demonstrated tensile strength at room temperature is  $2275 \text{ MN/m}^2$  (330,000 psi). Design configuration would be a stainless steel shell of 36.9 cm (14.5 inch) inside diameter and wall of 3.19 mm (0.125 inch) surrounded by a fiberglass shell with a wall thickness of 4.19 mm (0.165 inch). This configuration would weigh 19.5 kg (42.9 lb) and hold 12.5 kg (27.5 lb) of nitrogen having a standard volume of 13.4 std. liters (380 SCF).

Gas regulators for differential control at high pressure are commercially available as special equipment for the conditions cited. Contact was made with Tescom Corporation, Minneapolis, Minn., who provided information on the units listed in the following table.



<u>Regulator Name</u>	<u>Tescom P/N</u>	<u>Weight kg</u>	<u>Max Inlet Pressure</u>	<u>Outlet Pressure MN/m<sup>2</sup> (psia)</u>	<u>Max Reference Pressure</u>	<u>Positive Bias Differential kN/m<sup>2</sup> (psid)</u>
N <sub>2</sub> Base Pressure Hand Loader	26-1024-34	2.5	41.4(6000)	.1- 17.2(15-2500)	-	-
N <sub>2</sub> Dome Pressure Reduced W1 Ref.	Similar to 26-1000	2.5	41.4(6000)	Max 17.6(2550)	16.5(2400)	103(150)
O <sub>2</sub> Back Pressure Regulator W1 Ref.	Similar to 26-1700	2.3	17.2(2500)	< 15.8(2300)	16.5(2400)	69(100)
H <sub>2</sub> Back Pressure Regulator W1 Ref.	Similar to 26-1700	2.3	16.9(2450)	< 15.8(2300)	16.5(2400)	34.5(50)



Because of the higher process water flow rate and higher operating pressure than the six-man rated WES, the deionizer would utilize a larger 1000 ml capacity sampling cylinder rated for 24.1 MN/m<sup>2</sup> (3500 psia) operation. Container size would be 8.9 cm (3.5 inch) outside diameter by 29.2 cm (11.5 inch) long, weighing 5.56 kg (12.25 lb).

Pressure rating of the dual heat transfer coil heat exchanger, P/N 3101-6, 4-8-6X, Parker Hannifin Corp., is 18.6 MN/m<sup>2</sup> (2700 psia). Similarly, most standard commercial tube fittings, hand valves, check valves, etc., have pressure ratings greater than 20.7 MN/m<sup>2</sup> (3000 psia) and would be suitable for service in this system.

Major components of a water electrolysis system which are weight sensitive to operating pressure are listed below. A comparison of component weight is provided between that of the six-man rated system at nominal 2.860 MN/m<sup>2</sup> (415 psia) and that of the high pressure O<sub>2</sub> generation system at nominal 17.2 MN/m<sup>2</sup> (2500 psia).

Component Name	Six-Man WES	High Pressure O <sub>2</sub> Gen.
	Weight kg (lb)	
Electrolysis Module	32.9 (72.5)	41.1 (90.5)
Water Accumulator	5.7 (12.7)	7.1 (15.7)
Phase Separator	7.2 (15.8)	9.1 (20.0)
Deionizer	1.5 ( 3.3)	5.6 (12.3)
N <sub>2</sub> Gas Bottle (Empty)	Not Included	19.5 (42.9)
N <sub>2</sub> Gas Bottle (Full)	-	32.0 (70.4)
N <sub>2</sub> Base Pressure Regulator	2.5 ( 5.5)	2.5 ( 5.5)
N <sub>2</sub> Dome Pressure Regulator	2.5 ( 5.5)	2.5 ( 5.5)
O <sub>2</sub> Back Pressure Regulator	0.7 ( 1.5)*	2.3 ( 5.0)
H <sub>2</sub> Back Pressure Regulator	0.7 ( 1.5)*	2.3 ( 5.0)

\* Absolute Back Pressure Regulators designed to specification.

It should be noted that the component weights listed, excepting the N<sub>2</sub> gas bottle, are for commercial off-the-shelf hardware or for preprototype designs without a critical regard for weight and would not be, necessarily, respective of flight-weight designs.



**SECTION 5.0 SPACE STATION PROTOTYPE SUPPORT WORK**

The design of an Oxygen Generation Subsystem as a part of the overall Life Support System for the Space Station Prototype was conducted in parallel with Phase I of this program. As reported, testing of the four-man breadboard WES provided information on component and system characteristics in different operating modes and supplied test data in support of engineering design. After shipment of the packaged Oxygen Generation Subsystem to NASA/JSC in Houston, Texas, in September 1973, consultation by telephone was provided to NASA during its installation and checkout.

During subsystem testing at NASA/JSC on February 19, 1975, the electrolysis module exhibited evidence of internal leakage. The torque of the nuts on the module tie bolts was not checked before the system was tested and this was surmised initially to be the cause of the leakage. The 27-cell electrolysis module was returned to General Electric Co./DECP for failure analysis, refurbishment, and checkout. This work was accomplished and is summarized in a letter report included in the Appendix. The refurbished module, containing 15 of the original 27 cells, was returned to NASA/JSC on March 24, 1975. Satisfactory performance of the electrolysis module and Oxygen Generation Subsystem was subsequently demonstrated over a 100-hour checkout test period.



SECTION 6.0 CONCLUSIONS

- 1) A 13-cell, SPE advanced module design for operation at an average temperature of 355k (180°F), and 2860kN/m<sup>2</sup> (415 psia) conditions was successfully demonstrated in a six-man rated water electrolysis system (WES) over a total operation period of 1060 hours.
- 2) Safe, unattended operation of a six-man rated, advanced pre-prototype WES was demonstrated in continuous and cyclic operating modes at a nominal pressure of 2860kN/m<sup>2</sup> (415 psia). The packaged system included semi-automatic controls for pushbutton start, stop, FDIA instrumentation and emergency controls for a safe emergency shutdown at high pressure.
- 3) A combination water pump/centrifugal phase separator was developed which demonstrated positive separation of hydrogen and water and pumping capability in the six-man advanced WES over a wide range of operating pressures from 172 - 2758kN/m<sup>2</sup> (25 - 400 psia).
- 4) An improved, dual-beaded fluorosilicone rubber gasket system was installed in the cells of the electrolysis module and successfully tested at maximum design operating conditions of 367k (200°F) and 3000kN/m<sup>2</sup> (435 psia).
- 5) A high pressure, catalytic O<sub>2</sub>/H<sub>2</sub> gas mixture sensing device was developed which demonstrated excellent sensitivity for both lean and rich mixtures below and above the flammability limits. This device was installed in both the O<sub>2</sub> and the H<sub>2</sub> output lines of the six-man rated, advanced WES as a fault detection sensor.
- 6) The results of a preliminary design study of a high pressure water electrolysis system are presented for an oxygen generator which would supply oxygen at a rate of 2.95kg/day (6.5 lb/day) and at a pressure of 17.2kN/m<sup>2</sup> (2500 psia) applicable to a waste process system.



SECTION 7.0 RECOMMENDATIONS

- 1) Redesign of the phase separator/pump developed under this program is recommended to provide a larger magnetic coupling and motor and modification of internal parts to eliminate impeller clearance changes caused by deflection at high pressure. Also, a design should be developed which would incorporate a proportionate control on the H<sub>2</sub> gas discharge to eliminate the cyclic pressure pulsations encountered in the initial design.
- 2) Electrolysis module design improvement resulting from incorporation of a beaded fluorosilicone gasket system should be life tested at maximum module outlet operating temperature of 361-367k (190-200°F). Also, the integrity of sealing capability should be evaluated by exercising the gasket system between 0 and 2860kN/m<sup>2</sup> (0-415 psia) reflecting anticipated WES shutdowns for servicing and maintenance.
- 3) Further unattended testing of the advanced pre-prototype system, derated to three-man oxygen output, should be performed in continuous, cyclic, standby and high pressure ESD modes. The purpose of this testing would be to further evaluate component performance, life capability and uncover anomalies requiring possible adjustment or modification in pressure regulator settings, automatic start-stop and ESD controls including setting of timing sequences and FDIA limits. Information from this testing would be applied to improvement in the performance and reliability of components and the system configuration for the Water Electrolysis Demonstrator Unit in the Life Sciences Payload Program.



GENERAL  ELECTRIC

APPENDIX



BASIC SPE WATER ELECTROLYSIS TECHNOLOGY


The electrolyte in the SPE electrolysis concept is a solid plastic sheet or membrane of perfluorinated sulfonic acid polymer about 0.030 cm (0.012 in.) thick, having many of the physical characteristics of Teflon. This polymer, when saturated with water, is an excellent ionic conductor ( $\leq 15$  ohm-cm resistivity) and is the only electrolyte required in the system. There are no free acid or alkaline liquids, with only water as the free liquid. A typical cell is shown in the following illustration. This is a cross-sectional view through the SPE and the attached catalyst structure (or electrodes) on either side of the membrane. Ionic conductivity is provided by the mobility of the hydrated hydrogen ions ( $H^+ \cdot x H_2O$ ). These ions move through the SPE membrane by passing between the fixed sulfonic acid groups.

To reduce the complexity of the water/gas separation techniques, the process water (reactant and coolant) is fed to the hydrogen electrode known as the cathode feed mode. The SPE is sufficiently water permeable to allow water to diffuse from the hydrogen electrode to the oxygen electrode, where it is electrochemically decomposed to provide oxygen, hydrogen ions and electrons. The hydrogen ions move to the hydrogen evolving electrode (cathode) by migrating through the SPE. The electrons pass through the external electrical circuit to reach the hydrogen electrode. At the hydrogen electrode, the hydrogen ions and electrons recombine electrochemically to produce hydrogen gas.

The process water entering the cell is in excess of the amount required for the cell reaction. This excess water functions as the system coolant by transferring the electrolysis cell waste heat to an external system heat exchanger and is recirculated within the system water loop.

The gases are generated at a stoichiometric ratio of hydrogen and oxygen at any pressure required of the system by simply back pressurizing the corresponding gas side. For high pressure operation, e.i. greater than 790 kN/m<sup>2</sup> (115 psia), the cell is enclosed in a pressure vessel and the differential pressure across the SPE is controlled by the system gas regulators.





SPE Electrolysis Cell Schematic

\* Revised  
No.: 73A490-828, Rev. A  
Date: 10/29/73  
Page: 1 of 6

**\*DYNAMIC PHASE SEPARATOR/PUMP ASSEMBLY SPECIFICATION**

\*1.0 **Functional Purpose:** During one GEE and zero GEE operation the dynamic phase separator/pump assembly, in any attitude, shall provide separation of a mixture of hydrogen and liquid water and also provide circulation capability of process water in an electrolysis system for a manned space station application.

1.1 **End Items:** Delivered dynamic phase separator/pump assembly hardware shall be:

- a) One (1) dynamic phase separator/pump with integrally mounted solenoid valve and relief valve.
- b) One (1) separator electronic controller.

\*2.0 **Mechanical Description:** The dynamic phase separator/pump assembly shall consist of an electric motor magnetically coupled to provide rotation to a spin chamber in which centrifugal force will separate liquid and gas phases from a mixture of hydrogen and water and also to provide an impeller for pressure rise with subsequent water circulation. Rotating parts shall be fully self-contained in the event of failure.

In addition, the assembly shall include a speed sensor (i.e., magnetic pickup and impeller) driven by a fluid coupling with the rotating water mass and conditioning electronic logic to open or close a solenoid valve, which is located in the hydrogen outlet. An in-line relief valve shall be connected in parallel at the hydrogen outlet to bypass the normally-closed solenoid valve.

\*3.0 **Weight:** Minimal weight shall be employed in the design of end items consistent with compliance with requirements of this specification. Weight estimates shall be identified on drawings.

\*4.0 **Port Configuration:**

- |  |                   |
|--|-------------------|
| • Hydrogen/water inlet boss                  | MS33649-6         |
| • Hydrogen outlet (one or two to be defined) | 1/4 inch Swagelok |
| • Water out boss (size to be defined)        | MS33649-4 or -6   |

Note: "NPT" pipe threads are not permitted.

\* Revised  
No.: 73A490-828, Rev. A  
Date: 10/29/73  
Page: 2 of 6

\*5.0

Electrical Interfaces and Requirements:

115 VAC  $\pm$  5%, 60 Hz, single phase  
28 VDC  $\pm$  5%,

Available for motor  
Available for control logic and  
solenoid valve operation

Note:

- Minimum power demand of end items shall be provided in the design consistent with requirements herein.
- Suitable Bendix bulkhead male connectors shall be provided on the end items including appropriate mating female connectors.
- The dynamic phase separator/pump assembly shall be designed to be ignition proof, i. e., the assembly or components thereof, shall not be capable of igniting any explosive mixture existing in or surrounding the assembly either functioning or at standstill in accordance with Procedure II, Method 511 of MIL-STD-810B dated 15 June 1967. The separator electronic controller is permitted to be "breadboarded" however, without potting compounds and need not be considered "explosion proof".
- The dynamic phase separator/pump assembly shall be designed with electromagnetic interference (EMI) characteristics (emission and susceptibility) in accordance with Class No. ID equipment of MIL-STD-461A dated 1 August 1968.
- Electrical wiring shall be properly supported and routed to prevent chafing, provide protection against sharp edges, mechanical strain, etc., and conform to MIL-W-16878. Color coding of conductors of the equivalent shall be provided for identification.
- Bonding requirements in accordance with MIL-B-5087 Class H, R and S as applicable.
- The motor and solenoid valve shall be capable of withstanding for one (1) minute a potential of 1000 volts RMS at 60 Hz gradually applied to each connector pin and the case without damage, arcing or breakdown and shall have a minimum insulation resistance of 2 megohms after this dielectric strength test.

\* Revised  
No.: 73A490-828, Rev. A  
Date: 10/29/73  
Page: 3 of 6

\*6.0

Mounting Provisions: Mounting of the dynamic phase separator/pump assembly shall have adequate structural integrity to assure compliance to this specification without mechanical failure or performance deterioration when subjected to:

- Acceleration "hard" environment of Procedure I, Method 513, paragraph 3.2.4 with "Manned Aerospace-Vehicle Category".
- Vibration "hard" environment of Procedure I, Method 514, paragraph 4.5.1, Part 1 (sinusoidal vibration curve "P" and time schedule I) and paragraph 4.5.2 Part 2 (random vibration curve AG), MIL-STD-810B dated 15 June 1967.
- Bench handling shock "hard" environment of Procedure V, Method 516, paragraph 3.7, MIL-STD-810B, dated 15 June 1967.

The mounting configuration of the separator electronic controller shall be designed for securement to a horizontal plate.

The mounting configuration of the dynamic phase separator/pump assembly shall be designed for securement to a cold plate which has cooling water flowing therein to remove heat. The dynamic separator/pump and cold plate will be secured to a vertical panel. The cold plate is not an end item of this specification.

\*7.0

Permissible Materials: In configuration proximity with the water, permissible materials are 316 or 321 AISI stainless steels, Viton "A", Lexan or Teflon. Consideration of other materials will be given when presented to GE/DECP by the vendor. No copper, iron, silver, zinc, cadmium or processes of brazing soldering are allowed in the configuration proximity of the water. Corrosion reduction processes shall be introduced to those surfaces which are in configuration proximity with the water; such as annealing after welding plain 316 SST, passivation of stainless steel and thermoplastic coating surfaces; i. e., fluorinated ethylene polypropylene (FEP) coating a 316 SST spin chamber or similar plastic coating to nickel magnetic slugs of the speed sensor.

Redundant Viton "A" O-ring seals shall be introduced into the design in appropriate regions to assure no external leakage of hydrogen to ambient.

Rub wear materials which could contaminate the delivered water and/or hydrogen or compromise useful life shall be minimized.

Titanium is not permitted in the design.

Lubrication materials are not permitted in the design which could contaminate the water and hydrogen or leak to ambient.

\* Revised  
No.: 73A490-828, Rev. A  
Date: 10/29/73  
Page: 4 of 6

Electroactivity contact of dissimilar metals per MS33586 shall be avoided.

Materials that could liberate toxic gases shall be avoided.

The use of metallic self-locking nuts is the preferred method to secure the assembly detail parts. Lockwire should be considered as an alternate approach. Star washers, jam nuts, lock washers, etc. shall not be used.

Assembly drawing copies with appropriate parts list, material identification and process specification definition shall be submitted to GE/DECP for review.

\*8.0

#### Overall Envelope Dimensions and Spin Chamber Storage Capacity:

Minimum sizing for compatibility to requirements of this specification is required.

Outline installation drawing copies delineating all pertinent details of the end items (e.g., port title and fitting identification, connector identification and pin designation electrical schematic, detail installation and outline dimensions, servicing and acceptance test notes as necessary, rated requirements, etc.) shall be submitted to GE/DECP for review.

\*9.0

#### Performance Requirements

The dynamic phase separator/pump assembly shall be capable of continuous or cyclic operation in any attitude in a one GEE or zero GEE environment with a two (2) phase mixture of saturated hydrogen gas and "sluglet" water at 50 to 100°F (normally 75°F) delivered to the inlet.

Note: A cycle is equivalent to one (1) 94 minute orbit of 55 minutes "on" power and 39 minutes "off" power.

The dynamic phase separator/pump assembly shall reach a sufficient speed of rotation for positive centrifugal separation of gas and liquid delivered to the unit and/or contained therein within 15 seconds of motor energization. The unit shall also be capable of pumping water at the specified rate and pressures within one (1) minute of motor energization.

The dynamic phase separator/pump shall be capable of acceptable functional performance at standstill, startup transient, steady state operation and/or shutdown transient during any attitude within an environment of one GEE or zero GEE and in an environment of 40 to 110°F and 0 to 14.7 psia.

During transient periods of starting and stopping the unit as well as at standstill both gas and liquid may be transferred to or from the cavity between the two-phase inlet port to water outlet port depending on environmental gravity conditions, shifting and circulation of fluids in the two-phase circuit, and gradual consumption of hydrogen by the electrolysis system. The solenoid valve and relief valve must remain closed and unenergized during these periods to prevent any discharge of water through the hydrogen outlet. Also, the inlet passages of these components shall be designed for negligible hold up or transfer of water to the hydrogen outlet during startup.

The dynamic phase separator assembly shall be capable of delivering a water flow of 10 to 30 lb/hr with a pressure rise (from two-phase inlet port to water outlet port) design requirement of 10 psid at 20 lb/hr. Simultaneously it shall provide phase separation and delivery of hydrogen to the hydrogen outlet port at the following conditions:

- The hydrogen content of the two-phase mixture will be delivered to the two-phase inlet port of the unit at a flow rate of 0 to 0.10 lb/hr.
- The hydrogen outlet pressure will be maintained by a downstream back pressure regulator (which is not an end item of this specification) at a selected pressure level adjustable between 100 and 380 psia. The selected pressure level will be regulated from 0 to plus 20 psid respectively, from cracking pressure to full hydrogen flow and with a minimum reseat pressure of minus 20 psid from cracking pressure at zero hydrogen flow.
- The hydrogen/water volumetric mixture ratio can vary from zero to 15.0 coincident with maximum hydrogen flow, minimum water flow and minimum hydrogen outlet pressure.

The dynamic phase separator/pump shall be capable of no external leakage, structural damage or performance deterioration with a proof pressure of 549 psig or no structural damage with a burst pressure of 915 psig.

Acceptable functional performance is defined as:

- No liquid water (e.g., sluglet or mist) is permitted in the hydrogen discharge for any conditions. The hydrogen outlet gas however, will be saturated with water vapor.
- No hydrogen gas is permitted in the water discharge for any conditions.

\* Revised  
No.: 78A490-828, Rev. A  
Date: 10/29/73  
Page: 6 of 6

- Pump pressure-rise capability and flow capacity as mentioned above.
- Minimal power demand (watts) shall be employed in the design consistent with compliance to the requirements of this specification.
- Pressure drop (two phase mixture inlet minus hydrogen outlet) of 2 psid maximum for all flows and pressures with solenoid valve open.
- Integrally mounted in-line relief valve shall have a nominal relieving pressure differential adjustable between 3 and 50 psid (between core pressure and H<sub>2</sub> outlet). Breaking of fluid connections and partial disassembly is permissible for manual adjustment.
- No external leakage of hydrogen or water.

- 10.0 Continuous Mission Rate Duty: Acceptable functional performance as defined in paragraph 9.0 during steady operation for six (6) months.
- 11.0 Cyclic Mission Rate Duty: Acceptable functional performance as defined in paragraph 9.0 during 5514 equivalent orbital cycles of paragraph 9.0.
- 12.0 Reliability: Useful life two (2) years.

## WATER TEMPERATURE REGULATING VALVE SPECIFICATION

- 1.0 \* Functional Purpose: During one GEE and zero GEE operation in any attitude the temperature regulating valve shall establish a constant controlled mixture-out temperature of hot and cold process water which is circulated to a solid polymer electrolyte module for a manned space station application.
- 2.0 Mechanical Description: The water temperature regulating valve consists of a sleeve mixing valve actuated by a sealed eutectic wax actuator which is sensitive to temperature by mixing hot and cold water. The valve shall provide forced flow of the water passed the waxed actuator for optimum heat transfer and sensing characteristics.
- 3.0 Weight: 1.6 lbs. maximum.
- 4.0 Port Configuration: Three ports (cold inlet, hot inlet and controlled mixture outlet) in accordance with MS 33649-6.
- 5.0 Electrical Interfaces: None.
- 6.0 Mounting Provisions: The water temperature regulating valve will be secured at three (3) mounting points.
- 7.0 Permissible Materials: 316, 321, 347, 17-4 PH AISI Stainless Steels; Viton "A" seal material; proprietary eutectic wax mixture.
- 8.0 \* Maximum Overall Envelope Dimensions: 6.00" x 1.52" x 3.00".
- 9.0 Performance Requirements:
- \* With 170 to 200°F water admitted to the "hot-in" port and 50 to 100°F water admitted to the "cold-in" port, the controlled mixture out temperature of the total process water flow (10.0 to 15.0 lb/hr) shall be  $160 \pm 5^{\circ}\text{F}$ . The valve shall be capable of external adjustment of the controlled mixture out temperature within a range of 150 to 170°F.
  - \* Pressure Loss: At 15.0 PPH; less than 0.25 psid.
  - \* Working Fluid: Water with dissolved hydrogen and random gas "sluglets".
  - \* Upstream Pressure: 333 to 373 psig.
- Environment Requirements: 40 to 110°F and 0 to 14.7 psia.
- External Leakage: None.
- \* Proof Pressure: 560 psig.
- \* Burst Pressure: 933 psig.

- 10.0 Continuous Mission Rate Duty: Steady state operation for six (6) months at  $160\pm 5^{\circ}\text{F}$  controlled mixture outlet temperature.
- 11.0 Cyclic Mission Rate Duty: 5514 temperature cycles consisting of a transient rise to  $160\pm 5^{\circ}\text{F}$  controlled mixture out temperature, steady state at  $160\pm 5^{\circ}\text{F}$  55 min., transient decrease to  $75\pm 5^{\circ}\text{F}$  controlled mixture out temperature and then  $75\pm 5^{\circ}\text{F}$  for 39 min.
- 12.0 Reliability: Useful life - two (2) years.

Table IV

\*REVISED

No. 73A490-830, Rev. B  
Date 9/14/73  
Page 1 of 2

\*HYDROGEN ABSOLUTE BACK-PRESSURE REGULATOR SPECIFICATION

- 1.0 Functional Purpose: During one GEE and zero GEE operation in any attitude the regulator shall establish a controlled pressure level on the hydrogen discharge side of a dynamic phase separator/pump in a water electrolysis system for a manned space station application.
- 2.0 Mechanical Description: The hydrogen absolute back-pressure regulator consists of a soft-seated valve actuated by a differential force of "upstream" hydrogen pressure, bellows gradient, compression spring and "downstream" pressure.
- 3.0\* Weight: 1.60 lb. maximum.
- 4.0 Port Configuration: MS 33649-4 inlet and outlet ports.
- 5.0 Electrical Interfaces: None.
- 6.0 Mounting Provisions: In-line tubing installed.
- 7.0\* Permissible Materials: 17-7 PH, 316 AISI Stainless Steels; Viton "A" seal material.
- 8.0\* Maximum Overall Envelope Dimensions: 1.56" dia x 4.40" long.
- 9.0 Performance Requirements:

\* With 50 to 100°F mixture of hydrogen and water vapor supplied to the inlet, the regulator shall crack within and be capable of controlling the upstream pressure to 361 to 381 psia, when passing a 50 to 100°F saturated mixture of 0.0194 to 0.220 lb./hr. of hydrogen independent of the downstream pressure. The regulator shall reseat (shut off hydrogen flow) at 341 psia minimum. The regulator shall be capable of external adjustment of the upstream pressure within a range of 100 to 500 psia.

Working Fluid: Hydrogen and water vapor.

Allowable Leakage Rate: No internal leakage after the reseating condition has been reached; no external leakage. Note: Redundant seals shall be provided for all external hydrogen leak paths except on inlet and outlet "MS" ports.

\* Downstream Working Fluid Pressures: 0 psia minimum; 265 psia maximum for 500 psia upstream pressure; 53 psia maximum for 100 psia upstream pressure; 15.5 psia nominal.

Table IV (Cont'd.)

\*REVISED  
No. 73A490-830, Rev. B  
Date 9/14/73  
Page 2 of 2

- \* Upstream Working Fluid Temperatures: 50°F minimum; 100°F maximum; 75°F nominal.
- \* Proof Pressure: 572 psig maximum.
- \* Burst Pressure: 1000 psig maximum limited by bellows.

Environment Requirements: 40 to 110°F and 0 to 14.7 psia.

- 10.0 Continuous Mission Rate Duty: Steady-state flows for six (6) months varied within a hydrogen range of 0.0194 to 0.220 lb./hr. of 75°F saturated.
- 11.0 Cyclic Mission Rate Duty: 5514 cycles of hydrogen/water vapor flow "on and off", i.e., one cycle equals 55 minutes of 75°F saturated hydrogen "on" flow time at 0.220 lb./hr. and 39 minutes of no flow.
- 12.0 Reliability: Useful life - two (2) years.

Table III

\* REVISED

No. 73A490-831, Rev. B

Date 9/14/73

Page 1 of 2

\* OXYGEN ABSOLUTE BACK-PRESSURE REGULATOR SPECIFICATION

1.0 Functional Purpose: During one GEE and zero GEE operation in any attitude the regulator shall establish a controlled pressure level on the oxygen discharge side of a solid polymer electrolyte module for a manned space station application.

2.0 Mechanical Description: The oxygen absolute back-pressure regulator consists of a soft-seated valve actuated by a differential force of "upstream" oxygen pressure, bellows gradient, compression spring and "downstream" pressure.

3.0 \* Weight: 1.60 lb. maximum.

4.0 Port Configuration: MS 33649-4 inlet and outlet ports.

5.0 Electrical Interfaces: None.

6.0 Mounting Provisions: In-line tubing installed.

7.0 \* Permissible Materials: 17-7 PH, 316 AISI Stainless Steel, Viton "A" seal material.

8.0 \* Maximum Overall Envelope Dimensions: 1.56" dia x 4.40" long.

9.0 Performance Requirements:

\* With 100 to 200°F mixture of oxygen and water vapor supplied to the inlet, the regulator shall crack within and be capable of controlling the upstream pressure to 415 to 435 psia, when passing a 100 to 200°F saturated mixture of 0.154 to 1.750 lb/hr of oxygen independent of the downstream pressure. The regulator shall reseat (shut off oxygen flow) at 395 psia minimum. The regulator shall be capable of external adjustment of the upstream pressure within a range of 100 to 500 psia.

Working Fluid: Oxygen and water vapor.

Allowable Leakage Rate: No internal leakage after the reseating condition has been reached. No external leakage.

\* Downstream Working Fluid Pressures: 0 psia minimum; 265 psia maximum for 500 psia upstream pressure; 53 psia maximum for 100 psia upstream pressure; 15.5 psia nominal.

\* Upstream Working Fluid Temperatures: 50°F minimum; 250°F maximum; 150°F nominal.

\* Proof Pressure: 653 psig maximum.

Table III (Cont'd.)

\* REVISED

No. 73A490-831, Rev. B

Date 9/14/73

Page 2 of 2

\* Burst Pressure: 1000 psig maximum limited by bellows.

Environment Requirements: 40 to 110°F and 0 to 14.7 psia.

10.0 Continuous Mission Rate Duty: Steady-state flow for six (6) months varied within an oxygen range of 0.154 to 1.750 lb./hr. at 150°F saturated.

11.0 Cyclic Mission Rate Duty: 5514 cycles of oxygen/water vapor flow "on and off", i.e., one cycle equals 55 minutes of 150°F saturated oxygen "on" flow time at 1.75 lb./hr. and 39 minutes of no flow.

12.0 Reliability: Useful life - two (2) years.

No: 73A490-862

Date: November 16, 1973

Page 1 of 6

## WATER ACCUMULATOR SPECIFICATION

### 1.0 Functional Purpose

The water accumulator shall establish a water storage capacity during starting and operating transients in the water circuit of a water electrolysis system. It also shall provide three (3) position switches for identifying "empty" and "full" points of a smaller volume to be used for charging the system with make-up water, as well as the position for "maximum stroke".

### 2.0 Mechanical Description

The water accumulator shall consist of a pressurized cylindrical container having a spring-loaded piston or diaphragm separating the water storage chamber from a hydrogen chamber at a lower pressure. The quantity of water stored will be dependent upon the pressure differential ( $pH_2O - pH_2$ ) as opposed by a return spring. The differential area gained by incorporating a piston rod may be utilized for balancing forces to reduce spring force and size. The position switches shall be integrally mounted and provided with a single electrical connector.

### 3.0 Weight

Minimal weight shall be employed in the design consistent with the requirements of this specification. A weight estimate of the assembly shall be identified on drawings.

### 4.0 Port Configuration

Hydrogen boss	MS33649-4
Water boss	MS33649-4

Note: "NPT" pipe threads are not permitted.

### 5.0 Electrical Interface and Requirements

Magnetic reed switches may be utilized as position switches which will be connected to a logic circuit (not an end item) for controlling a make-up water pump used for charging the water accumulator.

Switch Rating: 0.25 amps resistive, 28 VDC

Both normally closed and normally open contacts available.



**Switch Location:** Three position switches shall be installed to signal volume point of the water accumulator per Table I.

**Electrical Connector:** An integrally mounted Bendix-type bulkhead male connector shall be provided including the mating female connector.

The water accumulator assembly shall be designed to be ignition proof, i.e., the assembly or components thereof, shall not be capable of igniting any explosive mixture existing in or surrounding the assembly either functioning or at standstill in accordance with Procedure II, Method 511 of MIL-STD-810B dated 15 June 1967.

Electrical wiring shall be properly supported and routed to prevent chafing, provide protection against sharp edges, mechanical strain, etc., and conform to MIL-W-16878. Color coding of conductors of the equivalent shall be provided for identification.

Bonding requirements in accordance with MIL-B-5087 Class H, R and S as applicable.

#### 6.0 Mounting Provisions

Mounting of the water accumulator shall have adequate structural integrity to assure compliance to this specification without mechanical failure or performance deterioration when subjected to:

- o Acceleration "hard" environment of Procedure I, Method 513, paragraph 3.2.4 with "Manned Aerospace Vehicle Category".
- o Vibration "hard" environment of Procedure I, Method 514, paragraph 4.5.1, Part 1 (sinusoidal vibration curve "P" and time schedule I) and paragraph 4.5.2, Part 2 (random vibration curve AG), MIL-STD-810B dated 15 June 1967.
- o Bench handling shock "hard" environment of Procedure V, Method 516, paragraph 3.7, MIL-STD-810B, dated 15 June 1967.

The mounting configuration of the water accumulator shall be designed for securement to a vertical plate, water side up.



7.0

Permissible MaterialsWetted Areas (Both water and hydrogen chambers)

Type 316, 321 A1S1 stainless steel, passivated; 316L, 321, 347 A1S1 stainless steel for welded parts, or solution anneal 316.

Type 316 (preferred), 302, 17-4 pH in springs.

No copper, iron, silver, zinc, nickel, cadmium or processes of brazing or soldering is permissible in wetted regions.

Elastomers: Teflon TFE, FEP, Viton A preferred  
Buna N acceptable.

Corrosion protection of large, exposed non-rubbing surfaces in the water chamber is desired by thermoplastic coating with FEP (fluorinated ethylene propylene).

Electroactivity contact of dissimilar metals per MS33586 shall be avoided.

Materials that could liberate toxic gases shall be avoided.

The use of metallic self-locking nuts is the preferred method to secure the assembly detail parts. Lockwire should be considered as an alternate approach. Star washers, jam nuts, lock washers, etc. shall not be used.

Assembly drawing copies with appropriate parts list, material identification and process specification definition shall be submitted to GE/DECP for review.

Redundant Viton "A" O-ring seals shall be introduced into the design in appropriate regions to assure no external leakage to ambient.

Rub wear materials which could contaminate the delivered water and/or hydrogen or compromise useful life shall be minimized.

Titanium is not permitted in the design.

Lubrication materials are not permitted in the design which could contaminate the water and hydrogen or leak to ambient.



## 8.0

Maximum Overall Envelope Dimensions

5.00 inch dia. x 24 inch long (including stroke)

Cylinder diameter and piston stroke shall be selected to minimize unit volume and weight, yet maintain optimum L/D considerations for smooth stroking performance of the accumulator.

Outline-installation drawing copies delineating all pertinent details of the water accumulator assembly (e.g., port title and fitting identification, connector identification and pin designation electrical schematic, detail installation and outline dimensions, servicing and acceptance test notes as necessary, rated requirements, etc.) shall be submitted to GE/DECP for review.

## 9.0

Performance Requirements

The water accumulator shall be in any attitude under cyclic operation capable of providing water storage capacity as a function of water pressure minus hydrogen pressure differential ( $\text{PH}_2\text{O} - \text{PH}_2$ ) according to Figure 1. The volume settings for switch positions are indicated with tolerances provided in Table I.




Figure 1



Table I

Percent Storage Capacity

<u>Switch Position</u>	<u>Volume Point-in.<sup>3</sup></u>	<u>Nominal</u>	<u>Switch Location Tolerance</u>
1. "Make-up H <sub>2</sub> O on"	0	0	0 - 10
2. * "Make-up H <sub>2</sub> O off"	5	25	22 - 28
3. "Max. Stroke"	20	100	90 - 100

\*Adjustable switch position is desirable, unit disassembly permissible.

Provision shall be made in the water accumulator design for adjustment of the return spring force as indicated by Figure 1. Unit disassembly for spring adjustment or for replacement with a spring of different size is permissible. Alteration of stroke length beyond 20 cubic inch capacity is permissible for spring adjustment.

Hysteresis due to friction shall be minimized to provide repeatable, smooth stroking within  $\pm 10\%$  of a mean linear pressure differential versus stroke characteristic.

## Fluid Media:

Water Side: Distilled water

Hydrogen Side: Saturated hydrogen with possible water condensate.

## Hydrogen Pressure:

Range: 100 to 365 psig

Design Point: 365 psig

## Water Pressure:

Greater than hydrogen pressure per Figure 1.

Maximum Pressure: 425 psig

Case Proof Pressure: 637 psig

Case Burst Pressure: 1060 psig

## Internal Seal or Diaphragm Differential Proof Pressure:

100 psid either direction



External Leakage: zero hydrogen or water at proof pressure

Internal Leakage: zero, water at proof pressure:  $pH_2O > pH_2$   
5 cc/hr hydrogen at proof pressure:  $pH_2 > pH_2O$

Environmental Conditions:

Ambient Pressure: 0 to 15 psia

Ambient/Fluid Temperature: 40 to 110°F

Gravity: 0 to 1 g any direction

10.0

Duty Cycle

Acceptable functional performance as defined in paragraph 9.0 for the following inclusive duty cycles.

<u>Percent "Maximum Stroke" Cycle</u>	<u>Rate</u>	<u>Total Cycles for 6 Months Mission</u>
0 - 100 - 0	one per 94 minutes	5,514
0 - 25 - 0	three per hour	15,000
± 2 at any point	one per minute	262,000

11.0

Reliability: Useful life (2) years.



# GENERAL ELECTRIC

AIRCRAFT  
EQUIPMENT  
DIVISION

GENERAL ELECTRIC COMPANY . . . . . DIRECT ENERGY CONVERSION PROGRAMS  
50 FORDHAM ROAD, WILMINGTON, MASS. 01887, Phone (617) 657-4610

April 3, 1975

National Aeronautics and Space Administration  
Johnson Space Center  
Houston, Texas 77058

Attention: Mr. R. B. Martin  
Mail Code EC 39

Subject: SSP 27-Cell Electrolysis Module Failure Analysis,  
Refurbishment, and Checkout by General Electric  
Company, Direct Energy Conversion Programs

Gentlemen:

The following is a chronology of the pertinent observations, measurements, and operations made by General Electric Company (GE) as part of the failure analysis, refurbishment and checkout of the SSP electrolysis module as received from NASA/JSC on March 3, 1975.

March 3, 1975

1. Removed module, delivered by R. Reysa, from carton - no apparent damage.
2. Checked all cells for electrical shorts using the capacitor charge technique with a Simpson Voltmeter. No shorts in all cells.
3. Measured 1000 Hz impedance of 27 cell stack (0.054 ohms) and of each cell (0.0016 to 0.0021 ohm range) which compared closely with measurement (0.00158 to 0.00189 ohm range) made during original buildup by GE on September 12, 1973.
4. Pressurized oxygen side with nitrogen at 22 psig. Gross leakage out H<sub>2</sub> ports to atmosphere was observed. Closed both H<sub>2</sub> side MDV's and raised pressure to 50 psig. No overboard (gasket) leakage was apparent.



## Direct Energy Conversion Programs

Mr. R. B. Martin

-2-

April 3, 1975

5. Set up module in a test hood with DC power supply, feed water pump at 5 to 7.0 psig, and H<sub>2</sub> and O<sub>2</sub> sides vented approximately to atmospheric pressure. During electrolysis operation at about one ampere, all cells exhibited expected voltage level (1.48 VDC).
6. Measured the outside distances of end plates and residual break away torque tension tie bolts. Values were essentially as measured at NASA/JSC prior to delivery to GE/DECP.
7. Removed module bellyband, tie rod nuts, belleville washers, and rear end plate. Cell No. 27 was removed and inspected. No gasket damage was evident and the imprint of the gasket dual bead rings on the cell solid polymer electrolyte (SPE) membrane was not severe enough to cause damage or leakage. Some corrosion of the anodized aluminum end plate was caused by water trapped in the pressure pad area during assembly. This corrosion cannot reach the cells or interfere with module performance or sealing capability.

March 4, 1975

1. Measured about 0.06 to 0.09 inch growth in stack height over night as evidence of gasket recovery without load, since the tie rods were not installed. Retorque tie bolts to 45 inch-pounds to reevaluate gasket seal.
2. Pressurized oxygen side with nitrogen at low pressure showing gross leakage as before.
3. Supplied a mixture of 5% H<sub>2</sub>/95% N<sub>2</sub> first to O<sub>2</sub> (dead ended) side and purged H<sub>2</sub> side with air. Fuel cell charging capability was under 0.2 VDC for most cells. Reversed the gas supplies to provide 5% H<sub>2</sub>/95% N<sub>2</sub> to H<sub>2</sub> side, air to O<sub>2</sub> side. Cell Nos. 3, 6, 10, 12, 13, 14, 17, 18, 19, 20, 22, 23, 25, 26, 27 evidenced open circuit values under 0.4 VDC. Test was not considered conclusive in locating cells with cross membrane leakage because of blockage and masking effects of entrapped residual water in the cells from electrolysis operation.
4. Module disassembly was initiated and using a plexiglass clamping fixture cell assemblies (M&E plus screens and gaskets) from No. 27 down through Cell No. 22 were leak checked at about 1/2 psi air pressure with the active area submerged in water. Because the air pressure would distend the membrane and wrinkle the protector ring welded to the screens, allowable pressure was very limited to the 1/2 psi value. No bubbles as evidence of leakage were observed.

**GENERAL ELECTRIC**

**Direct Energy Conversion Programs**

Mr. R. B. Martin

-3-

April 3, 1975

March 5, 1975

1. Continued leak checking. Cells 21 down through 17 showed no leakage.
2. The module with its 16 remaining cells was compressed using "C" clamps on the end plates and leak checked for cross membrane leakage. Gross leakage still existed.
3. Remaining cells with their associated screens were individually tested for leakage. Cell No. 4 was found to have a small pin hole in the membrane at the edge of the catalyst region near the H<sub>2</sub> outlet port. Pin hole was only detectable by holding cell against a fluorescent light background. The tongued portion of the H<sub>2</sub> side screen protruding into the H<sub>2</sub> outlet port showed evidence of slightly brown oxidized surface. The oxygen side of the membrane showed a fanned out region from the hole exhibiting cracked catalyst, whereas the H<sub>2</sub> side showed indentations or dimples (between screen openings) resulting from membrane heating and distortion from H<sub>2</sub> > O<sub>2</sub> pressure differential. The hole itself was fish-mouthed toward the H<sub>2</sub> side indicating O<sub>2</sub> over pressure. Inspection of adjacent screening did not reveal any barbs or broken strands which might have caused the membrane puncture.
4. Measurement of the screen and gasket thickness showed the molded gaskets averaged 0.030 to 0.031 (0.025/0.029 per drawing in the flat unheaded region), whereas the screens were 0.023 for a difference of 0.007 to 0.008. Bead height was about 0.011 inches on each side. Assuming 100% impression of the beads and as confirmed by stack/component measurements during stack assembly and from component and overall stack dimensions an average 0.008 inch rubber deflection per cell was calculated. This calculates to about 7.5 percent compression of 0.106 inch rubber per cell (2 x 0.0305 cell gaskets plus 0.045 manifold gasket) in the flat region. The torque region at the manifold ports has the lowest loading or gasket pressure and in view of the 0.007 inch height difference was vulnerable to local unloading of the gasket due to rubber relaxation, O<sub>2</sub>/H<sub>2</sub> mixing in the manifold region and high pressure differential and local heating which damaged the cells.

March 6, 1975

1. Measurements of cell gaskets revealed that the gaskets were molded 0.001 inch thicker in the O<sub>2</sub> and H<sub>2</sub>O port region than at the H<sub>2</sub> outlet port region. Since the stack assembly contains 54 cell gaskets, the 0.054 inch total differential explained the apparent tendency toward non-parallelism of end plates during tightening of the bolts with uniform torque measurements. It also may explain the



## Direct Energy Conversion Programs

Mr. R. B. Martin

-4-

April 3, 1975

### 1. Continued

tendency toward unloading and possible leakage of the gasket in the H<sub>2</sub> outlet port region.

2. Review of NASA/JSC data from testing on 2-19-75 showed evidence of module cross membrane (or manifold) leakage, i. e., fairly rapid increase of about 1 psi/min in oxygen pressure, during the period of holding H<sub>2</sub> side pressure at 30 to 35 psig for system pressurization and startup.
3. The test data on 2-19-75 at 1:57:36 DARS time showed an oxygen pressure decay rate of 1. 6 psi/min during the shutdown period which sharply increased and resulted in severe manifold leakage and probably primary cell damage when the oxygen pressure suddenly dropped from 10. 4 to 7. 70 psig as the module voltage dropped from 26. 16 to 7. 41 volts in 7. 3 seconds at about 2:00:00 DARS time. This abrupt loss of oxygen pressure and cell voltage occurs when rapid hydrogen admission to the O<sub>2</sub> side consumes most of the oxygen within the cell screen cavity and at the electrode with local temperatures which can soften and damage the SPE membrane. Further testing the same day revealed normal cell operation and lower oxygen pressure decay rates during subsequent shutdowns probably due to resealing of the gaskets due to rubber expansion at higher module operating temperature. At oxygen pressures under 20 psig or at H<sub>2</sub> > O<sub>2</sub> pressure differentials greater than 25 psid during shutdown further evidence of excessive leakage was revealed by an increasing oxygen pressure (3:05:14 DARS time) as hydrogen (and water) leaked into the oxygen side.

March 7, 1975

1. A repeat of individually leak checking of cells was performed with the screen assemblies removed in test fixture up to an air pressure of 31 inch water column. Found Cell No. 7 a leaker from a small pin hole in addition to Cell No. 4, and rejected Cell No. 8 because of overheated damaged area in the sealing region near the O<sub>2</sub> port. Cells No. 1, 2, 3, 5, 6, 9, 10, 11, 12 and 13 showed no evidence of leakage by air bubble formation inside the flooded catalyst area

March 10, 1975

1. Completed individual leak checking of cells and rejected Cell Nos. 17, 18, 19 and 26 because of leakage. Discovered air pressures as high as 18 and 26 inch W.C. in two cases which were required for air bubble break through because of water sealing of the small pin holes at lower pressures.

**GENERAL  ELECTRIC**

**Direct Energy Conversion Programs**

Mr. R. B. Martin

-5-

April 3, 1975

2. Pressed a sample cell assembly (using No. 4 M&E assembly) including pressure pads in Wabash hand press up to 12 ton load to measure gasket deflection and to visually inspect afterward for any signs of excessive embossing of separator sheets in the port area from 0.005 shim. Sample OK.

March 11, 1975

1. Visually inspected all cells under a microscope first using the rejected leaking cells as a reference. All cells showed some evidence of locally cracked catalyst from overheating, particularly on the O<sub>2</sub> side near the O<sub>2</sub> port or dimpling or cratering between screen openings on the H<sub>2</sub> side due to softening of the SPE membrane and H<sub>2</sub> > O<sub>2</sub> differential pressure. Cell Nos. 10, 13, 20 and 22 were rejected on the basis where opposite sides both showed local damage as described.

March 13, 1975

1. Reassembled module with 16 cells (1, 2, 3, 5, 6, 9, 11, 12, 14, 15, 16, 21, 23, 24, 25 and 27) having been refurbished as follows:

- a) The bolt holes in the 0.005 inch thick niobium separator sheets were elongated 0.03 to 0.06 inch, sheets were reflattened, solvent cleaned, vapor degreased and ultrasonically cleaned. Voltage tabs were spot welded to edge of separator sheets.
- b) Eyelets on the protector rings surrounding the manifold ports were trimmed off to increase gasket sealing area. Other electrolysis hardware has shown this eyelet to be ineffective in protecting the silicone rubber from the SPE and could interfere with sealing capability.
- c) Gasket and screen assemblies were cleaned in water and gaskets were re-attached to protector rings using silicone rubber adhesive as required.
- d) Niobium shims 0.005 inch thick were tack welded to screens in the tongued port region on the side facing the separator sheet to accommodate the unequal assembly thickness.
- e) Removed wrinkled and damaged teflon sleeving from tie bolts and applied heat shrinkable polyolefin HS-101 tubing (Original 0.280 O.D. x 0.12 inch wall, Manufacturer: Insultab, Inc., Waltham, Mass.). Original heat shrinkable teflon tubing was not in stock and would require seven to 10 days delivery time.

**GENERAL  ELECTRIC**

**Direct Energy Conversion Programs**

Mr. R. B. Martin

-6-

April 3, 1975

- f) Made eighteen 1.30 inch long stainless steel spacer sleeves for tie bolts to compensate for reduced stack width of eleven cells left out.
- g) Reduced width of sheet metal band surrounding module to 3.50 inches and removed harness for measurement of cell voltages 17 through 27.
- h) Measured belleville washer stack height and module end plate distances at tie bolt torque values of 45 and 60 in-lb and let sit overnight.

March 14, 1975

1. Electrically checked all cells for shorts, and shorts to ground with Simpson meter. All cells OK.
2. Measured residual torques on tie bolts (46 in-lb average) and retorqued to 75 in-lb.
3. Pressurized H<sub>2</sub> side with N<sub>2</sub> at 50 psig and measured 41.2 cc/min out O<sub>2</sub> port. This was excessive. Reduced N<sub>2</sub> pressure to 50 inch H<sub>2</sub>O and leak was hardly detectable by H<sub>2</sub>O slug movement in 1/4 inch tygon line. Increased N<sub>2</sub> pressure and measured 6.4 cc/min leakage at 7.2 psig ( $6.4 \times \frac{50}{7.2} = 45$  cc/min).

Conclusion: Probable sealing of very fine pin hole with water at bubble points under 50 inch H<sub>2</sub>O.

4. Disassembled module and individually leak checked each cell with air at 40 psig while clamped between the module end plates with four "C" clamps. Found original Cell No. 5 leaked and all others OK. Subsequent microscopic inspection of Cell No. 5 revealed an isolated region of cracked catalyst on the O<sub>2</sub> side about two inches from O<sub>2</sub> port. A small isolated dimple and hole was also visible on the opposite side.

March 17, 1975

1. Reassembled electrolysis module with 15 cells in following order 1, 2, 3, 6, 9, 11, 12, 14, 15, 16, 21, 23, 24, 25 and 27 in positions 1 through 15.

NOTE: (With the removal of original Cell No. 5 from position No. 4, voltage tabs of positions 4 through 15 are labeled (under bellyband) 5 through 16 consecutively.)

Measured belleville washer stack height and end plate distances at tie bolt torque values of 15, 30, 45, 60 and 75 inch-lbs. See data in Table I.

**GENERAL ELECTRIC**  
Direct Energy Conversion Programs

Mr. R. B. Martin

-7-

April 3, 1975

2. Leak checked module with H<sub>2</sub> side pressurized with N<sub>2</sub> at 50 psig and measured 3.5 cc/min out O<sub>2</sub> port. Calculated theoretical N<sub>2</sub> diffusion through 15 cells at 50 psid is 3.67 cc/min.
3. Discussed observations and conclusions of failure analysis to date and module refurbishment with R. Gillen, NASA/JSC during his brief visit to GE/DECP in late afternoon. Presented him with M&E of failed Cell No. 4 and additional cell parts for NASA inspection.

March 18, 1975

1. Measured washer and end plate distances, residual torques (average 63 inch-lbs) and retorqued to 75 inch/lb.
2. Pressurized H<sub>2</sub> and O<sub>2</sub> sides in common with air at 50 psig and module submerged in water tank. Observed no visible leakage.
3. Assembled module dolly base to front end plate, connected voltage leads to voltage tabs using teflon insulating tape, and attached sheet metal band with hose clamps.
4. Retorqued tie bolts to 90 inch-lb and recorded measurements.
5. Placed assembled module in air circulated oven at 120°F at 1600 hours.
6. Informed R. Reysa, B. Pond, NASA/JSC by telephone to reduce power supply input to 34 VDC and to reduce output power conditioner shutdown voltage to 29 to 30 VDC by altering resistors in emergency controller.

March 19, 1975

1. Removed module from oven at 122°F at 0815 hours and measured residual torques, belleville washer heights and end plate distances while still hot.
2. Installed module in low pressure test hood with compound gages at H<sub>2</sub> and O<sub>2</sub> ports and operated at 2 ampere load. Found Cell No. 1 partially shorted by voltage tab against negative terminal plate and with lead wires of cell position No. 14 and No. 15 reversed. Added additional electrical insulation and corrected reversed wires. Short test with Simpson meter showed all cells OK.

**GENERAL ELECTRIC**

**Direct Energy Conversion Programs**

Mr. R. B. Martin

-8-

April 3, 1975

3. Operated electrolysis module at 5 to 7 psig water input pressure and approximately 0.5 psig O<sub>2</sub> and H<sub>2</sub> output pressure, with applied loads of 2, 10, 20, 30, 40, 50, and 60 amperes. Normal cell voltages (all under 1.66 VDC @ 60 amperes) were recorded on all cells.
4. Closed off valves at H<sub>2</sub>O in, H<sub>2</sub> out, and O<sub>2</sub> outlet ports while monitoring pressure on H<sub>2</sub> and O<sub>2</sub> cavities with compound gages. After 54 minutes (lunch hour) H<sub>2</sub> pressure was 22.5 inch Hg vacuum and O<sub>2</sub> pressure was 10.9 inch Hg vacuum. Because some residual water is trapped in the H<sub>2</sub> side and two volumes of H<sub>2</sub> gas are consumed for each volume of O<sub>2</sub> gas to form water, in time all H<sub>2</sub> would be consumed and O<sub>2</sub> would occupy both sides at equal pressure. This is called an "oxygen takeover". Test was repeated after a few minutes of electrolysis operation monitoring module voltage and pressures for 25 minutes with values plotted in Figure 1.
5. After module operation at 10 amps and shutdown, the O<sub>2</sub> outlet valve was closed and H<sub>2</sub> side valves remained open allowing communication with the water supply at atmospheric pressure. The data plotted in Figure 2 was recorded over a 45 minute period of an eventual "hydrogen takeover". These tests demonstrated the behavior of the electrolysis module with regard to voltage and gas pressures after shutdown at atmospheric pressure. Decay rates would be affected by the gas pressures at shutdown and the trapped volumes on each side. The ability of the module in this test to support a vacuum condition and differential pressure over a one hour period of time verified the integrity of the cells and gasket seals.

March 20, 1975

1. Measured residual torques (68.8 in-lb average), module dimensions and retorqued tie bolts to 100 in-lb.
2. Purged H<sub>2</sub> side of residual water with nitrogen and conducted cross membrane leak check with H<sub>2</sub> side pressurized with N<sub>2</sub> at 50 psig. Measured 4.16 cc/min out O<sub>2</sub> port which was acceptable.
3. Purged and pressured H<sub>2</sub> side with helium gas to 50 psig and measured a rate of 20.2 cc/min out O<sub>2</sub> port at atmospheric pressure. Because of the high diffusion rate of helium gas through the SPE, nitrogen gas is normally used for multiple cell cross membrane leak checks to avoid masking of a pin hole leak.
4. Retorqued tie bolts to 100 in-lb and recorded dimensions in Table I. Checked cells for shorts. All OK.

**GENERAL ELECTRIC**  
Direct Energy Conversion Programs

Mr. R. B. Martin

-9-

April 3, 1975

5. Attached handles, brackets, and packed for shipment.

NOTE: Rear end plate was discovered rotated by one bolt hole such that rear handle is tilted 20°. It was left in this manner to avoid delay in shipment.

March 24, 1975

1. Electrolysis module delivered to NASA/JSC by A. C. Erickson, GE/DECP.

**CONCLUSIONS AND RECOMMENDATIONS**

The following conclusions and recommendations are provided to NASA/JSC which have resulted from the module failure analysis, refurbishment and subsequent oxygen generation system testing at NASA/JSC.

1. Electrolysis module failure is attributed to unloading of the cell gaskets in the fluid port area, over a 20 month period, which resulted in leakage from the hydrogen manifold into the oxygen screen cavity of one or more cells at a pressure differential greater than 20 psid. This was caused by inadequate local compression of the gasket for the reasons described herein (See chronology date March 5, 1975).
2. The refurbished module contains 15 of the 27 damaged original cells which exhibited normal performance and sealing capability as demonstrated by electrolysis operation at full load and from supportive leak checks. The integrity of the damaged SPE membranes is unknown, and cross membrane gas diffusion rates should be monitored during periods of high  $H_2 > O_2$  pressure differential as during initial pressurization and after removal of electrical load. Based on observations made during system tests at NASA/JSC on March 27, 1975, an oxygen side pressure rise of about 3.0 psi/hr appears normal during system pressurization with the  $H_2$  side at 30 to 35 psig. Also, an oxygen side pressure decay rate of 0.7 psi/min was measured after load removal at operating pressures. Abrupt or severe departure from these rates would indicate excessive cross membrane leakage and the module should be leak checked on the bench with nitrogen gas.
3. Detection of hydrogen in the oxygen output stream was provided in the oxygen generation subsystem, as designed, by two combustible gas detectors at the oxygen discharge to atmosphere. This capability was lost by the installation of an oxygen output line to a saturator, wet test meter and discharge outside the building at NASA/JSC. Some means of continuous detection of hydrogen in the

Mr. R. B. Martin

-10-

April 3, 1975

## 3. Continued

oxygen stream is recommended during electrolysis operation to stop system operation thus avoiding a mixture buildup in downstream components. A brief discussion of electrolysis module failure as experienced on February 19, 1975 at NASA/JSC and the potential safety hazard is offered. Internal cross membrane leakage as experienced, results in the mixing of hydrogen and oxygen within the screen cavity and combination at the electrode catalyst with the generation of heat. For the rates involved, the relatively high activity and surface area of the catalyst to the small cell volume occupied by multi-layered screening prevents the accumulation of a mixture in an explosive volume. During electrolysis operation, the continuous supply of water for heat removal and the self-quenching capability of water leakage along with any hydrogen admitted to the oxygen cavity results in relatively unaffected module operation as experienced on February 19, 1975. Depending on the size and location of the leakage point, some hydrogen may bypass the catalyst area and be carried out the oxygen manifold which is a small tube like volume formed by the alignment of holes in the stack of rubber gaskets. Because of the process and configuration described, the formation of a quantity of gas mixture and an amount of energy which could result in an internal pressure rise or rupture of the assembly or components is extremely remote as demonstrated by the 27-cell module failure. Rather, it has been found from pressure tests that a gasket-type assembly as used in the module design provides a self-venting feature by local separation or displacement of the gaskets.

4. The beaded gasket design was introduced for the first time into the SSP electrolysis module delivered to NASA/JSC. Since only short-term acceptance tests were employed before shipment, no continuous long-term evaluation of the design and ensuing rubber relaxation phenomena was possible. It is felt that the molded dual-bead sealing concept is a sound design and failure in the manifold region was due to inadequate control of tolerances and rubber deflection under load. Because it is difficult to maintain the tolerances in rubber fabrication as closely as desired, future compensation will be made by the adjustment in the pressed height of the cell screen package. That is, shims or stops will be used during manufacture of the multi-layered screen package to provide a difference of 0.002 to 0.004 inch between the measured face rubber thickness (flat region) and screen assembly as adjusted. Previous flat gasket design criteria employed a nominal 10 percent initial rubber deflection during assembly for sealing internal gas pressures up to 100 psig. Local rubber deflection in the beaded gasket during module assembly could be 50 percent in the beaded region and was calculated at 10 percent in the

**GENERAL  ELECTRIC**

**Direct Energy Conversion Programs**

**Mr. R. B. Martin**

**-11-**

**April 3, 1975**

**4. Continued**

flat region from end plate measurements. It is recommended that periodic measurements at 2 to 3 month intervals be made of belleville washer stack height (See Table I) and the tension tie bolts should be retorqued to 90-100 inch-lb when average washer height expands beyond 1.750 inches.

**Very truly yours,**

**A. C. Erickson  
Project Engineer - Electrolysis System  
Building 1A  
Tele. No.: (617) 657-4698**

ORIGINAL PAGE IS  
OF POOR QUALITY

TABLE I

ELECTROLYSIS MODULE THE BOLT TORQUE AND DIMENSIONAL MEASUREMENTS

DATE TIME	3-17-75					3-18-75					3-19-75					3-20-75					3-24-75	
	1010	1030	1112	1250	1340	1620	0815	0815	0900	1005	1550	0815	0815	0840	0915	1130	1145	1100	1100	Electrolysis Operation	Lenk Check	Lenk Check
BOLT POSITION*	BELLEVILLE WASHER STACK HEIGHT** AND MEASURED RESIDUAL BREAKAWAY TORQUE ON BOLT																					
** Includes 40 Washers (Theo. Solid Hgt. = 1.400") Two .063" Flat Washers and .188" Head of Guide																						
*In clockwise order facing washer end of module. H <sub>2</sub> out port at 12:00 o'clock, H <sub>2</sub> O in port at 6:00, No. 1 to right of H <sub>2</sub> port, No. 10 between O <sub>2</sub> and H <sub>2</sub> ports.	1	2.010	1.975	1.926	1.894	1.816	1.816	1.814	65	1.800	1.740	1.736	1.738	100	1.752	66	1.733	90	1.732	1.736	72	
	2	1.991	1.952	1.907	1.861	1.791	1.775	1.786	62	1.766	1.737	1.734	1.735	90	1.751	65	1.724	95	1.728	1.731	66	
	3	1.992	1.956	1.915	1.864	1.801	1.794	1.800	63	1.776	1.733	1.732	1.735	85	1.751	65	1.726	100	1.727	1.735	68	
	4	2.015	1.979	1.938	1.899	1.851	1.849	1.859	59	1.858	1.793	1.737	1.737	85	1.757	64	1.738	95	1.736	1.741	68	
	5	1.988	1.951	1.906	1.859	1.792	1.776	1.782	65	1.767	1.737	1.733	1.734	90	1.752	66	1.728	95	1.729	1.734	65	
	6	2.005	1.976	1.935	1.893	1.846	1.842	1.846	62	1.844	1.761	1.742	1.742	95	1.760	66	1.739	95	1.736	1.740	60	
	7	2.010	1.973	1.943	1.898	1.840	1.826	1.834	63	1.817	1.742	1.742	1.742	93	1.760	68	1.732	100	1.731	1.735	68	
	8	1.991	1.961	1.923	1.875	1.825	1.821	1.828	63	1.818	1.755	1.746	1.749	90	1.768	68	1.735	100	1.735	1.740	68	
	9	1.994	1.961	1.915	1.864	1.805	1.799	1.804	66	1.792	1.742	1.731	1.733	95	1.750	65	1.725	97	1.729	1.735	55	
	10	1.999	1.976	1.930	1.889	1.823	1.820	1.824	64	1.816	1.772	1.762	1.766	95	1.782	75	1.764	90	1.750	1.750	64	
	11	2.012	1.985	1.946	1.904	1.872	1.869	1.873	60	1.870	1.833	1.741	1.742	98	1.757	70	1.747	90	1.743	1.749	72	
	12	1.990	1.950	1.906	1.857	1.790	1.790	1.795	74	1.797	1.749	1.750	1.750	90	1.768	65	1.740	94	1.736	1.739	65	
	13	2.010	1.959	1.907	1.844	1.776	1.763	1.767	70	1.760	1.732	1.731	1.733	96	1.747	65	1.738	95	1.729	1.732	58	
	14	2.013	1.975	1.911	1.858	1.766	1.754	1.757	55	1.754	1.732	1.726	1.732	85	1.747	60	1.728	93	1.732	1.734	54	
	15	2.002	1.964	1.921	1.868	1.814	1.807	1.813	62	1.807	1.749	1.750	1.749	90	1.766	70	1.741	94	1.737	1.744	62	
	16	2.013	1.979	1.937	1.900	1.836	1.820	1.827	62	1.817	1.747	1.743	1.739	95	1.751	60	1.732	90	1.732	1.734	68	
	17	1.985	1.936	1.888	1.827	1.773	1.768	1.772	59	1.767	1.732	1.741	1.736	95	1.748	65	1.726	100	1.727	1.731	74	
	18	2.000	1.948	1.903	1.844	1.777	1.763	1.769	59	1.762	1.733	1.733	1.732	85	1.746	58	1.725	100	1.727	1.732	66	
	Avg.	2.001	1.964	1.920	1.872	1.811	1.803	1.808	62.9	1.799	1.751	1.739	1.740	91.8	1.756	68.8	1.735	95.2	1.733	1.737	65.2	
	Δ	-.037	-.044	-.048	-.061	-.008	+.005			-.009	-.048	-.012	+.001		-.016		-.022		-.002	+.004		
CLOCK POSITION	OVERALL DISTANCE OUTSIDE OF END PLATES, INCHES																					
12	18/1	4.700	4.654	4.635	4.625	4.611	4.605	4.597		4.591	4.578	4.569	4.570		4.556		4.536		4.532	4.532		
2	3/4	4.741	4.693	4.678	4.660	4.646	4.641	4.633		4.624	4.614	4.607	4.602		4.586		4.566		4.565	4.563		
4	6/7	4.773	4.721	4.697	4.678	4.659	4.655	4.650		4.642	4.637	4.626	4.634		4.607		4.595		4.587	Not Meas.		
6	9/10	4.784	4.734	4.702	4.678	4.659	4.654	4.650		4.612	4.633	Not Measured			Not Measured		4.595		4.594	"		
8	12/13	4.746	4.679	4.646	4.633	4.615	4.608	4.607		4.598	4.593	4.589	4.575		4.556		4.560		4.558	"		
10	15/16	4.688	4.661	4.663	4.621	4.596	4.588	4.578		4.574	4.568	4.563	4.553		4.544		4.530		4.526	4.515		
	Avg.	4.740	4.690	4.665	4.649	4.631	4.625	4.619		4.612	4.604	4.591	4.587		4.570		4.564		4.560			
	Δ	-.050	-.025	-.016	-.018	-.006		-.006		-.007	-.008	-.013	-.004		-.017		-.006		-.004			
Applied Torque In-lbs. Comment	15	30	45	60	75	75			75	90	90	Re-torque @ 120°F	Hot check @ 70°F	Overnite set @ 70°F	Re-torque	100		100	Re-torqued torque #9 and 10 to 75 in-lb at NASA/JSC			




Figure 1.

ORIGINAL PAGE IS  
OF POOR QUALITY

GENERAL  ELECTRIC




Figure 2.

